



*Commonwealth of Virginia*

**VIRGINIA DEPARTMENT OF ENVIRONMENTAL QUALITY**

VALLEY REGIONAL OFFICE

P.O. Box 3000, Harrisonburg, Virginia 22801  
(540) 574-7800 FAX (804) 698-4178

Located at 4411 Early Road, Harrisonburg, Virginia

[www.deq.virginia.gov](http://www.deq.virginia.gov)

Travis A. Voyles  
Acting Secretary of Natural and Historic Resources

Michael S. Rolband, PE, PWD, PWS Emeritus  
Director  
(804) 698-4000

November 29, 2022

Tiffany R. Severs  
Regional Director

Mr. Michael Foeckler  
VP of Operations and Facility Planning  
Christendom Educational Corporation  
Sent by Email ([mfoeckler@christendom.edu](mailto:mfoeckler@christendom.edu))

**NOTICE OF VIOLATION**

Re: Notice of Violation No. W2022-11-V-0003  
Christendom College STP  
VPDES Permit No. VA0067067

Dear Mr. Foeckler:

This letter notifies you of information upon which the Department of Environmental Quality (Department or DEQ) may rely in order to institute an administrative or judicial enforcement action. Based on this information, DEQ has reason to believe that Christendom Educational Corporation may be in violation of the State Water Control Law, Regulations, and VPDES Permit No. VA0067067 (Permit) at Christendom College STP (Facility), located at 134 Christendom Drive, Front Royal, VA 22630.

This letter addresses conditions at the facility named above, and also cites compliance requirements of the State Water Control Law, Regulations, and Permit. Pursuant to Va. Code § 62.1-44.15 (8a), this letter is not a case decision under the Virginia Administrative Process Act, Va. Code § 2.2-4000 *et seq.* (APA).

**OBSERVATIONS AND LEGAL REQUIREMENTS**

On November 7, 2022, DEQ staff conducted a Compliance Evaluation Inspection of the Facility. The report for that inspection is enclosed. The following describe the staff's factual observations and identifies the applicable legal requirements:

**Observation:** An accumulation of solids was observed in the receiving stream downstream of Outfall 001.

Legal Requirements: Permit Part II.F states, "Except in compliance with this permit, or another permit issued by the Board, it shall be unlawful for any person to:

1. Discharge into state waters sewage, industrial wastes, other wastes, or any noxious or deleterious substances; or
2. Otherwise alter the physical, chemical or biological properties of such state waters and make them detrimental to the public health, or to animal or aquatic life, or to the use of such waters for domestic or industrial consumption, or for recreation, or for other uses."

Permit Part II.Q requires the permittee to properly operate and maintain all facilities and systems of treatment and control (and related appurtenances) which are installed or used by the permittee to achieve compliance with the conditions of this permit.

Observation: A current O&M Manual is not maintained for the Facility.

Legal Requirement: Permit Part I.D.4 requires the permittee to maintain a current O&M Manual for the treatment works that is in accordance with Virginia Pollutant Discharge Elimination System Regulations, 9VAC25-31 and (for sewage treatment plants) Sewage Collection and Treatment Regulations, 9VAC25-790.

Observation: Maintenance is not performed in accordance with the O&M Manual as indicated by the condition of the chlorine contact tank baffles.

Legal Requirement: Permit Part I.D.4 requires the permittee to operate the treatment works in accordance with the O&M Manual.

Observation: Documentation of compliance with the permit requirement that there shall be no discharge of floating solids or visible foam in other than trace amounts is not completed in accordance with the O&M Manual.

Legal Requirement: Permit Part I.D.4 requires the permittee to operate the treatment works in accordance with the O&M Manual.

### **ENFORCEMENT AUTHORITY**

Va. Code § 62.1-44.23 of the State Water Control Law provides for an injunction for any violation of the State Water Control Law, any State Water Control Board rule or regulation, an order, permit condition, standard, or any certificate requirement or provision. Va. Code §§ 62.1-44.15 and 62.1-44.32 provide for a civil penalty up to \$32,500 per day of each violation of the same. In addition, Va. Code § 62.1-44.15 authorizes the Department to issue orders to any person to comply with the State Water Control Law and regulations, including the imposition of a civil penalty for violations of up to \$100,000. Also, Va. Code § 10.1-1186 authorizes the Director of DEQ to issue special orders to any person to comply with the State Water Control Law and regulations, and to impose a civil penalty. Va. Code §§ 62.1-44.32 (b) and 62.1-44.32 (c) provide for other additional penalties.


### **FUTURE ACTIONS**

DEQ staff wish to discuss all aspects of their observations with you, including any actions needed to ensure compliance with state law and regulations, any relevant or related measures you plan to take or have taken, and a schedule, as needed, for further activities. In addition, please advise us if you dispute any of the observations recited herein or if there is other information of which DEQ should be aware. In order to avoid adversarial enforcement proceedings, Christendom Educational Corporation may be asked to enter into a Consent Order with the Department to formalize a plan and schedule of corrective action and to settle any outstanding issues regarding this matter, including the assessment of civil charges.

In the event that discussions with staff do not lead to a satisfactory conclusion concerning the contents of this letter, you may elect to participate in DEQ's Process for Early Dispute Resolution. Also, if informal discussions do not lead to a satisfactory conclusion, you may request in writing that DEQ take all necessary steps to issue a final decision or fact finding under the APA on whether or not a violation has occurred. For further information on the Process for Early Dispute Resolution, please see Agency Policy Statement No. 8-2005 posted on the Department's website under "Permits and Regulations," and "Enforcement,""  
([https://townhall.virginia.gov/L/GetFile.cfm?File=C%5CTownHall%5Cdocroot%5CGuidanceDocs%5C440%5CGDoc\\_DEQ\\_2672\\_v1.pdf](https://townhall.virginia.gov/L/GetFile.cfm?File=C%5CTownHall%5Cdocroot%5CGuidanceDocs%5C440%5CGDoc_DEQ_2672_v1.pdf)) or ask the DEQ contact listed below.

Please contact Celeste Horton at (540) 830-4677 or [celeste.horton@deq.virginia.gov](mailto:celeste.horton@deq.virginia.gov) by December 9, 2022, to discuss this matter and arrange a meeting.

Sincerely,



Brandon D. Kiracofe  
Regional Water Permits & Compliance Manager

cc: ECM Compliance  
Linda Ferguson Davie – VRO (electronic)  
Tiffany Severs – VRO (electronic)  
Celeste Horton – VRO (electronic)  
Inboden Environmental Services, Inc. ([compliance@inbodenenv.com](mailto:compliance@inbodenenv.com))

# Virginia Department of Environmental Quality

## Wastewater Facility Inspection Report

### Preface

VPDES Permit No.	(Re)Issuance Date	Modification Date	Expiration Date
VA0067067	01/01/2019	--	12/31/2023
Facility Name	Address		Telephone Number
Christendom College STP	134 Christendom Drive, Front Royal, VA 22630		(540) 636-2900
Owner Name	Address		Telephone Number
Christendom Educational Corporation	134 Christendom Drive, Front Royal, VA 22630		(540) 636-2900
Responsible Official	Title		Telephone Number
Tom Heim (tom.heim@christendom.edu)	Director of Operations		(540) 636-2908
Additional Contact	Title		Telephone Number
Mike Foeckler (mfoeckler@christendom.edu)	VP of Operations & Facility Planning		(540) 636-2900
Responsible Operator	Operator Certification Class/Number		Telephone Number
Mark E. Inboden (minboden@Inbodenenv.com)	Class 1 / 19650095252		(540) 477-3300

#### A. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS

1. During the period beginning with the permit's effective date and lasting until the permit's expiration date or until the issuance of the Certificate to Operate (CTO) for the 0.04 MGD or 0.05 MGD facility, whichever occurs first, the permittee is authorized to discharge from Outfall 001.

This discharge shall be limited and monitored as specified below:

	EFFLUENT CHARACTERISTICS		DISCHARGE LIMITATIONS			MONITORING REQUIREMENTS	
	Monthly Average	Weekly Average	Minimum	Maximum	Frequency	Sample Type	
Flow (MGD) <sup>a</sup>	NL	NA	NA	NL	1/Day	Estimate	
pH (standard units)	NA	NA	6.5	9.5	1/Day	Grab	
CBOD <sub>5</sub> <sup>b</sup>	24 mg/L	2.3 kg/d	36 mg/L	3.4 kg/d	1/Week	8 HC	
Total Suspended Solids <sup>b</sup>	30 mg/L	2.8 kg/d	45 mg/L	4.3 kg/d	1/Week	8 HC	
E. coli (N/100 mL) <sup>c</sup>	126	Geometric Mean	NA	NA	4/Month in any month of each calendar year		
Total Residual Chlorine (TRC)(mg/L) <sup>c</sup>	0.0080	0.0098	NA	NA	10 a.m. to 4 p.m.	Grab	
Dissolved Oxygen (mg/L)	NA	NA	6.0	NA	1/Day	Grab	
Ammonia-N (Jun-Dec) (mg/L) <sup>c</sup>	1.6	2.4	NA	NA	1/Week	8 HC	
Ammonia-N (Jan-May) (mg/L) <sup>c</sup>	2.2	3.1	NA	NA	1/Week	8 HC	

NL = No Limitation, monitoring required    NA = Not Applicable    8 HC = 8-Hour Composite

4/Month in any month of each calendar year = 4 samples taken, with at least 1 sample taken each calendar week, in any calendar month and reported no later than January 10<sup>th</sup> of every year

- a. The design flow of this treatment facility is 0.025 MGD. See Part I.D.1 for additional requirements related to facility flows.
- b. See Part I.B for disinfection requirements.
- c. See Part I.C for additional monitoring and reporting instructions.
- d. At least 85% removal for CBODs and TSS shall be attained for this discharge.
- e. This facility has Total Nitrogen and Total Phosphorus calendar year load limits associated with this outfall included in the current Registration List under registration number VAN010131, enforceable under the General VPDES Watershed Permit Regulation for Total Nitrogen and Total Phosphorus Discharges and Nutrient Trading in the Chesapeake Watershed in Virginia.
- f. There shall be no discharge of floating solids or visible foam in other than trace amounts.

# Virginia Department of Environmental Quality

## WASTEWATER FACILITY INSPECTION REPORT

<b>FACILITY NAME:</b> Christendom College STP		<b>INSPECTION DATE:</b> 11/07/2022
		<b>INSPECTOR</b> Alex Wynn
<b>PERMIT No.:</b> VA0067067		<b>REPORT DATE:</b> 11/18/2022
<b>TYPE OF FACILITY:</b> <input checked="" type="checkbox"/> Municipal <input checked="" type="checkbox"/> Small Minor <input type="checkbox"/> Industrial <input type="checkbox"/> Federal	<b>TIME OF INSPECTION:</b>	Arrival 10:00am
		Departure 11:15am
<b>PHOTOGRAPHS:</b> <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	<b>TOTAL TIME SPENT</b>	3 days w/ travel & report
	<b>UNANNOUNCED INSPECTION?</b> <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
<b>REVIEWED BY:</b> TAE, BDK		
<b>PRESENT DURING INSPECTION:</b> Mike Foeckler, Tom Heim, Mark Inboden (IES), Daniel Bradford (IES), Karl DeMay (IES), Celeste Horton (DEQ)		

### TECHNICAL INSPECTION

1. Has there been any new construction? • If so, were plans and specifications approved? Comments: Modifications were made to the aeration system and clarifier in 2021.	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> NA
2. Is the Operations and Maintenance Manual approved and up-to-date? Comments: O&M Manual was last revised in 2018.	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> NA
3. Are the Permit and/or Operation and Maintenance Manual specified licensed operator being met? Comments:	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA
4. Are the Permit and/or Operation and Maintenance Manual specified operator staffing requirements being met? Comments: An IES operator is at the facility ~2 hours/day.	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA
5. Is there an established and adequate program for training personnel? Comments:	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA
6. Are preventive maintenance task schedules being met? Comments: Metals surfaces have not been cleaned and repainted yearly. All exposed steel has not been scraped and painted yearly.	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> NA
7. Does the plant experience any organic or hydraulic overloading? Comments: Hydraulic and organic overloading. Both items are being addressed with future plant upgrades.	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA
8. Has there been any bypassing or overflows since the last inspection? Comments: None reported.	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> NA
9. Is the standby generator (including power transfer switch) operational and exercised regularly? Comments:	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> NA
10. Is the plant alarm system operational and tested regularly? Comments:	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> NA

# VA DEQ Wastewater Facility Inspection Report

Permit #	VA0067067
----------	-----------

## TECHNICAL INSPECTION

11. Is sludge disposed of in accordance with the approved sludge management plan? Comments: Sludge is hauled to Front Royal WWTP for further processing.		<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA
12. Is septage received? • If so, is septage loading controlled, and are appropriate records maintained? Comments:		<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> NA <input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> NA
13. Are all plant records (operational logs, equipment maintenance, industrial waste contributors, sampling and testing) available for review and are records adequate? Comments:		<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA
14. Which of the following records does the plant maintain? <input checked="" type="checkbox"/> Operational logs <input checked="" type="checkbox"/> Instrument maintenance & calibration <input checked="" type="checkbox"/> Mechanical equipment maintenance <input type="checkbox"/> Industrial waste contribution (Municipal facilities) Comments:		
15. What does the operational log contain? <input checked="" type="checkbox"/> Visual observations <input checked="" type="checkbox"/> Flow measurement <input checked="" type="checkbox"/> Laboratory results <input checked="" type="checkbox"/> Process adjustments <input type="checkbox"/> Control calculations <input type="checkbox"/> Other (specify): Comments:		
16. What do the mechanical equipment records contain? <input checked="" type="checkbox"/> As built plans and specs <input checked="" type="checkbox"/> Manufacturer's instructions <input checked="" type="checkbox"/> Lubrication schedules <input checked="" type="checkbox"/> Spare parts inventory <input checked="" type="checkbox"/> Equipment/parts suppliers <input type="checkbox"/> Other (specify): Comments:		
17. What do the industrial waste contribution records contain (Municipal only)? <input type="checkbox"/> Waste characteristics <input type="checkbox"/> Impact on plant <input type="checkbox"/> Locations and discharge types <input type="checkbox"/> Other (specify) Comments: NA		
18. Which of the following records are kept at the plant and available to personnel? <input checked="" type="checkbox"/> Equipment maintenance records <input checked="" type="checkbox"/> Operational log <input type="checkbox"/> Industrial contributor records <input type="checkbox"/> Instrumentation records <input checked="" type="checkbox"/> Sampling and testing records Comments: Field instrument sets are assigned to each operator. The operator keeps the instrumentation records and their IDC in their work vehicle.		
19. List records not normally available to plant personnel and their location: Comments: None		
20. Are the records maintained for the required time period (three or five years)? Comments: Hard copies are stored at the facility. Electronic copies are stored at IES.		<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No

# VA DEQ Wastewater Facility Inspection Report

Permit #	VA0067067
----------	-----------

<u>UNIT PROCESS</u>	<u>APPLICABLE</u>	<u>PROBLEMS*</u>	<u>COMMENTS</u>
Sewage Pumping			
Flow Measurement (Influent)			
Screening/Comminution	X		
Grit Removal			
Oil/Water Separator			
Flow Equalization			
Ponds/Lagoons			
Imhoff Tank			
Primary Sedimentation			
Trickling Filter			
Septic Tank and Sand Filter			
Rotating Biological Contactor			
Activated Sludge Aeration	X		<i>Trouble with filamentous growth and grease.</i>
Biological Nutrient Removal			
Sequencing Batch Reactor			
Secondary Sedimentation	X		<i>Trouble with floating solids.</i>
Flocculation			
Tertiary Sedimentation			
Filtration			
Micro-Screening			
Activated Carbon Adsorption			
Chlorination	X	1	<i>CCT baffles are developing holes from corrosion.</i>
Dechlorination	X		
Ozonation			
Ultraviolet Disinfection			
Post Aeration	X		
Flow Measurement (Effluent)	X		
Land Application (Effluent)			
Plant Outfall	X	1,5	<i>Accumulation of solids in receiving stream</i>
Sludge Pumping			
Flotation Thickening (DAF)			
Gravity Thickening			
Aerobic Digestion	X		
Anaerobic Digestion			
Lime Stabilization			
Centrifugation			
Sludge Press			
Vacuum Filtration			
Drying Beds			<i>Not in use.</i>
Thermal Treatment			
Incineration			
Composting			
Land Application (Sludge)			

\* Problem Codes

- 1. Unit Needs Attention
- 2. Abnormal Influent/Effluent
- 3. Evidence of Equipment Failure
- 4. Unapproved Modification or Temporary Repair
- 5. Evidence of Process Upset
- 6. Other (explain in comments)

# VA DEQ Wastewater Facility Inspection Report

Permit #

VA0067067

## INSPECTION OVERVIEW AND CONDITION OF TREATMENT UNITS

The single train package plant was installed in 1985. The STP receives flow from Christendom College. Modifications were made to the STP in August 2021 to address flow and treatment concerns. See unit check lists for modification specifics.

Operations staff noted the STP experiences increased organic and hydraulic loading while the college is in session (August-May). Christendom College notified DEQ on 10/17/2022 they plan to install a temporary FEQ during the week of 11/14/2022.

Operation of the aeration basin has been modified to accommodate the peak flows and reduce solids washouts. During the inspection the aeration basin was in the “settle” mode. There is no aeration in the basin from 08:00am – 01:00pm. This mode of operation was implemented during the commencement of the 2022 academic year. Treatment efficiency is regularly impacted by influent grease loading and a variability of instantaneous flows.

The clarifier had a thick blanket of brown foam on the surface. The operator stated the foam is removed daily and reoccurs on the surface by the time the operator arrives the next day. The foam is removed manually by operating the scum collection system and using a hose to spray the foam into the scum collection pipe.

The chlorine contact tank (CCT) is pumped frequently to remove settled solids. The CCT’s baffles have significant rust accumulation. Several baffles were starting to develop holes above the water surface. See camera images.

Sludge is frequently removed from the digester due to the STP’s ongoing solids issues. Sludge was last hauled away by a contracted septic hauler on 10/31/22.

There was an accumulation of solids in the receiving stream. The bulk of the solids were retained by a fallen tree approximately 10 feet downstream of the outfall. See camera images.

A pole barn style building was installed in 2022 over the treatment system to prevent leaves and other debris from falling into the tanks. The building has a coarse screen wrapped around the sides with doors to access the STP.

See unit checklists for additional comments.

# VA DEQ Wastewater Facility Inspection Report

Permit #	VA0067067
----------	-----------

## INSPECTION OVERVIEW AND CONDITION OF TREATMENT UNITS EFFLUENT FIELD DATA:

Flow	MGD	Dissolved Oxygen	mg/L	TRC (Contact Tank)	mg/L
pH	S.U.	Temperature	°C	TRC (Final Effluent)	mg/L
<b>Was a Sampling Inspection conducted?</b> <input type="checkbox"/> Yes (see Sampling Inspection Report) <input checked="" type="checkbox"/> No					

## CONDITION OF OUTFALL AND EFFLUENT CHARACTERISTICS:

1. Type of outfall:  Shore based  Submerged Diffuser?  Yes  No
2. Are the outfall and supporting structures in good condition?  Yes  No
3. Final Effluent (evidence of following problems):  Sludge bar  Grease  
 Turbid effluent  Visible foam  Unusual color  Oil sheen
4. Is there a visible effluent plume in the receiving stream?  Yes  No
5. Receiving stream:  No observed problems  Indication of problems (explain below)  
Comments: Receiving stream has settled solids and foam. It was recorded in the operator's log that the creek had been hosed.

## REQUEST for CORRECTIVE ACTION:

1. Update the O&M Manual to address the current standard of operations and the modifications made to the STP in August 2021. Ensure the O&M Manual includes a signed Part II K certification and effective date page. Submit a copy of the updated O&M Manual. [Permit Part I D.4]
2. Repair the corroding CCT baffles. [Permit Part II Q]
3. Provide the procedures used for documenting compliance with the permit requirement that there shall be no discharge of floating solids or visible foam in other than trace amounts. [Part I D.4.i]
4. Remove the accumulated solids from the receiving stream and dispose of in a proper manner. [Permit Part II F and R]
5. Cease hosing the creek. [Permit Part II F]

\*\*\*See the Laboratory Inspection Report for additional requests for corrective action.\*\*\*

## NOTES and COMMENTS:

- Ensure no foam or solids are discharged to the receiving stream when the foam on the clarifier's surface is removed and/or sprayed into the scum collection pipe. [Permit Part II F]

**UNIT PROCESS: Screening/Comminution**

1. Number of Units:	Manual: 1	Mechanical: 1	
Number in operation:	Manual: 1	Mechanical: 1	
2. Bypass channel provided:	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No	
Bypass channel in use:	<input type="checkbox"/> Yes	<input checked="" type="checkbox"/> No	
3. Area adequately ventilated:	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No *	
4. Alarm system for equipment failure or overloads:	<input type="checkbox"/> Yes	<input checked="" type="checkbox"/> No	
5. Proper flow distribution between units:	<input type="checkbox"/> Yes	<input type="checkbox"/> No	<input checked="" type="checkbox"/> NA
6. How often are units checked and cleaned?	Daily		
7. Cycle of operation:	Continuous		
8. Volume of screenings removed:	NA		
9. General condition:	<input checked="" type="checkbox"/> Good	<input type="checkbox"/> Fair	<input type="checkbox"/> Poor

## Comments:

- 3 HP comminutor motor

## UNIT PROCESS: ACTIVATED SLUDGE AERATION

1. Number of units: 1	In operation: 1		
2. Mode of operation: Extended aeration			
3. Proper flow distribution between units:	<input type="checkbox"/> Yes	<input type="checkbox"/> No*	<input checked="" type="checkbox"/> NA
4. Foam control operational:	<input type="checkbox"/> Yes	<input type="checkbox"/> No*	<input checked="" type="checkbox"/> NA
5. Scum control operational:	<input type="checkbox"/> Yes	<input type="checkbox"/> No*	<input checked="" type="checkbox"/> NA
6. Evidence of following problems:			
a. dead spots	<input type="checkbox"/> Yes*	<input checked="" type="checkbox"/> No	
b. excessive foam	<input type="checkbox"/> Yes*	<input checked="" type="checkbox"/> No	
c. poor aeration	<input type="checkbox"/> Yes*	<input checked="" type="checkbox"/> No	
d. excessive aeration	<input type="checkbox"/> Yes*	<input checked="" type="checkbox"/> No	
e. excessive scum	<input type="checkbox"/> Yes*	<input checked="" type="checkbox"/> No	
f. aeration equipment malfunction	<input type="checkbox"/> Yes*	<input checked="" type="checkbox"/> No	
g. other (identify in comments)	<input type="checkbox"/> Yes*	<input checked="" type="checkbox"/> No	

7. Mixed liquor characteristics (as available):

pH (s.u.)		SDI		Odor	None
DO (mg/L)		SVI		Color	Brown
MLSS (mg/L)		Settability (mg/L)	650 mg/L	Others (identify)	

## 8. Return/waste sludge:

a. Return Rate: Cont. b. Waste Rate: 10-15 min c. Frequency of Wasting: 1/2 days

9. Aeration system control:  Manual  Time clock  Continuous  Other (explain)

10. Effluent control devices working properly (oxidation ditches):  Yes  No\*  NA

11. General condition:  Good  Fair  Poor

### Comments:

- Aeration system control:
  - o May-August: Continuous operation
  - o September-May:
    - Air is off from 8:00am – 1:00pm during peak flows to the STP.
    - Aeration is continuous from 1:00pm – 8:00am.
- Polymer is added daily to assist with settling. 1 scoop of dry polymer is mixed with 5 gal. of water.
- BioRemove™ is added regularly to assist with treatment issues derived from oil & grease.
- Fine bubble diffusers were installed in the aeration basin in August 2021.

**UNIT PROCESS: Sedimentation** Primary       Secondary       Tertiary

1. Number of units 1      In operation: 1

2. Proper flow distribution between units:       Yes       No\*       NA

3. Signs of short circuiting and/or overloads:       Yes       No

4. Effluent weirs level:  
Clean:       Yes       No\*  
                   Yes       No\*

5. Scum collection system working properly:       Yes       No\*       NA

6. Sludge collection system working properly:       Yes       No\*

7. Influent, effluent baffle systems working properly:       Yes       No\*

8. Chemical addition:  
Chemicals: NA       Yes       No

9. Effluent characteristics: Clear with mild pin-floc.

10. General condition:       Good       Fair       Poor

## Comments:

- Thick, brown, foam floating on clarifier surface. The operator stated this occurs daily.
- The foam is removed manually by operating the scum collection system and using a hose to spray the foam into the scum collection pipe.
- The following modifications were made to the clarifier in August 2021:
  - o Increased the length of the clarifier inlet weir to cover the entire width of the clarifier.
  - o Installed a new scum collection system. The skimmer is the length of the clarifier width and is connected to a new air lift pump. The air lift pump sends the collected scum to the front of the aeration basin.
  - o A Stamford baffle was installed to keep most floating scum and sludge away from the effluent weir.
  - o Timers were installed to control the RAS/WAS air lift pumps.

## UNIT PROCESS: Chlorination

1. No. of chlorinators: 1	In operation: 1		
2. No. of evaporators: 0	In operation: 0		
3. No. of chlorine contact tanks: 1	In operation: 1		
4. Proper flow distribution between units:	<input type="checkbox"/> Yes	<input type="checkbox"/> No*	<input checked="" type="checkbox"/> NA
5. How is chlorine introduced into the wastewater?			
<input type="checkbox"/> Perforated diffusers			
<input type="checkbox"/> Injector with single entry point			
<input checked="" type="checkbox"/> Other: Drips into start of CTT from tubing connected to a solution pump.			
6. Chlorine residual in basin effluent:	>2.20 mg/L on 10/6/22		
7. Applied chlorine dosage:	2.5 gals/day		
8. Contact basins adequately baffled:	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No*	
9. Adequate ventilation:			
a. cylinder storage area	<input type="checkbox"/> Yes	<input type="checkbox"/> No*	<input checked="" type="checkbox"/> NA
b. equipment room	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No*	
10. Proper safety precautions used:	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No*	
11. General condition:	<input type="checkbox"/> Good	<input checked="" type="checkbox"/> Fair	<input type="checkbox"/> Poor

### Comments:

- Sodium Hypochlorite (12.5%) is used.
- Chlorine is fed continuously to the CCT.
- CCT baffles have significant rust accumulation. Several baffles were starting to develop holes above the water surface. See camera images.

**UNIT PROCESS: Dechlorination**

1. Chemical used:  Sulfur Dioxide  Bisulfite  Other

2. No. of sulfonators: 0 In operation: NA

3. No. of evaporators: 0 In operation: NA

4. No. of chemical feeders: 1 In operation: 1

5. No. of contact tanks: 0 In operation: NA

6. Proper flow distribution between units:  Yes  No\*  NA

7. How is chemical introduced into the wastewater?  
 Perforated diffusers  
 Injector with single entry point?  
 Other: 4-tube tablet feeder

8. Control system operational:  
a. residual analyzers:  Yes  No\*  
b. system adjusted:  Yes  No\*  NA  Other:

9. Applied dechlorination dose: ~ 4 tablets/day

10. Chlorine residual in basin effluent: <0.10 mg/L on 10/6/22

11. Contact basins adequately baffled:  Yes  No  NA

12. Adequate ventilation:  
a. cylinder storage area:  Yes  No\*  
b. equipment room:  Yes  No\*  NA  NA

13. Proper safety precautions used:  Yes  No\*

14. General condition:  Good  Fair  Poor

Comments:

## UNIT PROCESS: Post Aeration

1. Number of units: 1	In operation: 1			
2. Proper flow distribution between units:	<input type="checkbox"/> Yes	<input type="checkbox"/> No*	<input checked="" type="checkbox"/> NA	
3. Evidence of following problems:				
a. dead spots	<input type="checkbox"/> Yes*	<input checked="" type="checkbox"/> No		
b. excessive foam	<input type="checkbox"/> Yes*	<input checked="" type="checkbox"/> No		
c. poor aeration	<input type="checkbox"/> Yes*	<input checked="" type="checkbox"/> No		
d. mechanical equipment failure	<input type="checkbox"/> Yes*	<input type="checkbox"/> No	<input checked="" type="checkbox"/> NA	
4. How is the aerator controlled? <input type="checkbox"/> Manual	<input type="checkbox"/> Time clock	<input type="checkbox"/> Continuous	<input type="checkbox"/> Other	<input checked="" type="checkbox"/> NA
5. What is the current operating schedule?	Continuous			
6. Step weirs level:	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No	<input type="checkbox"/> NA	
7. Effluent D.O. level:	Not analyzed			
8. General condition:	<input checked="" type="checkbox"/> Good	<input type="checkbox"/> Fair	<input type="checkbox"/> Poor	

### Comments:

- Cascade steps following the dechlorinator.

**UNIT PROCESS: Effluent/Plant Outfall**

1. Type Outfall:  Shore based  Submerged

2. Type if shore based:  Wingwall  Headwall  Rip Rap

3. Flapper valve:  Yes  No  NA

4. Erosion of bank:  Yes\*  No  NA

5. Effluent plume visible?  Yes\*  No

6. Condition of outfall and supporting structures:  Good  Fair  Poor

7. Final effluent, evidence of following problems:

a. oil sheen  Yes\*  No

b. grease  Yes\*  No

c. sludge bar  Yes\*  No

d. turbid effluent  Yes\*  No

e. visible foam  Yes\*  No

f. unusual color  Yes\*  No

## Comments:

- c) There was an accumulation of solids in the receiving stream. The bulk of the solids were retained by a fallen tree approximately 10 feet downstream of the outfall. Solids were identified as far down as 100 ft from the outfall.
- e) Foam was identified near the outfall. See camera images.

## UNIT PROCESS: AEROBIC DIGESTION

1. Number of units:	1	In operation:	1
2. Type of sludge treated		<input type="checkbox"/> Primary	<input checked="" type="checkbox"/> WAS
3. Frequency of sludge application to digesters: Every other day.			
4. Supernatant return rate: Supernatant is manually pumped from the digester every other day.			
5. pH adjustment provided: Utilized:	<input type="checkbox"/> Yes <input type="checkbox"/> Yes	<input checked="" type="checkbox"/> No <input type="checkbox"/> No	<input checked="" type="checkbox"/> NA
6. Tank contents well-mixed and relatively free of odors:	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No*	
7. If diffused aeration is used, do diffusers require frequent cleaning?	<input type="checkbox"/> Yes	<input checked="" type="checkbox"/> No	<input type="checkbox"/> NA
8. Location of supernatant return:	<input checked="" type="checkbox"/> Head	<input type="checkbox"/> Primary	<input type="checkbox"/> Other
9. Process control testing:			
a. reduction of volatile solids	<input type="checkbox"/> Yes	<input checked="" type="checkbox"/> No	%
b. pH	<input type="checkbox"/> Yes	<input checked="" type="checkbox"/> No	s.u.
c. alkalinity	<input type="checkbox"/> Yes	<input checked="" type="checkbox"/> No	mg/l
d. dissolved oxygen	<input type="checkbox"/> Yes	<input checked="" type="checkbox"/> No	mg/l
10. Foaming problem present:	<input type="checkbox"/> Yes*	<input checked="" type="checkbox"/> No	
11. Signs of short-circuiting or overloads:	<input checked="" type="checkbox"/> Yes*	<input type="checkbox"/> No	
12. General condition:	<input checked="" type="checkbox"/> Good	<input type="checkbox"/> Fair	<input type="checkbox"/> Poor

### Comments:

- 11) Solids are frequently removed from the digester due to high volume of solids in the STP.
- The digester was recoated and reinforced as part of the August 2021 improvements.

**UNIT PROCESS: Flow Measurement**

Influent       Intermediate       Effluent

1. Type measuring device: Ultrasonic transponder at a 60° V-notch weir

2. Present reading: 10.93 GPM (10:43am, 11/7/22)

3. Bypass channel:       Yes       No  
Metered:       Yes       No       NA

4. Return flows discharged upstream from meter:       Yes       No  
Identify:

5. Device operating properly:       Yes       No \*

6. Date of last calibration: 01/26/2022

7. Evidence of following problems:


a. obstructions       Yes\*       No  
b. grease       Yes\*       No

8. General condition:       Good       Fair       Poor

Comments:

Christendom College STP  
11/07/2022

VA0067067



Christendom College STP

Comminutor

Aeration basin




Aeration basin

Blowers and control panels

Clarifiers (2)

Christendom College STP  
11/07/2022


VA0067067



Scum collection pipe and clarifier weir

Chlorine contact tank, ultrasonic transponder, and weir.

Baffles of chlorine contact tank. Circled in red is a hole developing from rust.



Dechlor tablet feeder, sample collection point, and cascade steps.

Red arrow is pointing to Outfall 001. The photo also shows a storm drainage outlet and blockage in the stream caused by fallen trees.

Photo taken on the west side of the fallen trees, looking towards outfall 001.

Christendom College STP  
11/07/2022

VA0067067




Photo of solids accumulation

Photo looking downstream towards the west.

Photo looking downstream towards the west. The red arrow is pointing to the Shenandoah River.



Sodium Hypochlorite (12.5%) feed and composite sampler.

Endress-Hauser flow meter.

KD's field instruments.

**DEPARTMENT OF ENVIRONMENTAL QUALITY - WATER DIVISION**  
**LABORATORY INSPECTION REPORT**

11/2014

PERMIT #: VA0067067	INSPECTION DATE: 11/07/2022	PREVIOUS INSP. DATE: 04/13/2018	PREVIOUS EVALUATION: --	TIME SPENT: 3 days w/ travel & report
NAME/ADDRESS OF FACILITY:  Christendom College STP 134 Christendom Drive Front Royal, VA 22630		FACILITY CLASS:  <input type="checkbox"/> MAJOR <input type="checkbox"/> MINOR <input checked="" type="checkbox"/> MINOR (Small) <input type="checkbox"/> VPA	FACILITY TYPE:  <input checked="" type="checkbox"/> MUNICIPAL <input type="checkbox"/> INDUSTRIAL <input type="checkbox"/> FEDERAL	UNANNOUNCED INSPECTION?  <input checked="" type="checkbox"/> YES <input type="checkbox"/> NO
INSPECTOR(S): Alex Wynn		REVIEWER(S): TAE, BDK	FFY-SCHEDULED INSPECTION?  <input checked="" type="checkbox"/> YES <input type="checkbox"/> NO	
PRESENT AT INSPECTION:  Mike Foeckler, Tom Heim, Mark Inboden (IES), Daniel Bradford (IES), Karl DeMay (IES), Celeste Horton (DEQ)				
LABORATORY EVALUATION				DEFICIENCIES?
				Yes
LABORATORY RECORDS				<input type="checkbox"/> <input checked="" type="checkbox"/>
GENERAL SAMPLING AND ANALYSIS				<input checked="" type="checkbox"/> <input type="checkbox"/>
pH PROCEDURE				<input checked="" type="checkbox"/> <input type="checkbox"/>
TOTAL RESIDUAL CHLORINE PROCEDURE				<input checked="" type="checkbox"/> <input type="checkbox"/>
DISSOLVED OXYGEN PROCEDURES				<input checked="" type="checkbox"/> <input type="checkbox"/>
OTHER				

VELAP CERTIFICATION (on site Environmental Laboratory)			Yes	No	NA
Does the laboratory have VELAP certification (interim or final)?			<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
- Document the laboratory's VELAP laboratory number:					
- Document the effective date of the VELAP certification:					
- Document the expiration date of the VELAP certification:					
- List the certified parameters:					
VELAP ACCREDITATION (Commercial Environmental Laboratory)			Yes	No	
IS A VELAP ACCREDITED LAB USED FOR OTHER PERMIT REQUIRED ANALYSES? VELAP#, LAB NAME, ADDRESS and LIST PARAMETERS:			<input checked="" type="checkbox"/>	<input type="checkbox"/>	
VELAP # 460024	LAB NAME and ADDRESS Inboden Environmental Services, Inc. Mount Jackson, VA 22842	PARAMETERS TSS, CBOD5, E. coli, & Ammonia-N			
IF PERMIT REQUIRED SAMPLE ANALYSIS IS PERFORMED AT ANOTHER LOCATION, ARE SHIPPING PROCEDURES ADEQUATE?			<input checked="" type="checkbox"/>	<input type="checkbox"/>	
COPIES: <input checked="" type="checkbox"/> DEQ - RO; <input checked="" type="checkbox"/> Owner, <input checked="" type="checkbox"/> Other: Inboden Environmental Services, Inc.					

**LABORATORY RECORDS SECTION**

LABORATORY RECORDS INCLUDE THE FOLLOWING:

<input checked="" type="checkbox"/>	SAMPLING DATE	<input checked="" type="checkbox"/>	ANALYSIS DATE	NA	CONT MONITORING CHART
<input checked="" type="checkbox"/>	SAMPLING TIME	<input checked="" type="checkbox"/>	ANALYSIS TIME	<input checked="" type="checkbox"/>	INSTRUMENT CALIBRATION
<input checked="" type="checkbox"/>	SAMPLE LOCATION	<input checked="" type="checkbox"/>	TEST METHOD	<input checked="" type="checkbox"/>	INSTRUMENT MAINTENANCE

CERTIFICATE OF ANALYSIS

WRITTEN INSTRUCTIONS INCLUDE THE FOLLOWING:

<input type="checkbox"/>	SAMPLING SCHEDULES	<input type="checkbox"/>	CALCULATIONS	<input type="checkbox"/>	ANALYSIS PROCEDURES
--------------------------	--------------------	--------------------------	--------------	--------------------------	---------------------

	YES	NO	N/A
DO ALL ANALYSTS INITIAL THEIR WORK?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
DO BENCH SHEETS (or LOG BOOK) INCLUDE ALL INFORMATION NECESSARY TO DETERMINE RESULTS?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
IS THE DMR COMPLETE AND CORRECT? LIST MONTH(S) REVIEWED: Mar-Oct 2022	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
ARE ALL MONITORING VALUES REQUIRED BY THE PERMIT REPORTED?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
DOES CHAIN OF CUSTODY DOCUMENT PROPER SAMPLE PRESERVATION WAS MET?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
WHEN THE CERTIFICATE OF ANALYSIS CONTAINS FLAGGED DATA IS THE 'FLAG' REPORTED ON THE DMR?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

**GENERAL SAMPLING AND ANALYSIS SECTION**

	YES	NO	N/A
ARE SAMPLE LOCATIONS ACCORDING TO PERMIT REQUIREMENTS?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
ARE PERMIT REQUIRED SAMPLE COLLECTION PROCEDURES APPROPRIATE?	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
ARE EFFLUENT SAMPLES REPRESENTATIVE OF THE MONITORED ACTIVITY?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
ARE PERMIT REQUIRED COMPOSITE SAMPLES FLOW PROPORTIONAL? <b>NOTE:</b> Equal volume composite aliquots are acceptable <u>if the instantaneous flow is within <math>\pm 10\%</math> of the daily average flow during the monitoring period.</u> Some permits specify how the composite is to be taken (e.g., 5G/8HC).	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
IS COLLECTION SAMPLE EQUIPMENT ADEQUATE?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
IS FLOW MEASUREMENT ACCORDING TO PERMIT REQUIREMENTS?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

**DEPARTMENT OF ENVIRONMENTAL QUALITY – WATER DIVISION**  
**LABORATORY INSPECTION REPORT SUMMARY**

<b>FACILITY NAME:</b>	Christendom College STP	<b>Permit #:</b>	VA0067067	<b>INSPECTION DATE:</b>	11/07/2022
<b>LABORATORY EVALUATION</b>		<input type="checkbox"/>	No required actions at this time		
		<input checked="" type="checkbox"/>	<b>REQUIRED CORRECTIVE ACTION(s) IDENTIFIED</b>		
<b>SUMMARY of REQUEST FOR CORRECTIVE ACTION</b>					
<b>Lab Records</b>					
<b>Laboratory Records section deficiency and required action:</b>					
<ol style="list-style-type: none"> <li>1. None noted.</li> </ol>					
<b>General Sampling and Analysis</b>					
<b>General Sampling and Analysis section deficiency and required action:</b>					
<ol style="list-style-type: none"> <li>1. Begin utilizing a thermometer in the facility's final effluent sample refrigerator. Ensure temperatures are recorded each time a composite sample is collected. The thermometer must be verified annually with a NIST certified thermometer. Provide documentation of the thermometer's implementation and of its verification with a NIST traceable thermometer. [Permit Part II B. &amp; Q.]</li> </ol>					
<b>pH Analysis</b>					
<b>pH deficiency and required action:</b>					
<ol style="list-style-type: none"> <li>1. Submit Initial Demonstration of Capabilities for the facility's operators. Maintain IDC documentation on site. [Permit Part II A.]</li> </ol>					
<b>TRC Analysis</b>					
<b>TRC deficiency and required action:</b>					
<ol style="list-style-type: none"> <li>1. Submit Initial Demonstration of Capabilities for the facility's operators. Maintain IDC documentation on site. [Permit Part II A.]</li> <li>2. Ensure the buffering capability check of DPD pillows is completed annually and the results are maintained onsite. [Permit Part II A.]</li> </ol>					
<b>D.O. Analysis</b>					
<b>D.O. deficiency and required action:</b>					
<ol style="list-style-type: none"> <li>1. Submit Initial Demonstration of Capabilities for the facility's operators. Maintain IDC documentation on site. [Permit Part II A.]</li> </ol>					
<b>OTHER – Comments or Observations</b>					
<ul style="list-style-type: none"> <li>• None.</li> </ul>					

ANALYST:	Karl DeMay	VPDES NO	VA0067067
----------	------------	----------	-----------

Meter: EcoSense DO200A

Parameter: Dissolved Oxygen  
Method: Membrane Electrode  
11/2014

METHOD OF ANALYSIS:

<input type="checkbox"/>	21 <sup>st</sup> Edition of Standard Methods (SM 21) – 4500-O G-2001 (SM 21 DO)
<input checked="" type="checkbox"/>	22 <sup>nd</sup> of Standard Methods, or Online Editions of Standard Methods (SM 22) – 4500-O G-2011 (SM 22 DO)

***Dissolved Oxygen (D.O.) is a method-defined analyte so modifications are not allowed.  
[40 CFR Part 136.6]***

	<b><i>Y</i></b>	<b><i>N</i></b>
1) Is a certificate of operator competence or initial demonstration of capability available for <u>each analyst/operator</u> performing this analysis? <b>NOTE:</b> Analyze 4 samples of air-saturated water. Recovery for each of the 4 samples must be +/- 4% of the calculated oxygen saturation for the altitude/barometric pressure and temperature of the samples. {Alternatively analyze 4 samples of water of known concentration (verified by iodometric titration procedure SM 21 or SM 22 4500-O C). Instrument measurements must agree within +/-0.1 mg/L of verified concentration.} [SM 21 or SM 22 1020 B.1 and 4020 B.1]	<input type="checkbox"/>	<input checked="" type="checkbox"/>
2) Are calibration results (mg/L) within $\pm$ 4% of the barometric (or altitude) corrected oxygen saturated water value? [SM 21 B.2 or SM 22 1020 B.2.]	<input checked="" type="checkbox"/>	<input type="checkbox"/>
3) If samples are collected, is collection carried out with a minimum of turbulence and air bubble formation and is the sample bottle allowed to overflow several times its volume? [SM 21 DO or SM 22 B 3.]	<input type="checkbox"/>	NA
4) Are meter and electrode operable and providing consistent readings? [SM 21 DO G 2. or SM 22 DO G 2.]	<input checked="" type="checkbox"/>	<input type="checkbox"/>
5) Is membrane in good condition without trapped air bubbles? <b>NOTE: No air bubbles <math>\geq</math> 1/8 inch (total area of all bubbles).</b> [SM 21 DO G 3.b. or SM 22 DO G 3.b.]	<input checked="" type="checkbox"/>	<input type="checkbox"/>
6) Is correct filling solution used in electrode? [Mfr.]	<input checked="" type="checkbox"/>	<input type="checkbox"/>
7) Are water droplets shaken off the membrane prior to calibration? [Mfr.]	<input checked="" type="checkbox"/>	<input type="checkbox"/>
8) Is meter calibrated before use or at least daily? [Mfr. & SM 21 1020 B 10.a. or SM 22 1020 B 11.a]	<input checked="" type="checkbox"/>	<input type="checkbox"/>
9) Is calibration procedure performed according to manufacturer's instructions? [Mfr.]	<input checked="" type="checkbox"/>	<input type="checkbox"/>
10) Is sample stirred during analysis (or is there sufficient flow across probe's membrane surface)? [SM 21 DO or SM 22 DO G 3.b. and Mfr.]	<input checked="" type="checkbox"/>	<input type="checkbox"/>
11) Is the sample analysis procedure performed according to manufacturer's instructions? [Mfr.]	<input checked="" type="checkbox"/>	<input type="checkbox"/>
12) Is meter stabilized before reading D.O.? [Mfr.]	<input checked="" type="checkbox"/>	<input type="checkbox"/>
13) Is electrode stored according to manufacturer's instructions? [Mfr.]	<input checked="" type="checkbox"/>	<input type="checkbox"/>

Comments:

- IDCs for the current operators were not available onsite.

ANALYST:	Karl DeMay	VPDES NO	VA0067067
----------	------------	----------	-----------

Meter: Oakton pH 30

Parameter: Hydrogen Ion (pH)

Method: Electrometric

3/2015

METHOD OF ANALYSIS:

<input type="checkbox"/>	21 <sup>st</sup> Edition of Standard Methods (SM 21) – 4500-H <sup>+</sup> B-2000 (SM 21 pH)
<input checked="" type="checkbox"/>	22 <sup>nd</sup> Edition of Standard Methods (SM 22), or Online Editions of Standard Methods – 4500-H <sup>+</sup> B-2011 (SM 22 pH)

***pH is a method-defined analyte so modifications are not allowed. [40 CFR Part 136.6]***

	Y	N
1) Is a certificate of operator competence or initial demonstration of capability available for <u>each analyst/operator</u> performing this analysis? <b>NOTE:</b> Analyze 4 samples of known pH; you may use an external source of buffers or other known standards (different lot/manufacturer than buffers used to calibrate meter). Recovery for each of the 4 samples must be +/- 0.2 SU of the known concentration of the sample or within “Acceptable Range” specified by the PT provider. [SM 1020 B.1] <b>NOTE: The same pH buffer [values] used for calibration of the instrument can be used as LCS if from a different source or different lot.</b>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
2) <b>IF</b> a replicate sample is analyzed is there a written procedure for which result will be reported on DMR (Sample or Replicate) and is this procedure being followed? [DEQ – based on EPA Good Laboratory Practices Standards]	<input type="checkbox"/>	NA
3) Is a Laboratory Control Sample (LCS) tested at least annually and are results within acceptance criteria? [SM 21 B.2 or SM 22 1020 B.3.] <b>NOTE:</b> LCS should be a purchased Proficiency Test (PT) sample or a different buffer other than ones used for calibration of the meter [with a +/- 0.2 SU acceptance range or within “Acceptable Range” specified by the PT provider]. <b>NOTE: The same pH buffer [values] used for calibration of the instrument can be used as LCS if from a different source or different lot.</b>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
4) Is the electrode in good condition (no chloride precipitate, scratches, deterioration, etc.)? [SM 21 pH or SM 22 pH 2.b./c. and 5.b.]	<input checked="" type="checkbox"/>	<input type="checkbox"/>
5) Is electrode storage solution in accordance with manufacturer's instructions? [SM 21 pH or SM 22 pH 4.a. and Mfr.]	<input checked="" type="checkbox"/>	<input type="checkbox"/>
6) Is meter calibrated on at least a daily basis using three buffers all of which are at the same temperature? [SM 21 pH or SM 22 pH 4.a.] <b>NOTE:</b> Start with Buffer 7 unless manufacturer's instructions state otherwise. <b>[NOTE: If meter is not capable of 3 buffer calibration use 2 buffers bracketing the expected sample pH and then measure a 3<sup>rd</sup> buffer (the measurement value recorded must be +/- 0.1 SU), and then reread and record value of buffer 7 to ensure +/- 0.1 SU.]</b>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
7) After calibration, is a buffer analyzed as a check sample to verify that calibration is correct? Verification measurement should be within +/- 0.1 SU. [SM 21 1020 B 10.c. or SM 22 1020 B 11.c.]	<input checked="" type="checkbox"/>	<input type="checkbox"/>
8) Is calibration verification measurement repeated with every 10 samples and at the end of a series of samples? Verification measurement should be within +/- 0.1 SU. [SM 21 pH or SM 22 pH 4020 B 2.b.] <b>NOTE:</b> Not applicable if pH meter is calibrated before taking any measurement (e.g., if operator monitors daily pH at more than one facility and calibrates before each measurement).	<input type="checkbox"/>	NA
9) Do the buffer solutions appear to be free of contamination or growths? [SM 21 pH or SM 22 pH 3.a.]	<input type="checkbox"/>	*
10) Are buffer solutions within the listed shelf-life or have they been prepared within the last 4 weeks? [SM 21 pH or SM 22 pH 3.a.]	<input type="checkbox"/>	*
11) Is the cap or sleeve covering the access hole on the reference electrode removed when measuring pH? [Mfr.]	<input type="checkbox"/>	NA
12) Is sample analyzed within 15 minutes of collections? [40 CFR Part 136]	<input checked="" type="checkbox"/>	<input type="checkbox"/>

13)	Is the electrode rinsed and then blotted dry between reading solutions (Disregard if a portion of the next sample analyzed is used as the rinsing solution.)? [SM 21 pH or SM 22 pH 4.a and 4.b.]	<input checked="" type="checkbox"/>	<input type="checkbox"/>
14)	Is the sample stirred gently at a constant speed during measurement? [SM 21 pH or SM 22 pH 4.b.]	<input checked="" type="checkbox"/>	<input type="checkbox"/>
15)	Does the meter hold a steady reading after reaching equilibrium? [4.b.]	<input checked="" type="checkbox"/>	<input type="checkbox"/>

Comments:

- IDCs for the current operators were not available onsite.
- pH buffers were not inspected at this inspection. Buffers are stored at IES's office.

<b>ANALYST:</b>	Karl DeMay	<b>VPDES NO.</b>	VA0067067
-----------------	------------	------------------	-----------

Parameter: Total Residual Chlorine (TRC)  
Method: DPD Colorimetric (HACH Pocket and Pocket II Colorimeter)  
11/2014

METHOD OF ANALYSIS:      Instrument: HACH DR300

<input checked="" type="checkbox"/>	HACH Manufacturer's Instructions (Method 8167) plus an edition of <i>Standard Methods</i>
<input type="checkbox"/>	21st Edition of <i>Standard Methods</i> 4500-Cl G-2000 (SM 21 Cl)
<input checked="" type="checkbox"/>	22 <sup>nd</sup> Edition of <i>Standard Methods</i> 4500-Cl G-2011 (SM 22 Cl)

	<b>Y</b>	<b>N</b>
1) Is a certificate of operator competence or initial demonstration of capability available for <u>each analyst/operator</u> performing this analysis? <b>NOTE:</b> Analyze 4 samples of known TRC. Must use a lot number or source that is different from that used to prepare calibration standards. May not use Spec <sup>✓</sup> ™. Acceptance range is 70-130% recovery <u>and</u> 20% Relative Standard Deviation (RSD) <u>or</u> within PT specified acceptance range <u>and</u> 20% RSD. [SM 1020 B.1]	<input type="checkbox"/>	<input checked="" type="checkbox"/>
2) Is calibration curve verification checked daily using a high and a low standard? <b>NOTE:</b> May use manufacturer's installed calibration and commercially available chlorine standards, or Spec <sup>✓</sup> ™, for daily calibration verifications. [SM 21 1020]	<input checked="" type="checkbox"/>	<input type="checkbox"/>
3) <u>IF</u> a replicate sample is analyzed is there a written procedure for which result will be reported on DMR (Sample or Replicate) and is this procedure being followed? [DEQ – based on EPA Good Laboratory Practices Standards]	<input type="checkbox"/>	NA
4) Is a Laboratory Control Sample (LCS) tested at least annually and are results within acceptance criteria? [SM 21 B. 2. or SM 22 1020 B.3.] <b>NOTE:</b> LCS should be a purchased Proficiency Test (PT) sample or if a known standard different from the calibration standards is used. Use the PT acceptance criteria when given or use 70-130% recovery <u>and</u> 20% Relative Standard Deviation (RSD) as the acceptance criteria.	<input checked="" type="checkbox"/>	<input type="checkbox"/>
5) Are the DPD Powder Pillows stored in a cool, dry place? [Mfr.]	<input checked="" type="checkbox"/>	<input type="checkbox"/>
6) Are the pillows within the manufacturer's expiration date? [Mfr.]	<input checked="" type="checkbox"/>	<input type="checkbox"/>
7) Are pillows appropriate for the sample size being analyzed and for <u>Total</u> Residual Chlorine	<input checked="" type="checkbox"/>	<input type="checkbox"/>
8) Has buffering capability of DPD pillows been checked annually? (Pillows should adjust sample pH to between 6 and 7) [Mfr.]	<input type="checkbox"/>	<input checked="" type="checkbox"/>
9) When pH adjustment is required, is H <sub>2</sub> SO <sub>4</sub> or NaOH used? [Hach 11.3.1]	<input type="checkbox"/>	NA
10) Are cells clean and in good condition? [Mfr]	<input checked="" type="checkbox"/>	<input type="checkbox"/>
11) Is the Hach colorimeter program set to measure "TRC, mg/L"? [Mfr.]	<input checked="" type="checkbox"/>	<input type="checkbox"/>
12) Is the low range (0.01 mg/L resolution) used for samples containing residuals from 0.1 mg/L - 2.00 mg/L? [Mfr.]	<input checked="" type="checkbox"/>	<input type="checkbox"/>
13) Is the 10-mL cell (2.5-cm diameter) used for samples from 0-2.00 mg/L? [Mfr.]	<input checked="" type="checkbox"/>	<input type="checkbox"/>
14) Are samples analyzed within 15 minutes of collection? [40 CFR Part 136]	<input checked="" type="checkbox"/>	<input type="checkbox"/>
15) Is meter zeroed correctly using sample for the blank analysis? [Mfr. and SM 21 1020 B.4. or SM 22 1020 B.5.]	<input checked="" type="checkbox"/>	<input type="checkbox"/>
16) Is the instrument light screen placed correctly on the meter body when the meter is zeroed and when the sample is analyzed? [Mfr.]	<input checked="" type="checkbox"/>	<input type="checkbox"/>
17) Is the DPD Total Chlorine Powder Pillow mixed into the sample? [Hach 11.1]	<input checked="" type="checkbox"/>	<input type="checkbox"/>

18)	Is the analysis made at least three minutes but not more than six minutes after Powder Pillow addition? [Hach 11.2]	<input checked="" type="checkbox"/>	<input type="checkbox"/>
19)	If read-out exceeds “2.19 mg/L”, is the original sample diluted correctly, and then reanalyzed within 15 minutes of the original collection time? [Hach 1.2 & 2.0]	<input checked="" type="checkbox"/>	<input type="checkbox"/>

Comments:

- IDCs for the current operators were not available onsite.
- Results of the annual buffering capability of DPD pillows check were not available on site.

**DEPARTMENT OF ENVIRONMENTAL QUALITY - WATER DIVISION**  
**SAMPLE ANALYSIS HOLDING TIME/CONTAINER/PRESERVATION CHECK SHEET**  
Revised 02/2015 [40 CFR, Part 136.3, Table II]

<b>FACILITY NAME:</b>	Christendom College STP								VPDES NO	VA0067067		DATE:	11/07/2022						
<b>HOLDING TIMES</b> [Note: Collection period (for composites) and Sample Collection time (end of collection period) must be recorded on the COC.]										<b>SAMPLE CONTAINER</b>				<b>PRESERVATION</b> [Note: Preservation is to occur <u>within 15</u> minutes of the end of the collection period.]					
PARAMETER	APPROVED	MET?		LOGGED?		ADEQ. VOLUME		APPROP. TYPE		APPROVED	MET?		CHECKED?						
		Y	N	Y	N	Y	N	Y	N		Y	N							
pH	15 MIN.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Within 15 minutes	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>											
CHLORINE	15 MIN.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Within 15 minutes	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>											
DISSOLVED O <sub>2</sub>	15 MIN	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Within 15 minutes	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>											
BOD <sub>5</sub> & CBOD <sub>5</sub>	48 HOURS	<input type="checkbox"/>	<input type="checkbox"/>	≤6° C	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>											
TSS	7 DAYS	<input type="checkbox"/>	<input type="checkbox"/>	≤6° C	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>											
E. coli	8 HRS	<input type="checkbox"/>	<input type="checkbox"/>	<10° C+0.008% Na <sub>2</sub> S <sub>2</sub> O <sub>3</sub>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>											
AMMONIA	28 DAYS	<input type="checkbox"/>	<input type="checkbox"/>	DECHLOR ≤6° C+H <sub>2</sub> S <sub>2</sub> O <sub>4</sub> pH<2t	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>											
Comments:	<b>All chemical preservation should be noted by the Permittee on the Chain of Custody.</b>																		

Holding Times and Preservation References (VELAP except for Field Tests)

**DEPARTMENT OF ENVIRONMENTAL QUALITY - WATER DIVISION**  
**EQUIPMENT TEMPERATURE LOG/THERMOMETER VERIFICATION CHECK SHEET**  
11/2014

<b>FACILITY NAME:</b>	Christendom College STP				<b>PERMIT NO:</b>	VA0067067		<b>DATE:</b>	11/07/2022				
<b>Equipment</b>	<b>Preservation Range</b>	<b>In Range?</b>		<b>Inspector Reading</b>	<b>Checked &amp; Logged Daily?</b>		<b>Correct Increment?</b>		<b>ANNUAL THERMOMETER VERIFICATION</b>				
									<b>Yes</b>	<b>No</b>	<b>Is the NIST / NIST-Traceable Reference Thermometer within the manufacturer's expiration date or recertified yearly?</b>		<b>Yes</b>
		<b>°C</b>	<b>Yes</b>		<b>No</b>	<b>Yes</b>	<b>No</b>	<b>Date Checked</b>	<b>Marked?</b>	<b>Offset Value<sup>1</sup> (Correction)</b>	<b>NIST Inspection Temp</b>		
<b>Auto Sampler</b>	1-6° C	<input type="checkbox"/>	<input type="checkbox"/>		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>			
<b>pH Meter</b>	± 1° C	<input checked="" type="checkbox"/>	<input type="checkbox"/>						08/08/2022	<input checked="" type="checkbox"/>	<input type="checkbox"/>	-0.3, -0.1, -0.2	0, 15, 30
<b>D.O. Meter</b>	± 1° C	<input checked="" type="checkbox"/>	<input type="checkbox"/>						08/08/2022	<input checked="" type="checkbox"/>	<input type="checkbox"/>	-0.1, 0.0, 0.0	0, 15, 30

**Comments:**

- There was not a NIST-traceable thermometer in the refrigerated auto sampler.

<sup>1</sup> Offset Value tolerances (reference **NIST 105-6**): Sampling Refrigerator and Auto Sampler, pH and D.O. meters must be within ±2°C (2 times tolerance value). Thermometers measuring Outfall permit compliance must be within ±1.0°C (2 times tolerance value).

# Documents

**PERMITTED FACILITY**

Christendom College STP  
 134 Christendom Dr, Front Royal VA 22630  
**Permit Number:** VA0067067  
**Permit Type:** Minor Municipal  
**No Discharge:**

**COMMONWEALTH OF VIRGINIA**  
**DEPARTMENT OF ENVIRONMENTAL QUALITY**  
 NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)  
 DISCHARGE MONITORING REPORT (DMR)

MONITORING PERIOD	
FROM	TO
8/1/2022	8/31/2022

**RETURN TO**

Department of Environmental Quality  
 Valley Regional Office  
 4411 Early Road, P.O. Box 3000, Harrisonburg VA 22801  
 (540) 574-7800

NOTE: READ PERMIT AND GENERAL INSTRUCTIONS BEFORE  
 COMPLETING THIS FORM AND RETURNING IT.

Outfall Num: 001

Reporting Frequency: Month

Run Date: Nov 15, 2022

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION			NO. EX.	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM			
001 FLOW	REPORTD	0.007	0.014		*****	*****	*****		0	1/DAY
	REQRMNT	0.025	NL	MGD	*****	*****	*****			1/DAY
002 pH	REPORTD	*****	*****		7.2	*****	8.4		0	1/DAY
	REQRMNT	*****	*****		6.5	*****	9.5	SU		1/DAY
004 TSS	REPORTD	0.11	0.23		*****	4.7	6.8		0	1/W
	REQRMNT	2.8	4.3	KG/D	*****	30	45	MG/L		1/W
005 CL2, TOTAL	REPORTD	*****	*****		*****	<QL	<QL		0	1/DAY
	REQRMNT	*****	*****		*****	0.0080	0.0098	MG/L		1/DAY
007 DO	REPORTD	*****	*****		6.4	*****	*****		0	1/DAY
	REQRMNT	*****	*****		6.0	*****	*****	MG/L		1/DAY
157 CL2, TOTAL CONTACT	REPORTD	*****	*****		0.7	*****	*****		1	1/DAY
	REQRMNT	*****	*****		1.0	*****	*****	MG/L	3	1/DAY
159 CBOD5	REPORTD	0.27	0.54		*****	10	12		0	1/W
	REQRMNT	2.3	3.4	KG/D	*****	24	36	MG/L		1/W
213 CL2, INST TECH MIN LIMIT	REPORTD	*****	*****		0.7	*****	*****		0	1/DAY
	REQRMNT	*****	*****		0.6	*****	*****	MG/L		1/DAY
353 AMMONIA, AS N JUN-DEC	REPORTD	*****	*****		*****	5.6	22.4		2	1/W
	REQRMNT	*****	*****		*****	1.6	2.4	MG/L		1/W

**Additional Permit Requirements:** Submit daily operations log with DMR.

**Outfall Comments:**

**Comments:**

# Christendom College

Wastewater Treatment Plant

Front Royal, VA

## Monthly Log Report of Final Effluent



Month: August Year: 2022

VA0067067

DATE	Flow MGD	pH S.U.	D.O. mg/l	TRC, Cont.		TRC, Final	CBOD5				Total Suspended Solids				Ammonia - N	
				Conc. mg/L	Tech Min Lim mg/L	Conc. mg/L	Conc. mg/L	Week Ave., mg/L	Loading kg/d	Week Ave., kg/d	Conc. mg/L	Week Ave., mg/L	Loading kg/d	Week Ave., kg/d	Conc. mg/L	Week Ave., mg/L
1	0.0023	8.0	8.3	2.5		<0.10										
2	0.0023	8.1	7.8	1.0		<0.10										
3	0.0017	7.7	7.4	5.8		<0.10	7	7	0.05	0.05	4.8	4.8	0.03	0.03	0.0	0.0
4	0.0019	8.2	7.3	3.2		<0.10										
5	0.0014	8.2	7.5	5.6		<0.10										
6	0.0032	7.9	7.4	3.9		<0.10										
7	0.0031	7.9	7.5	3.2		<0.10										
8	0.0039	8.4	7.3	1.0		<0.10										
9	0.0037	8.2	7.9	2.6		<0.10										
10	0.0055	8.1	7.6	1.3		<0.10	12	12	0.25	0.25	6.8	6.8	0.14	0.14	0.0	0.0
11	0.0040	8.2	8.2	7.9		<0.10										
12	0.0067	8.2	8.1	1.3		<0.10										
13	0.0034	8.2	8.7	1.0		<0.10										
14	0.0064	8.4	8.5	7.9		<0.10										
15	0.0072	8.2	7.8	0.7	0.7	<0.10										
16	0.0087	8.0	8.4	6.6		<0.10										
17	0.0071	8.1	7.8	1.3		<0.10	9	9	0.24	0.24	2.1	2.1	0.06	0.06	0.0	0.0
18	0.0084	7.9	8.6	3.0		<0.10										
19	0.0087	7.8	9.2	1.4		<0.10										
20	0.0116	7.8	8.6	1.8		<0.10										
21	0.0124	7.6	7.9	2.0		<0.10										
22	0.0110	8.0	6.8	1.4		<0.10										
23	0.0121	8.0	7.1	2.6		<0.10										
24	0.0119	8.1	7.6	2.1		<0.10	12	12	0.54	0.54	5.0	5.0	0.23	0.23	22.4	22.4
25	0.0099	8.2	7.0	3.2		<0.10										
26	0.0135	8.0	6.7	1.3		<0.10										
27	0.0127	7.3	7.6	1.3		<0.10										
28	0.0118	7.2	7.9	1.1		<0.10										
29	0.0101	7.7	6.4	4.4		<0.10										
30	0.0127	7.6	6.7	6.2		<0.10										
31	0.0104	7.6	6.7	1.2		<0.10										
Tot	0.2297															
Max	0.014	8.4		7.9		<0.10	12	12	0.54	0.54	6.8	6.8	0.23	0.23	22.4	22.4
Min	0.001	7.2	6.4	0.7	0.7		7	7	0.05	0.05	2.1	2.1	0.03	0.03	0.0	0.0
Ave	0.007			2.9		<0.10	10	10	0.27	0.27	4.7	4.7	0.11	0.12	5.6	5.6

Note: "0" = "<QL". The Ammonia value given as zero tested below the Ammonia QL of 0.2 mg/L. A zero is inserted here instead of "<QL" for calculation purposes.

"0" = "<QL". The BOD value given as zero tested below the test QL of 2 mg/L. A zero is inserted here instead of "<QL" for calculation purposes.

"0" = "<QL". The TSS value given as zero tested below the test QL of 1.0 mg/L. A zero is inserted here instead of "<QL" for calculation purposes.

Lab QC:

9/10/2022

Date

Permit Number: VA0067067

**QUALITY CONTROL & ASSURANCE**  
Onsite pH Instrument Calibration Confirmation Test  
Analysis of pH 7 Buffer

MONTH:	YEAR:	pH Meter Model: pH Meter Thermistor Calibration Date:			
DAY	DATE BUFFER REPLACED	PH 7 BUFFER CHECK	TIME	TEMPERATURE (degrees C)	INITIALS
1	✓	7.00	1206	24.7	JK
2		7.02	1118	25.3	JK
3		6.99	1403	28.6	JK
4		6.99	1254	26.6	JK
5		7.01	1316	28.4	JK
6		7.01	9:54	24.0	JK
7	✓	7.03	10300	24.2	JK
8	✓	7.01	1207	27.9	JK
9		7.02	1354	28.8	JK
10		7.01	1559	28.9	JK
11		7.00	1621	28.3	JK
12		7.02	1309	23.7	JK
13		7.04	1434	23.3	JK
14		7.03	1428	24.9	JK
15	✓	7.05	1552	21.8	JK
16		7.03	1405	22.1	JK
17		7.03	1406	23.8	JK
18		7.06	1408	23.6	JK
19	✓	7.03	1457	26.7	JK
20		7.01	10:16	22.1	W
21		7.02	10.33/10.23	23.7/23.0	W
22		7.03	1244	24.8	JK
23		7.02	1145	25.5	JK
24		7.04	1226	26.7	JK
25		7.03	1446	26.7	JK
26		7.01	1220	26.4	JK
27	8/27/22	7.09	12:35	29.6	JK
28		7.09	12:36	28.5	JK
29	✓	7.02	1211	26.1	JK
30		7.05	1132	27.0	JK
31		7.04	1326	25.3	JK

NOTES: Instrument calibration performed in accordance with manufacturers' instructions.  
pH Standard Method 4500 H+B - 2011



Permit Number: VA0067067

MONTH AugustYEAR 2022

## DAILY OPERATION

D A Y	Tech.'s Initials	Chlorine Contact Tank				Aeration		Digester	Comments
		TRC Sample Time	TRC Test Time	TRC Result, mg/L	RPD % (+/- 20%)	Sett. Solids %	D.O. Result mg/L		
1	<u>SC</u>	1218	1223	2.50					
2	<u>SC</u>	1155	1159	1.03		28			
3	<u>SC</u>	1408	1412	5.84					
4	<u>SC</u>	1249	1252	3.16		30			Slow wasted 5 min
5	<u>SC</u>	1510	1514	5.64					
6	<u>SC</u>	10:04	10:04	3.93					
7	<u>SC</u>	10:07	10:12	3.24					1.96 x 2
8	<u>SC</u>	1204	1207	1.00					1.62 x 2
9	<u>SC</u>	1354	1354	2.60		32			
10	<u>SC</u>	1554	1557	1.30					D.O. 8.08 pH 8.14
11	<u>SC</u>	1618	1621	7.88					
12	<u>SC</u>	1306	1309	1.34		29			
13	<u>SC</u>	1444	1449	1.03					
14	<u>SC</u>	1436	1439	7.88					
15	<u>SC</u>	1607	1610	0.70					
16	<u>SC</u>	1423	1428	6.60					
17	<u>SC</u>	1426	1430	1.25		29			
18	<u>SC</u>	1415	1419	3.04					
19	<u>SC</u>	1507	1510	1.41		30			Slow wasted 6 min
20	<u>SC</u>	10:26	10:28	1.80		30			
21	<u>SC</u>	10:38	10:42	4.99					
22	<u>SC</u>	1300	1303	1.36					
23	<u>SC</u>	1182	1185	7.58					
24	<u>SC</u>	1237	1241	2.14					
25	<u>SC</u>	1452	1455	3.22		55			wasted 10 min
26	<u>SC</u>	1232	1235	1.26		55			wasted 5 min
27	<u>RD</u>	12:39	12:37	1.32					wasted 10 min
28	<u>RD</u>	13:02	13:05	1.06					
29	<u>SC</u>	1213	1217	3.30 x 4.40		60			wasted 10 min
30	<u>SC</u>	1126	1129	4.16		52			wasted 7 min
31	<u>SC</u>	1303	1307	1.12		77			

RPD % Calculation:

Duplicate Difference

Duplicate Average

X 100

All sampling performed during forward flow.

Permit Number: VA0067067

Mt. Jackson, Va. 22842



## QUALITY CONTROL &amp; ASSURANCE

MONTH: *August*YEAR: *2022*

D A Y	COLORIMETER							DISSOLVED OXYGEN METER					pH METER									
	CALIBRATION				CALIBRATION				Membrane Replace	pH BUFFERS REPLACED?	Date Replaced	pH CALIBRATION				BUFFERS			7 check +/- 0.10	Time	INITIALS	PROBE CLEANED & REFILLED
	STANDARDS			BLANK	S1	S2	S3	Acceptable				4	7	10	Temp.	4	7	10				
1	0.00	0.15	0.83	1.58	✓	1016	X	8.16	25.1	1205	X	N	4 7 10	✓	4.01	7.00	10.01	23.0	7.00	1014	X	N
2	0.00	0.17	0.83	1.58	✓	0924	X	8.05	26.5	1113	X	N	4 7 10		4.01	7.00	10.01	23.1	7.00	0935	X	N
3	0.00	0.22	0.83	1.57	✓	1027	X	7.16	29.6	1354	X	N	4 7 10		4.01	7.00	10.01	24.1	7.01	1207	X	N
4	0.00	0.21	0.83	1.61	✓	0938	X	7.91	28.5	1253	X	N	4 7 10		4.01	7.00	10.01	24.3	7.00	0944	X	N
5	0.00	0.21	0.83	1.61	✓	1019	X	7.76	28.9	1517	X	N	4 7 10		4.01	7.00	10.01	23.7	7.02	1018	X	N
6	0.00	0.21	0.87	1.49	✓	0950	0	7.90	26.0	9:58	0	0	4 7 10		4.00	201	18.61	210	201	9:54	01	W
7	0.06	0.20	0.87	1.48	✓	0955	0	7.67	24.6	1003	0	0	4 7 10		4.01	7.00	10.00	21.2	20.3	1000-01	W	
8	0.00	0.21	0.84	1.59	✓	1036	X	8.24	27.1	1204	X	N	4 7 10		4.01	7.00	10.01	25.8	7.00	1046	X	N
9	0.00	0.20	0.84	1.57	✓	0932	X	8.45	29.2	1353	X	N	4 7 10		4.01	7.00	10.01	25.3	200	0921	X	N
10	0.00	0.18	0.84	1.61	✓	1042	X	8.20	27.8	1557	X	N	4 7 10		4.01	7.00	10.01	24.9	7.02	1051	X	N
11	0.00	0.14	0.86	1.64	✓	1031	X	7.18	29.4	1619	X	N	4 7 10		4.01	7.00	10.01	23.4	7.00	1052	X	N
12	0.00	0.19	0.85	1.63	✓	0928	X	8.25	25.0	1303	X	N	4 7 10		4.01	7.00	10.01	20.8	7.00	0927	X	N
13	0.00	0.20	0.88	1.70	✓	0931	X	8.23	25.5	1430	X	N	4 7 10		4.01	7.00	10.01	16.3	7.04	0928	X	N
14	0.00	0.15	0.88	1.65	✓	0948	X	7.36	26.7	1427	X	N	4 7 10		4.01	7.00	10.01	19.7	7.02	0944	X	N
15	0.00	0.22	0.88	1.67	✓	1052	X	8.31	21.7	1546	X	N	4 7 10		4.01	7.00	10.01	21.8	7.07	1650	X	N
16	0.00	0.21	0.88	1.72	✓	0903	X	8.09	24.7	1404	X	N	4 7 10		4.01	7.00	10.01	18.8	7.03	0901	X	N
17	0.00	0.24	0.89	1.73	✓	1045	X	8.14	26.0	1406	X	N	4 7 10		4.01	7.00	10.01	19.3	7.04	1048	X	N
18	0.00	0.18	0.87	1.68	✓	0955	X	8.09	26.2	1408	X	N	4 7 10		4.00	7.00	10.01	18.2	7.03	0954	X	N
19	0.00	0.18	0.88	1.65	✓	0958	X	7.48	20.6	0955	X	N	4 7 10		4.01	7.00	10.01	21.2	7.04	0955	X	N
20	0.00	0.21	0.87	1.48	✓	1012	0	7.90	24.8	10:20	0	0	4 7 10		4.01	201	10.01	22.1	201	10.16	01	W
21	0.00	0.20	0.87	1.67	✓	1028	0	7.85	23.4	10:33	0	0	4 7 10		4.01	202	10.01	23.0	202	10.22	01	W
22	0.00	0.19	0.88	1.68	✓	1048	X	7.38	25.5	1213	X	N	4 7 10		4.01	7.00	10.01	22.7	7.01	1046	X	N
23	0.00	0.19	0.89	1.70	✓	1015	X	7.89	27.4	1143	X	N	4 7 10		4.01	7.00	10.01	23.1	7.00	1017	X	N
24	0.00	0.18	0.88	1.68	✓	0925	X	8.42	27.9	1225	X	N	4 7 10		4.01	7.00	10.01	19.8	7.03	0838	X	N
25	0.00	0.17	0.87	1.68	✓	1003	X	7.73	28.4	1447	X	N	4 7 10		4.01	7.00	10.01	21.7	7.03	1002	X	N
26	0.00	0.19	0.85	1.63	✓	1014	X	7.33	28.1	1212	X	N	4 7 10		4.01	7.00	10.01	22.3	7.02	1003	X	N
27	0.00	0.25	0.92	1.60	✓	0914	X	7.4	29.4	1237	X	N	4 7 10		4.01	207	10.01	23.0	207	10.21	01	W
28	0.00	0.28	0.93	1.61	✓	1025	X	7.97	26.9	1228	X	N	4 7 10		4.01	207	10.01	23.9	2.07	1022	01	W
29	0.00	0.19	0.85	1.65	✓	0924	X	7.57	27.2	1215	X	N	4 7 10		4.01	7.00	10.01	25.7	6.99	0827	X	N
30	0.00	0.18	0.85	1.63	✓	0940	X	8.28	22.3	1130	X	N	4 7 10		4.01	7.00	10.01	22.7	7.01	0440	X	N
31	0.00	0.19	0.85	1.65	✓	0949	X	8.10	25.3	1322	X	N	4 7 10		4.01	7.00	10.01	20.0	7.03	0942	X	N

SPEC-CHECK Color Standards: S1 = +/-  
 Lot #: S2 = +/-  
 Exp. Date: S3 = +/-

DPD Reagent Buffering Capability (1/year): Acceptance Range pH 6.00-7.00 SU  
 Reagent Lot #: \_\_\_\_\_  
 Reagent Exp. Date: \_\_\_\_\_  
 pH Result: \_\_\_\_\_

NOTES:  
 Instrument calibration performed in accordance  
 with manufacturers' instructions.

Permit Number:

VA0067067

Month August

Year 2022

Final - 001

S N	Flow- Meter	Flow, Gallons	Techs Initials	Final Sample Time	pH Test Time	pH Result, Std. Unit	Temp. Result, °C	TRC Test Time	TRC Result, mg/L	D.O. Sample Time	D.O. Test Time	D.O. Result, mg/L
1	5374876	2304	X	1213	1218	8.02	24.2	1216	0.02	1207	1207	8.37
2	5377180	2339	X	1119	1123	8.07	24.7	1123	0.00	1116	1117	7.76
3	5379519	1704	X	1403	1408	7.23	25.9	1406	0.01	1357	1357	7.43
4	5381223	1933	X	1303	1309	8.18	25.8	1307	0.00	1258	1259	7.30
5	5383156	1384	X	1526	1525	8.17	25.3	1524	0.00	1516	1517	7.46
6	5384640	3184	W	10505	10511	7.90	24.9	1013	0.06	1020	1028	7.34
7	5387724	3084	W	10108	10114	7.87	25.1	1015	0.01	1023	1026	7.51
8	5390808	3864	X	1213	1218	8.41	21.1	1216	0.00	1209	1209	7.31
9	5394672	3708	X	1401	1405	8.24	26.3	1404	0.02	1357	1357	7.9
10	5398372	5531	X	1603	1608	8.11	26.1	1607	0.00	1601	1601	7.56
11	5403903	4017	X	1632	1637	8.19	25.3	1635	0.00	1624	1624	8.16
12	5407920	6678	X	1116	1326	8.19	23.8	1319	0.00	1311	1312	8.13
13	5414598	3253	X	1436	1441	8.21	22.7	1440	0.00	1432	1433	8.71
14	5417951	6443	X	1432	1437	8.35	22.0	1435	0.00	1439	1430	8.45
15	5424394	7204	X	1555	1600	8.21	21.9	1558	0.01	1549	1550	7.78
16	5431598	8662	X	1416	1421	7.95	22.2	1420	0.00	1410	1411	8.44
17	5440260	7128	X	1420	1425	8.06	22.4	1423	0.00	1416	1417	7.82
18	5447388	8936	X	1419	1428	8.15	22.7	1422	0.00	1411	1412	8.58
19	5455824	8691	X	1501	1506	7.77	23.4	1508	0.02	1458	1459	9.15
20	5464515	11611	W	1031	1034	7.79	23.0	1035	0.01	1040	1043	8.60
21	5476126	12356	W	1039	1044	7.66	23.8	1045	0.01	1058	1058	7.90
22	5488482	11002	X	1253	1259	8.00	24.6	1257	0.00	1248	1249	6.80
23	5499484	12132	X	1148	1153	7.97	24.7	1151	0.02	1144	1144	7.07
24	5511616	11880	X	1233	1239	8.11	25.0	1236	0.00	1227	1230	7.63
25	5523496	9980	X	1459	1504	8.15	25.5	1502	0.00	1453	1454	6.95
26	5533476	12456	X	1221	1226	7.98	25.7	1225	0.01	1217	1218	6.77
27	5546932	11288	W	12243	12246	7.30	27.7	12242	0.02	12338	1241	7.55
28	55593620	8246	X	12154	12157	7.19	27.2	12153	0.03	12147	12152	7.85
29	5571436	10100	X	1231	1238	7.71	26.3	1235	0.01	1220	1221	6.42
30	5581536	12694	X	1135	1142	7.56	26.2	1140	0.00	1133	1133	6.73
31	5594230	10436	X	1326	1331	7.62	26.4	1330	0.02	1323	1324	6.65
1st	15004666											

QA/QC NOTES: pH duplicate is to be +/- 0.10 SU - Initial pH result is to be reported  
Initial TRC reported if duplicate performed  
DO analysis is performed in-situ

Final discharge sampled during forward flow

Methods:

pH SM 4500 H+B - 2011  
DO SM 4500-OG - 2011  
TRC Hach 8167 (SM 4500-Cl G - 2011)

12738

12069

X



5790 Main Street  
Mt. Jackson, VA 22842  
(540) 477-3300  
TOLL-FREE: (800) 648-1010  
FAX: (540) 477-3360

September 10, 2022

Ms. Linda Ferguson-Davie  
Water Compliance Auditor  
Valley Regional Office - DEQ  
P. O. Box 3000  
Harrisonburg, VA 22801

Re: Christendom College STP, Permit Number VA0067067  
Letter of Explanation – Permit Violation, August 2022

Ms. Ferguson-Davie,

Inboden Environmental Services, Inc. (IES) is the contract operator for the Christendom College STP. This letter is part of Christendom College's August Discharge Monitoring Report and addresses the high ammonia result.

Exceedance: During this monitoring period, an effluent sample collected on 8/24 had an ammonia result of 22.4 mg/L. This ammonia result exceeded both the monthly average and weekly average permit limits.

Cause: IES suspects the high ammonia to be a result of grease build-up in the collection system and high influent temperatures. The final effluent temperatures were reported as >25 ° Celsius at the end of August, and it is believed that the aeration blowers were not able to provide enough aeration for nitrifier performance.

Remedy: The operator has removed floating grease from the treatment system and has turned the aeration blowers on high when the effluent temperatures are observed to be greater than 25° Celsius in order to maintain an adequate environment for nitrification.

If you have any questions or need additional information, please contact our office.

Sincerely,

Daniel Bradford, IES

CC: Mark Inboden, IES  
Tom Heim, Christendom College  
Mike Foeckler, Christendom College



# Inboden Environmental Services, Inc.

5790 Main Street, Mt. Jackson, VA 22842

## Analytical Report Form

**Customer:** Christendom College  
 134 Christendom Drive  
 Front Royal, VA 22630

**Contact:** Mike Foeckler

**Special Notes:**

**Report Date:** 8/12/2022  
**Batch ID:**  
**Received Date:** 8/3/2022  
**Sampler:** Cannone, Jonathan  
**Sample Priority:** Normal

**Sample Location:** Final Effluent      **Sample Type:** Composite - Wastewater  
**Sample ID Number:** 2208040841      **Sample Date & Time:** 8/3/2022 8:00 AM

Parameter	Result	IES	QL	Units	Method	Analysis Date	Analysis Time	Analyst
Ammonia as N	< 0.2	0.2	mg/L	*SM 4500-NH3 D-2011		8/9/2022	11:00	gh
CBOD5	7	2	mg/L	*SM 5210 B-2011		8/4/2022	10:30	gh
Total Suspended Solids	4.8	1	mg/L	*SM 2540 D-2011		8/4/2022	9:30	gh

**Notes:**

Analytes with an asterisk (\*) present indicate NELAP accreditation. Analytes that have no asterisk(\*) are not NELAP accredited.

Reproduction of this report is not permitted, except in full, without the expressed written consent of Inboden Environmental Services Inc.

IES Quantification Limit is the concentration of the lowest calibration standard above zero with a reliable signal.

Chain-of-Custody indicates complete composite sample collection time frame.

SM represents "Standard Methods for the Examination of Water and Wastewater", 22nd Edition, 2012.

Results shown relate only to samples.

Reviewed and approved for Inboden Environmental Services, Inc.

By:   
 Date: 8/12/2022

Mark E. Inboden, Laboratory Director





## CHAIN OF CUSTODY/REQUEST FOR ANALYSIS

Inboden Environmental Services, Inc.

5790 Main Street, Mt. Jackson, VA 22842

tel: (540)477-3300 fax: (540)477-3360 toll free: 1-800-648-1010

Email: frontdesk@ies.com

A NELAP Accredited Laboratory: VELAP Laboratory ID# 460024



Page 1 of 1

PLEASE USE PRINT TO FILL OUT THIS FORM. CORRECTION TAPE, PAINT, OR INK IS PROHIBITED. PLEASE USE BLUE OR BLACK INK.

Client Name: Christendom College		COMPLIANCE TYPE		Turn Around Time (TAT):		LAB USE ONLY	
Address: 134 Christendom Drive Front Royal, Va 22630 Contact: Mike Foeckler Phone#: 540-636-2900 Fax#: 540-636-1655 Email: Project Name: Quote/PO#:		VPDES/DMR/VPA PWSID: NON-COMPLIANCE		Normal <input checked="" type="checkbox"/>	Rush <input type="checkbox"/>	Received on Ice? <input checked="" type="checkbox"/> Y / <input type="checkbox"/> N	
				Rush TAT subject to pre-approval and surcharge Date Required: <u>  </u> / <u>  </u> / <u>  </u>		Correct bottles used? <input checked="" type="checkbox"/> Y / <input type="checkbox"/> N COC/Labels on bottles agree? <input checked="" type="checkbox"/> Y / <input type="checkbox"/> N	
		MATRIX		METHOD OF PRESERVATION KEY:		Correct Preservation on all preserved bottles? <input checked="" type="checkbox"/> Y / <input type="checkbox"/> N Cl <sub>2</sub> Check for Ammonia? <input type="checkbox"/> Y / <input checked="" type="checkbox"/> N - or <input type="checkbox"/> N/A Total number of bottles: <u>2</u>	
		Wastewater <input checked="" type="checkbox"/>	Drinking Water <input type="checkbox"/>	(1) Cool, <6° (5) HCL (9) Ascorbic Acid (2) H <sub>2</sub> SO <sub>4</sub> (6) Na <sub>2</sub> SO <sub>3</sub> (10) Filter (3) HNO <sub>3</sub> (7) Na <sub>2</sub> S <sub>2</sub> O <sub>3</sub> (4) NaOH (8) None Other: _____		Temp Instr. ID# <u>Etekcity</u>	

SAMPLE INFORMATION						ANALYSIS REQUESTED						
SAMPLE LOCATION	Composite Start		Composite End or Grab		Samplers Initials	Sample Type*	Bottle Type**	PARAMETER		Preservative (See Key Above)	Receipt Temp.	Bottle Properly Preserved?
	Date	Time	Date	Time				G -or- C	G -or- P			
Final Effluent	8/3/22 0800	8/3/22 0800	8/3/22 0800	8/3/22 0800	X	C	P	CBOD5, TSS		1	0.9	Y
Final Effluent	8/3/22 0800	8/3/22 0800	8/3/22 0800	8/3/22 0800	X	C	P	Ammonia		1,2	0.7	Y

Sampled by: <u>Jonathan Cannone</u>	Date: <u>8/3/22</u>	Time: <u>1413</u>	Received by: _____	Date: <u>8/3/22</u>	Time: <u>1753</u>	Comments: _____
Relinquished by: <u>Jonathan Cannone</u>	Date: <u>8/3/22</u>	Time: <u>1753</u>	Received by: <u>Shab</u>	Date: <u>8/3/22</u>	Time: <u>1753</u>	
Relinquished by: _____	Date: _____	Time: _____	Received by: _____	Date: _____	Time: _____	
Relinquished by: _____	Date: _____	Time: _____	Received by: _____	Date: _____	Time: _____	

\* G=Grab; C=Composite

\*\*G=Glass; P=Plastic

2208040841

QAM attachment #16  
rev. 1.0 mel 12815

Christendom College STP  
WASTEWATER TREATMENT

Permit Number:

VA0067067

Inboden Environmental Services, Inc.  
Mt. Jackson, Va. 22842

QUALITY CONTROL & ASSURANCE  
Onsite pH Instrument Calibration Confirmation Test  
Analysis of pH 7 Buffer

MONTH:	YEAR:	pH Meter Model: pH Meter Thermistor Calibration Date:			
DAY	DATE BUFFER REPLACED	PH 7 BUFFER CHECK	TIME	TEMPERATURE (degrees C)	INITIALS
1		7.06	13:56	17.4	
2		7.07	17:01	16.1	
3		7.04	14:36	17.3	
4		7.06	18:07	19.3	
5		7.01	16:53	27.6	KAD
6		7.02	11:18	22.5	KAD
7					
8					
9					
10					
11					
12					
13					
14					
15					
16					
17					
18					
19					
20					
21					
22					
23					
24					
25					
26					
27					
28					
29					
30					
31					

NOTES: Instrument calibration performed in accordance with manufacturers' instructions.

pH Standard Method 4500 H+B - 2011

Christendom College STP  
WASTEWATER TREATMENT  
Permit Number:

Christendom College STP  
WASTEWATER TREATMENT

Permit Number: VA0067067

Permit Number: VA0067067

Inboden Environmental Services, Inc.

Mr. Johnson, 247740



UA

D A Y	Month		Year		Final - 001							
	Flow Meter	Flow, Gallons	Techs Initials	Final Sample Time	pH Test Time	pH Result, Std. Unit	Temp. Result, °C	TRC Test Time	TRC Result, mg/L	D.O. Sample Time	D.O. Test Time	D.O. Result, mg/L
1	6244722	13133	JP	15:00	15:02	7.61	17.8	15:05	0.02	15:18	15:14	6.81
2	6257855	11282	JP	17:10	17:13	7.32	20.7	17:15	0.01	17:19	17:21	7.03
3	6269137	17135	JP	14:41	14:43	7.59	19.8	14:45	0.00	14:47	14:50	7.13
4	6281772	1575	JP	18:20	18:23	7.40	18.9	18:23	0.03	18:27	18:30	6.78
5	6293342	8105	JP	17:04	17:07	7.21	22.7	17:09	0.02	17:02	17:06	6.59
6	6301452		JP	11:46	11:49	7.37	22.6	11:44	0.02	11:43	11:46	6.52
7												
8												
9												
10												
11												
12												
13												
14												
15												
16												
17												
18												
19												
20												
21												
22												
23												
24												
25												
26												
27												
28												
29												
30												
31												
32												
QA/QC NOTES:		pH duplicate is to be +/- 0.10 SU - initial pH result is to be reported initial TRC reported if duplicate performed DO analysis is performed in-situ				Final discharge sampled during forward flow				Methods:		
										pH	SM 4500 H*B - 2011	
										DO	SM 4500-OIS - 2011	
										TRC	Hach 8167 (SM 4500/CI) (S - 2011)	

QA/QC NOTES: pH duplicate is to be +/- 0.10 SU - initial pH result is to be reported initial TRC reported if duplicate performed DO analysis is performed in-situ

Final discharge sampled during forward flow

Methods: pH SM 4500-H'B - 2011  
 DO SM 4500-QG - 2011  
 TRC Hach 8167 (SM 4500-CI G - 2011)

### pH Result:

### Initials

Christendom College STP  
WASTEWATER TREATMENT

Permit Number: VA0067067

Inboden Environmental Services, Inc.

Mt. Jackson, Va. 22842



QUALITY CONTROL & ASSURANCE

MONTH:      YEAR:

D A Y	COLORIMETER				DISSOLVED OXYGEN METER				pH METER								PROBE CLEANED & REFILLED				
	CALIBRATION				CALIBRATION				pH CALIBRATION				BUFFERS				T check +/- 0.10	Time	INITIALS		
	STANDARDS				Acceptable	Time	Initials	D.O. mg/L	TEMP °C	Time	Initials	Membrans Replace	pH BUFFERS REPLACED?	Date Replaced	4	7	14	Temp.			
1	0.00	0.23	0.38	1.65	✓	16:00	SP	2.58	20.1	14:30	SP	N	4 7 10	4.03	7.02	10.04	13.7	7.02	10.02	SP	N
2	0.00	0.22	0.39	1.66	✓	12:05	SP	4.31	16.7	12.01	SP	N	4 7 10	4.03	7.02	10.04	15.9	7.02	12:03	SP	N
3	0.00	0.16	0.26	1.47	✓	6:45	SP	3.46	19.8	14:38	SP	N	4 7 10	4.03	7.02	10.04	14.4	6.99	10.59	SP	N
4	0.00	0.16	0.34	1.62	✓	9:25	SP	3.09	23.8	13:06	SP	N	4 7 10	4.03	7.02	10.04	16.8	7.02	9.14	SP	N
5	0.00	0.23	0.36	1.66	✓	6:02	KDP	8.11	24.6	16.52	KDP	N	4 7 10	4.03	7.02	10.04	19.5	7.02	6.07	SP	N
6	0.00	0.21	0.39	1.68	✓	9:30	KDP	3.60	21.6	11:31	KDP	N	4 7 10	4.03	7.02	10.04	20.5	6.98	6.10	SP	N
7													4 7 10								
8													4 7 10								
9													4 7 10								
10													4 7 10								
11													4 7 10								
12													4 7 10								
13													4 7 10								
14													4 7 10								
15													4 7 10								
16													4 7 10								
17													4 7 10								
18													4 7 10								
19													4 7 10								
20													4 7 10								
21													4 7 10								
22													4 7 10								
23													4 7 10								
24													4 7 10								
25													4 7 10								
26													4 7 10								
27													4 7 10								
28													4 7 10								
29													4 7 10								
30													4 7 10								
31													4 7 10								
	SPEC-CHECK Color Standards: S1 = +/- 0.09 Lot #: _____ S2 = +/- 0.10 Exp. Date: _____ S3 = +/- 0.14				DPD Reagent Buffering Capability (1/month): Acceptance Range pH 6.00-7.00 SU Reagent Lot #: _____ Date: _____ Reagent Exp. Date: _____ Time: _____ pH Result: _____ Initials: _____														NOTES: Instrument calibration performed in accordance with manufacturers' instructions.		

Christendom College STP  
WASTEWATER TREATMENT

Permit Number: VA0067067

DAILY OPERATION

MONTH	YEAR	Chlorine Contact Tank			Aeration			Digester	Comments
D	A	Tech's Initials	TRC Sample Time	TRC Test Time	TRC Result, mg/L	RPD % (+/- 20%)	Sett. Solids %	D.O. Result mg/L	Sludge Hauled
1	25	SS	15:14	15:18	2.10				
2	25	SS	17:24	17:38	2.05				
3	25	SS	14:54	14:58	1.87				
4	25	SS	18:32	18:35	1.95				
5	25	KPD	16:53	16:58	3.51				
6	25	KPD	11:19	11:22	4.74				
7									
8									
9									
10									
11									
12									
13									
14									
15									
16									
17									
18									
19									
20									
21									
22									
23									
24									
25									
26									
27									
28									
29									
30									
31									

RPD % Calculation:

Duplicate Difference  
Duplicate Average

X 100

All sampling performed during forward flow.

Filled O2 tank with 12Y2 Gallon.  
Cl2 150K3

11/6/22 Sunday 73°F cloudy 200/DS

- Calibrated Instrument
- Skimmed & Strapped & Hosed Clarifier
- Skimmed 5 gals from Contact tank
- Added 2 Cl<sub>2</sub> tablets to return Box
- Added SO<sub>2</sub> tablets shook down
- Added H<sub>2</sub>O mix with 1 Cyp polymer to aeration
- Added 3 bags of G bugs
- Ran Daily Tests

10/30/22 Sunday 62°F Sunny

- Calibrated Instruments
- Skinned Clarifiler a lot
- Hosed Clarifiler
- Change tube in Cl<sub>2</sub> stenner pump
- unclogged Cl<sub>2</sub> ~~line~~ pull up line with new tubing
- added 2 Cl<sub>2</sub> tablets to return box
- added 3 Bag O2 & Bugs to aeration
- Ran Daily tests
- added SO<sub>2</sub> tablets & shook down
- Left blower on Hand

10/31/22 Monday 54°F light rain

- Calibrated Instruments
- Skinned Clarifiler & Hosed down
- Skinned some in contact tank
- added SO<sub>2</sub> tablets & shook down
- added 3 bags O2 & Bugs to aeration
- added 1 Cl<sub>2</sub> tablet to return box

10/31/22 Continued

- wasted 10 mins
- First Choice pumped Contact tank & digester
- Ran Daily tests

Tuesday 11/1/22 Torsicco & Tracy  
Change Braker for Blower #1  
wine both blower to Normal 

11-22

- calibrated tools, wasted 10 min
- Skimmed clarifier
- Shook down & added sea
- Added 3 bags of bugs
- Added 4 ClO tablets to Return
- Hosed clarifier
- Hosed Creek 
- Ran test

11-22

- calibrated instruments, Hosed Creek
- wasted 10 min, Added 3 bags of bugs
- Skimmed clarifier & contact tank, Added 1 CUP POPO
- Pumped contact tank, Bucket Boxe off Auto SAM
- Hosed clarifier, Shook down sea & added 



5790 Main Street  
Mt. Jackson, VA 22842  
(540) 477-3300  
TOLL-FREE: (800) 648-1010  
FAX: (540) 477-3360  
WEB: www.4ies.com

## Thermometer Calibration Certificate

Client: IES Operator

Date: 08/08/2022  
Time: 11:00 AM


Make	Model No.	Serial No.	Type	Range	Divisions, °C	Immersion	Length
Oakton	pH 30	T31108110	pH Meter	0 to 50 °C	0.1 °C	N/A	N/A

NIST Thermometer Reading	Thermometer Reading	Correction
0.0 °C	0.3 °C	-0.3 °C
15.0 °C	15.1 °C	-0.1 °C
30.0 °C	30.2 °C	-0.2 °C

NOTE: If above correction is preceded by a (+) sign, it should be added to the thermometer reading; if it is preceded by a (-) sign, it should be subtracted from the thermometer reading to obtain the correct temperature.

Make	Model No.	Serial No.	Type	Range	Divisions, °C	Immersion	Length
Thermco	1011-3	1015	Glass nitrogen filled	-1 to 110 °C	0.2 °C	76 mm	457 mm

NIST thermometer checked with ice point. Pure distilled shaved ice used for ice point calibration.

  
Laboratory Technician  
Gabriella Hensley

Consulting-Laboratory-Monitoring-Contract Operations-Engineering-Utility Contractor



5790 Main Street  
Mt. Jackson, VA 22842

1000 Clark Street  
McLean, VA 22101

Phone: 477-6390

FAX: 703-256-2942

5790 Main Street  
Mt. Jackson, VA 22842  
(540) 477-3300  
TOLL-FREE (800) 648-1010  
FAX. (540) 477-3360  
WEB: www.4ies.com

## INBODEN ENVIRONMENTAL SERVICES, Inc.

5790 Main St. Mt. Jackson, VA 22842

QUALITY CONTROL

### INBODEN ENVIRONMENTAL SERVICES, Inc.

5790 Main St. Mt. Jackson, VA 22842

#### QUALITY CONTROL LOG

#### COLORIMETER INSTRUMENT CHECK

Date: 08-08-2022

Client: IES Operations		Date: 08-08-2022
Instrument Identification: Hach DR300 S/N 19090A001360		Date: DEC-2022
DPD Chlorine Standard	Lot: A0356 Exp. Date: DEC-2022	
DPD Chlorine Standard	Standard Reading	Instrument Reading
Standard 1	0.21 ± 0.09	0.18
Standard 2	0.91 ± 0.10	0.88
Standard 3	1.60 ± 0.14	1.56
Accepted (YES or NO)		YES
Primary Check Standard		
YSI Primary Standard Kit	Lot: 200729 Exp Date: 08-31-2022	
Standard Value:	Instrument Reading	
1.49 ± 0.006	1.45	
Accepted (YES or NO)	YES	

\* All values listed are in mg/L

*G. Hensley*  
Laboratory Technician  
Gabriella Hensley



5790 Main Street  
Mt. Jackson, VA 22842  
(540) 477-3300  
TOLL-FREE: (800) 648-1010  
FAX: (540) 477-3360  
WEB: www.ies.com

## Laboratory Secondary Control Standard Certificate

Date: 08/08/2022  
Time: 11:00 AM

Client: IES Operator

Make	Model No.	Serial No.	Type	Range	Divisions, S.U.
Oakton	pH 30	T31108110	pH Meter	-1.00-15.00 S.U.	0.01 S.U.

pH Buffer 4 Identification	pH Buffer 7 Identification	pH Buffer 10 Identification	Temperature °C	Acceptable (YES or NO)
Manufacturer: BlueBook Lot No.:1GH1124 Reading: 3.99	Manufacturer: BlueBook Lot No.:1GF824 Reading: 7.00	Manufacturer: BlueBook Lot No.:1GG1079 Reading: 10.00	23.1	<u>YES</u>

Laboratory Standard	Standard Value	pH Meter Reading	Acceptable (YES or NO) pH within 0.10 of standard
Manufacturer: USABlueBook Lot No.:1GC844	7.00	6.97	<u>YES</u>

pH determined using SM4500-H+ B-2011

Laboratory Technician  
Gabriella Hensley

Consulting-Laboratory-Monitoring-Contract Operations-Engineering-Utility Contractor



5790 Main Street  
Mt. Jackson, VA 22842  
(540) 477-3300  
TOLL-FREE: (800) 648-1010  
FAX: (540) 477-3360  
WEB: www.4ies.com

## Thermometer Calibration Certificate

Date: 08/08/2022  
Time: 11:00 AM

Client: IES Operations  
5790 Main St. Mount Jackson, VA 22842

Make	Model No.	Serial No.	Type	Range, °C	Divisions, °C	Immersion	Length
EcoSense	DO200A	JC06598	Thermister	-6.0 to +46.0	0.1 °C	N/A	N/A

NIST Thermometer Reading		Thermometer Reading	Correction
0.0 °C		0.1 °C	-0.1 °C
15.0 °C		15.0 °C	0.0 °C
30.0 °C		30.0 °C	0.0 °C

NOTE: If above correction is preceded by a (+) sign, it should be added to the thermometer reading; if it is preceded by a (-) sign, it should be subtracted from the thermometer reading to obtain the correct temperature.

Calibration Instrument							
Make	Model No.	Serial No.	Type	Range	Divisions, °C	Immersion	Length
Thermco	1011-3	1015	Glass nitrogen filled	-1 to 110 °C	0.2 °C	76 mm	457 mm

NIST thermometer checked with ice point. Pure distilled shaved ice used for ice point calibration.

  
Quality Control Technician  
Gabriella Hensley

Consulting-Laboratory-Monitoring-Contract Operations-Engineering-Utility Contractor

# OPERATION AND MAINTENANCE MANUAL

Christendom College  
Sewage Treatment Plant

July 1985

Prepared For:  
Christendom College  
134 Christendom Drive  
Front Royal, VA 22630

Revised By:  
Inboden Environmental Services, Inc.  
5790 Main Street  
Mount Jackson, VA 22842  
(540) 477-3300

Revised:  
November 1985  
January 1991  
March 9, 2009  
June 19, 2018

## IV. OPERATION OF TREATMENT FACILITY

The operation of the treatment facility shall be in accordance with the manufacturers recommendations, contained in Appendix "H" of this manual. A generalized check list for troubleshooting appears as Appendix "E" of this manual.

Sludge generated at the facility is disposed of in accordance with the approved Sludge Management Plan for VPDES Permit No: VA0067067 and involves pumping and hauling the wasted sludge to the Town of Front Royal STP.

The operation of sludge pump and supernatant pump station shall be on an as needed bases. The operation and maintenance of these pumps shall be in accordance with the manufacturers' recommendations, contained in Appendix "L" of this manual.

## V. MAINTENANCE

Routine maintenance shall be performed by the plant operator. Major repairs and equipment replacements shall be performed by Inboden Environmental Services, Inc. or Kappe Associates, Inc.

### Tools

Normal maintenance will be accomplished with common tools. These common tools shall be supplied by the College. Any special equipment will be supplied by the service representative.

### Spare Parts

The following spare parts will be stored at the College:

1. 1 each: Spare blower (The spare blower shall have identical features to the blower furnished with the plant. The blower shall be less motors and accessories and be packaged for storage.)
2. 6 each: snap caps
3. 6 each: diffusers
4. 4 each: froth nozzle
5. 2 each: blower belts
6. 2 each: complete set of blower bearings

These parts shall be stored at a dry inside location readily accessible for replacement.

## Maintenance Schedule

### General

Daily	1. Check motors for overheating by hand 2. Wash plant sidewalls
Weekly	1. Check effluent weir level
Monthly	1. Clean dust away from motor
Semi-Annually	1. Check valves for leaks 2. Clean spray pump screen
Yearly	1. Repaint effluent weir 2. Clean and repaint metal surfaces 3. Scrape and paint all exposed steel

### Electrical

Monthly	1. Inspect breakers, fuses, and resets
Yearly	1. Check electrical leads

### Comminutor

Monthly	1. Check oil level 2. Check cutting efficiency
Semi-Annually	1. Grease Comminutor

### Aerator Blowers

Daily	1. Check air valve settings
Weekly	1. Inspect V-belt for slippage
Monthly	1. Check pulley alignment 2. Clean air filter 3. Oil pressure relief valve 4. Inspect V-belt for wear 5. Check oil level

6. Grease bearings
7. Check motor mounting bolts

### Clarifier

Daily	<ol style="list-style-type: none"><li>1. Clean tank walls</li><li>2. Skim scum from scum baffles</li><li>3. Hose down weirs and scum</li></ol>
Semi-annually	<ol style="list-style-type: none"><li>1. Take out of service and inspect all mechanical equipment wear and corrosion.</li><li>2. Check all moving parts for wear</li><li>3. Replace moving parts, if necessary</li><li>4. Check weirs to make sure they are level</li></ol>

### Hypochlorinator

For all maintenance of the hypochlorinator see Appendix "J".

### Cascade Aerator

Daily	<ol style="list-style-type: none"><li>1. Clean any deposits or debris</li></ol>
-------	---

### Maintenance Records

The College shall institute procedures for maintaining an equipment record system. Each major component of the plant shall have an equipment record maintained on it.

The Vice President of Operations shall have ultimate responsibility for the maintenance of the equipment record system and review the records at a minimum of once per year. The Vice President of Operations may day to day keeping of the equipment records to the designated operator.

The equipment records shall be kept in a 3-ring binder catalog in the office of the Vice President of Operations.

The maintenance record for each piece of equipment shall include the following:

1. Common Name:
2. Function:
3. Date of Purchase:
4. Manufacturer model number:
5. Serial Number:
6. Notes:
7. Listings of Corrective or Emergency Maintenance work: A detailed description of the problem, its source, and curative procedures shall be attached to the maintenance record for each piece of equipment.

Sample Maintenance Record Forms are shown in Appendix “G”.

## VI. SAMPLING AND LABORATORY TESTING

All field monitoring and sampling shall be done by the contract operator. Required field monitoring and sample types are listed on the VPDES permit.

Sampling: Influent and other process control samples may be taken at any time to diagnose a biological issue or quantify various parameters within the treatment waste. All effluent samples are taken from a point following the cascade aerator. All samples are either classified as “composite” or “grab” samples. A “composite” sample is composited from many individual samples collected at regular intervals over a period of time. The volume of each sample is taken proportional to the flow a rate at the time of sampling. A “grab” sample is a single sample collected at one individual sampling event and does not reflect the current flow rate. Required sampling parameters and frequencies are specified in the VPDES Permit No: VA0067067. Sample results must be reported within the Discharge Monitoring Report (DMR) and sent to DEQ each month. A copy of the DMR is included as Appendix “B”.

The following principles are to be followed in order to collect a representative sample:

1. Samples should be taken after post-aeration.
2. Sample are to be preserved and cooled properly.
3. Sample containers shall be clean and not contaminated during sampling.

**Christendom College STP**

WASTEWATER TREATMENT

Inboden Environmental Services, Inc.

Mt. Jackson, Va. 22842

*Inboden Environmental Services, Inc.*

VA0067067

**Foam Log****MONTH**

Are floating solids or is visible foam present beyond a trace (barely noticeable) amount?

Month and Year:

Day	Sample Pt.		Stream		If so, check for cause. action to be taken (if any):
	YES	NO	YES	NO	
1					
2					
3					
4					
5					
6					
7					
8					
9					
10					
11					
12					
13					
14					
15					
16					
17					
18					
19					
20					
21					
22					
23					
24					
25					
26					
27					
28					
29					
30					
31					

Can foam be created by turbulence upstream of outfall?

# Virginia Department of Environmental Quality

## Wastewater Facility Inspection Report

### Preface

VPDES Permit No.	(Re)Issuance Date	Modification Date	Expiration Date
VA0067067	01/01/2019	--	12/31/2023
Facility Name	Address		Telephone Number
Christendom College STP	134 Christendom Drive, Front Royal, VA 22630		(540) 636-2900
Owner Name	Address		Telephone Number
Christendom Educational Corporation	134 Christendom Drive, Front Royal, VA 22630		(540) 636-2900
Responsible Official	Title		Telephone Number
Tom Heim (tom.heim@christendom.edu)	Director of Operations		(540) 636-2908
Additional Contact	Title		Telephone Number
Mike Foeckler (mfoeckler@christendom.edu)	VP of Operations & Facility Planning		(540) 636-2900
Responsible Operator	Operator Certification Class/Number		Telephone Number
Mark E. Inboden (minboden@Inbodenenv.com)	Class 1 / 19650095252		(540) 477-3300

#### A. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS

1. During the period beginning with the permit's effective date and lasting until the permit's expiration date or until the issuance of the Certificate to Operate (CTO) for the 0.04 MGD or 0.05 MGD facility, whichever occurs first, the permittee is authorized to discharge from Outfall 001.

This discharge shall be limited and monitored as specified below:

	EFFLUENT CHARACTERISTICS		DISCHARGE LIMITATIONS			MONITORING REQUIREMENTS	
	Monthly Average	Weekly Average	Minimum	Maximum	Frequency	Sample Type	
Flow (MGD) <sup>a</sup>	NL	NA	NA	NL	1/Day	Estimate	
pH (standard units)	NA	NA	6.5	9.5	1/Day	Grab	
CBOD <sub>5</sub> <sup>b</sup>	24 mg/L	2.3 kg/d	36 mg/L	3.4 kg/d	1/Week	8 HC	
Total Suspended Solids <sup>b</sup>	30 mg/L	2.8 kg/d	45 mg/L	4.3 kg/d	1/Week	8 HC	
E. coli (N/100 mL) <sup>c</sup>	126	Geometric Mean	NA	NA	4/Month in any month of each calendar year		
Total Residual Chlorine (TRC)(mg/L) <sup>c</sup>	0.0080	0.0098	NA	NA	10 a.m. to 4 p.m.	Grab	
Dissolved Oxygen (mg/L)	NA	NA	6.0	NA	1/Day	Grab	
Ammonia-N (Jun-Dec) (mg/L) <sup>c</sup>	1.6	2.4	NA	NA	1/Week	8 HC	
Ammonia-N (Jan-May) (mg/L) <sup>c</sup>	2.2	3.1	NA	NA	1/Week	8 HC	

NL = No Limitation, monitoring required    NA = Not Applicable    8 HC = 8-Hour Composite

4/Month in any month of each calendar year = 4 samples taken, with at least 1 sample taken each calendar week, in any calendar month and reported no later than January 10<sup>th</sup> of every year

- a. The design flow of this treatment facility is 0.025 MGD. See Part I.D.1 for additional requirements related to facility flows.
- b. See Part I.B for disinfection requirements.
- c. See Part I.C for additional monitoring and reporting instructions.
- d. At least 85% removal for CBODs and TSS shall be attained for this discharge.
- e. This facility has Total Nitrogen and Total Phosphorus calendar year load limits associated with this outfall included in the current Registration List under registration number VAN010131, enforceable under the General VPDES Watershed Permit Regulation for Total Nitrogen and Total Phosphorus Discharges and Nutrient Trading in the Chesapeake Watershed in Virginia.
- f. There shall be no discharge of floating solids or visible foam in other than trace amounts.

# Virginia Department of Environmental Quality

## WASTEWATER FACILITY INSPECTION REPORT

<b>FACILITY NAME:</b> Christendom College STP		<b>INSPECTION DATE:</b> 11/07/2022
		<b>INSPECTOR</b> Alex Wynn
<b>PERMIT No.:</b> VA0067067		<b>REPORT DATE:</b> 11/18/2022
<b>TYPE OF FACILITY:</b> <input checked="" type="checkbox"/> Municipal <input checked="" type="checkbox"/> Small Minor <input type="checkbox"/> Industrial <input type="checkbox"/> Federal	<b>TIME OF INSPECTION:</b>	Arrival 10:00am
		Departure 11:15am
<b>PHOTOGRAPHS:</b> <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	<b>TOTAL TIME SPENT</b>	3 days w/ travel & report
	<b>UNANNOUNCED INSPECTION?</b> <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
<b>REVIEWED BY:</b> TAE, BDK		
<b>PRESENT DURING INSPECTION:</b> Mike Foeckler, Tom Heim, Mark Inboden (IES), Daniel Bradford (IES), Karl DeMay (IES), Celeste Horton (DEQ)		

### TECHNICAL INSPECTION

1. Has there been any new construction? • If so, were plans and specifications approved? Comments: Modifications were made to the aeration system and clarifier in 2021.	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> NA
2. Is the Operations and Maintenance Manual approved and up-to-date? Comments: O&M Manual was last revised in 2018.	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> NA
3. Are the Permit and/or Operation and Maintenance Manual specified licensed operator being met? Comments:	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA
4. Are the Permit and/or Operation and Maintenance Manual specified operator staffing requirements being met? Comments: An IES operator is at the facility ~2 hours/day.	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA
5. Is there an established and adequate program for training personnel? Comments:	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA
6. Are preventive maintenance task schedules being met? Comments: Metals surfaces have not been cleaned and repainted yearly. All exposed steel has not been scraped and painted yearly.	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> NA
7. Does the plant experience any organic or hydraulic overloading? Comments: Hydraulic and organic overloading. Both items are being addressed with future plant upgrades.	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA
8. Has there been any bypassing or overflows since the last inspection? Comments: None reported.	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> NA
9. Is the standby generator (including power transfer switch) operational and exercised regularly? Comments:	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> NA
10. Is the plant alarm system operational and tested regularly? Comments:	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> NA

# VA DEQ Wastewater Facility Inspection Report

Permit #	VA0067067
----------	-----------

## TECHNICAL INSPECTION

11. Is sludge disposed of in accordance with the approved sludge management plan? Comments: Sludge is hauled to Front Royal WWTP for further processing.		<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA
12. Is septage received? • If so, is septage loading controlled, and are appropriate records maintained? Comments:		<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> NA <input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> NA
13. Are all plant records (operational logs, equipment maintenance, industrial waste contributors, sampling and testing) available for review and are records adequate? Comments:		<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA
14. Which of the following records does the plant maintain? <input checked="" type="checkbox"/> Operational logs <input checked="" type="checkbox"/> Instrument maintenance & calibration <input checked="" type="checkbox"/> Mechanical equipment maintenance <input type="checkbox"/> Industrial waste contribution (Municipal facilities) Comments:		
15. What does the operational log contain? <input checked="" type="checkbox"/> Visual observations <input checked="" type="checkbox"/> Flow measurement <input checked="" type="checkbox"/> Laboratory results <input checked="" type="checkbox"/> Process adjustments <input type="checkbox"/> Control calculations <input type="checkbox"/> Other (specify): Comments:		
16. What do the mechanical equipment records contain? <input checked="" type="checkbox"/> As built plans and specs <input checked="" type="checkbox"/> Manufacturer's instructions <input checked="" type="checkbox"/> Lubrication schedules <input checked="" type="checkbox"/> Spare parts inventory <input checked="" type="checkbox"/> Equipment/parts suppliers <input type="checkbox"/> Other (specify): Comments:		
17. What do the industrial waste contribution records contain (Municipal only)? <input type="checkbox"/> Waste characteristics <input type="checkbox"/> Impact on plant <input type="checkbox"/> Locations and discharge types <input type="checkbox"/> Other (specify) Comments: NA		
18. Which of the following records are kept at the plant and available to personnel? <input checked="" type="checkbox"/> Equipment maintenance records <input checked="" type="checkbox"/> Operational log <input type="checkbox"/> Industrial contributor records <input type="checkbox"/> Instrumentation records <input checked="" type="checkbox"/> Sampling and testing records Comments: Field instrument sets are assigned to each operator. The operator keeps the instrumentation records and their IDC in their work vehicle.		
19. List records not normally available to plant personnel and their location: Comments: None		
20. Are the records maintained for the required time period (three or five years)? Comments: Hard copies are stored at the facility. Electronic copies are stored at IES.		<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No

# VA DEQ Wastewater Facility Inspection Report

Permit #	VA0067067
----------	-----------

<u>UNIT PROCESS</u>	<u>APPLICABLE</u>	<u>PROBLEMS*</u>	<u>COMMENTS</u>
Sewage Pumping			
Flow Measurement (Influent)			
Screening/Comminution	X		
Grit Removal			
Oil/Water Separator			
Flow Equalization			
Ponds/Lagoons			
Imhoff Tank			
Primary Sedimentation			
Trickling Filter			
Septic Tank and Sand Filter			
Rotating Biological Contactor			
Activated Sludge Aeration	X		<i>Trouble with filamentous growth and grease.</i>
Biological Nutrient Removal			
Sequencing Batch Reactor			
Secondary Sedimentation	X		<i>Trouble with floating solids.</i>
Flocculation			
Tertiary Sedimentation			
Filtration			
Micro-Screening			
Activated Carbon Adsorption			
Chlorination	X	1	<i>CCT baffles are developing holes from corrosion.</i>
Dechlorination	X		
Ozonation			
Ultraviolet Disinfection			
Post Aeration	X		
Flow Measurement (Effluent)	X		
Land Application (Effluent)			
Plant Outfall	X	1,5	<i>Accumulation of solids in receiving stream</i>
Sludge Pumping			
Flotation Thickening (DAF)			
Gravity Thickening			
Aerobic Digestion	X		
Anaerobic Digestion			
Lime Stabilization			
Centrifugation			
Sludge Press			
Vacuum Filtration			
Drying Beds			<i>Not in use.</i>
Thermal Treatment			
Incineration			
Composting			
Land Application (Sludge)			

\* Problem Codes

- 1. Unit Needs Attention
- 2. Abnormal Influent/Effluent
- 3. Evidence of Equipment Failure
- 4. Unapproved Modification or Temporary Repair
- 5. Evidence of Process Upset
- 6. Other (explain in comments)

# VA DEQ Wastewater Facility Inspection Report

Permit #

VA0067067

## INSPECTION OVERVIEW AND CONDITION OF TREATMENT UNITS

The single train package plant was installed in 1985. The STP receives flow from Christendom College. Modifications were made to the STP in August 2021 to address flow and treatment concerns. See unit check lists for modification specifics.

Operations staff noted the STP experiences increased organic and hydraulic loading while the college is in session (August-May). Christendom College notified DEQ on 10/17/2022 they plan to install a temporary FEQ during the week of 11/14/2022.

Operation of the aeration basin has been modified to accommodate the peak flows and reduce solids washouts. During the inspection the aeration basin was in the “settle” mode. There is no aeration in the basin from 08:00am – 01:00pm. This mode of operation was implemented during the commencement of the 2022 academic year. Treatment efficiency is regularly impacted by influent grease loading and a variability of instantaneous flows.

The clarifier had a thick blanket of brown foam on the surface. The operator stated the foam is removed daily and reoccurs on the surface by the time the operator arrives the next day. The foam is removed manually by operating the scum collection system and using a hose to spray the foam into the scum collection pipe.

The chlorine contact tank (CCT) is pumped frequently to remove settled solids. The CCT’s baffles have significant rust accumulation. Several baffles were starting to develop holes above the water surface. See camera images.

Sludge is frequently removed from the digester due to the STP’s ongoing solids issues. Sludge was last hauled away by a contracted septic hauler on 10/31/22.

There was an accumulation of solids in the receiving stream. The bulk of the solids were retained by a fallen tree approximately 10 feet downstream of the outfall. See camera images.

A pole barn style building was installed in 2022 over the treatment system to prevent leaves and other debris from falling into the tanks. The building has a coarse screen wrapped around the sides with doors to access the STP.

See unit checklists for additional comments.

# VA DEQ Wastewater Facility Inspection Report

Permit #	VA0067067
----------	-----------

## INSPECTION OVERVIEW AND CONDITION OF TREATMENT UNITS EFFLUENT FIELD DATA:

Flow	MGD	Dissolved Oxygen	mg/L	TRC (Contact Tank)	mg/L
pH	S.U.	Temperature	°C	TRC (Final Effluent)	mg/L
<b>Was a Sampling Inspection conducted?</b> <input type="checkbox"/> Yes (see Sampling Inspection Report) <input checked="" type="checkbox"/> No					

## CONDITION OF OUTFALL AND EFFLUENT CHARACTERISTICS:

1. Type of outfall:  Shore based  Submerged Diffuser?  Yes  No
2. Are the outfall and supporting structures in good condition?  Yes  No
3. Final Effluent (evidence of following problems):  Sludge bar  Grease  
 Turbid effluent  Visible foam  Unusual color  Oil sheen
4. Is there a visible effluent plume in the receiving stream?  Yes  No
5. Receiving stream:  No observed problems  Indication of problems (explain below)  
Comments: Receiving stream has settled solids and foam. It was recorded in the operator's log that the creek had been hosed.

## REQUEST for CORRECTIVE ACTION:

1. Update the O&M Manual to address the current standard of operations and the modifications made to the STP in August 2021. Ensure the O&M Manual includes a signed Part II K certification and effective date page. Submit a copy of the updated O&M Manual. [Permit Part I D.4]
2. Repair the corroding CCT baffles. [Permit Part II Q]
3. Provide the procedures used for documenting compliance with the permit requirement that there shall be no discharge of floating solids or visible foam in other than trace amounts. [Part I D.4.i]
4. Remove the accumulated solids from the receiving stream and dispose of in a proper manner. [Permit Part II F and R]
5. Cease hosing the creek. [Permit Part II F]

\*\*\*See the Laboratory Inspection Report for additional requests for corrective action.\*\*\*

## NOTES and COMMENTS:

- Ensure no foam or solids are discharged to the receiving stream when the foam on the clarifier's surface is removed and/or sprayed into the scum collection pipe. [Permit Part II F]

**UNIT PROCESS: Screening/Comminution**

1. Number of Units:	Manual: 1	Mechanical: 1	
Number in operation:	Manual: 1	Mechanical: 1	
2. Bypass channel provided:	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No	
Bypass channel in use:	<input type="checkbox"/> Yes	<input checked="" type="checkbox"/> No	
3. Area adequately ventilated:	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No *	
4. Alarm system for equipment failure or overloads:	<input type="checkbox"/> Yes	<input checked="" type="checkbox"/> No	
5. Proper flow distribution between units:	<input type="checkbox"/> Yes	<input type="checkbox"/> No	<input checked="" type="checkbox"/> NA
6. How often are units checked and cleaned?	Daily		
7. Cycle of operation:	Continuous		
8. Volume of screenings removed:	NA		
9. General condition:	<input checked="" type="checkbox"/> Good	<input type="checkbox"/> Fair	<input type="checkbox"/> Poor

## Comments:

- 3 HP comminutor motor

## UNIT PROCESS: ACTIVATED SLUDGE AERATION

1. Number of units: 1	In operation: 1		
2. Mode of operation: Extended aeration			
3. Proper flow distribution between units:	<input type="checkbox"/> Yes	<input type="checkbox"/> No*	<input checked="" type="checkbox"/> NA
4. Foam control operational:	<input type="checkbox"/> Yes	<input type="checkbox"/> No*	<input checked="" type="checkbox"/> NA
5. Scum control operational:	<input type="checkbox"/> Yes	<input type="checkbox"/> No*	<input checked="" type="checkbox"/> NA
6. Evidence of following problems:			
a. dead spots	<input type="checkbox"/> Yes*	<input checked="" type="checkbox"/> No	
b. excessive foam	<input type="checkbox"/> Yes*	<input checked="" type="checkbox"/> No	
c. poor aeration	<input type="checkbox"/> Yes*	<input checked="" type="checkbox"/> No	
d. excessive aeration	<input type="checkbox"/> Yes*	<input checked="" type="checkbox"/> No	
e. excessive scum	<input type="checkbox"/> Yes*	<input checked="" type="checkbox"/> No	
f. aeration equipment malfunction	<input type="checkbox"/> Yes*	<input checked="" type="checkbox"/> No	
g. other (identify in comments)	<input type="checkbox"/> Yes*	<input checked="" type="checkbox"/> No	

7. Mixed liquor characteristics (as available):

pH (s.u.)		SDI		Odor	None
DO (mg/L)		SVI		Color	Brown
MLSS (mg/L)		Settability (mg/L)	650 mg/L	Others (identify)	

## 8. Return/waste sludge:

a. Return Rate: Cont. b. Waste Rate: 10-15 min c. Frequency of Wasting: 1/2 days

9. Aeration system control:  Manual  Time clock  Continuous  Other (explain)

10. Effluent control devices working properly (oxidation ditches):  Yes  No\*  NA

11. General condition:  Good  Fair  Poor

### Comments:

- Aeration system control:
  - o May-August: Continuous operation
  - o September-May:
    - Air is off from 8:00am – 1:00pm during peak flows to the STP.
    - Aeration is continuous from 1:00pm – 8:00am.
- Polymer is added daily to assist with settling. 1 scoop of dry polymer is mixed with 5 gal. of water.
- BioRemove™ is added regularly to assist with treatment issues derived from oil & grease.
- Fine bubble diffusers were installed in the aeration basin in August 2021.

**UNIT PROCESS: Sedimentation** Primary       Secondary       Tertiary

1. Number of units 1      In operation: 1

2. Proper flow distribution between units:       Yes       No\*       NA

3. Signs of short circuiting and/or overloads:       Yes       No

4. Effluent weirs level:  
Clean:       Yes       No\*  
                   Yes       No\*

5. Scum collection system working properly:       Yes       No\*       NA

6. Sludge collection system working properly:       Yes       No\*

7. Influent, effluent baffle systems working properly:       Yes       No\*

8. Chemical addition:  
Chemicals: NA       Yes       No

9. Effluent characteristics: Clear with mild pin-floc.

10. General condition:       Good       Fair       Poor

## Comments:

- Thick, brown, foam floating on clarifier surface. The operator stated this occurs daily.
- The foam is removed manually by operating the scum collection system and using a hose to spray the foam into the scum collection pipe.
- The following modifications were made to the clarifier in August 2021:
  - o Increased the length of the clarifier inlet weir to cover the entire width of the clarifier.
  - o Installed a new scum collection system. The skimmer is the length of the clarifier width and is connected to a new air lift pump. The air lift pump sends the collected scum to the front of the aeration basin.
  - o A Stamford baffle was installed to keep most floating scum and sludge away from the effluent weir.
  - o Timers were installed to control the RAS/WAS air lift pumps.

## UNIT PROCESS: Chlorination

1. No. of chlorinators: 1	In operation: 1		
2. No. of evaporators: 0	In operation: 0		
3. No. of chlorine contact tanks: 1	In operation: 1		
4. Proper flow distribution between units:	<input type="checkbox"/> Yes	<input type="checkbox"/> No*	<input checked="" type="checkbox"/> NA
5. How is chlorine introduced into the wastewater?			
<input type="checkbox"/> Perforated diffusers			
<input type="checkbox"/> Injector with single entry point			
<input checked="" type="checkbox"/> Other: Drips into start of CTT from tubing connected to a solution pump.			
6. Chlorine residual in basin effluent:	>2.20 mg/L on 10/6/22		
7. Applied chlorine dosage:	2.5 gals/day		
8. Contact basins adequately baffled:	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No*	
9. Adequate ventilation:			
a. cylinder storage area	<input type="checkbox"/> Yes	<input type="checkbox"/> No*	<input checked="" type="checkbox"/> NA
b. equipment room	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No*	
10. Proper safety precautions used:	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No*	
11. General condition:	<input type="checkbox"/> Good	<input checked="" type="checkbox"/> Fair	<input type="checkbox"/> Poor

### Comments:

- Sodium Hypochlorite (12.5%) is used.
- Chlorine is fed continuously to the CCT.
- CCT baffles have significant rust accumulation. Several baffles were starting to develop holes above the water surface. See camera images.

**UNIT PROCESS: Dechlorination**

1. Chemical used:  Sulfur Dioxide  Bisulfite  Other

2. No. of sulfonators: 0 In operation: NA

3. No. of evaporators: 0 In operation: NA

4. No. of chemical feeders: 1 In operation: 1

5. No. of contact tanks: 0 In operation: NA

6. Proper flow distribution between units:  Yes  No\*  NA

7. How is chemical introduced into the wastewater?  
 Perforated diffusers  
 Injector with single entry point?  
 Other: 4-tube tablet feeder

8. Control system operational:  
a. residual analyzers:  Yes  No\*  
b. system adjusted:  Yes  No\*  Automatic  Manual  Other: NA

9. Applied dechlorination dose: ~ 4 tablets/day

10. Chlorine residual in basin effluent: <0.10 mg/L on 10/6/22

11. Contact basins adequately baffled:  Yes  No  NA

12. Adequate ventilation:  
a. cylinder storage area:  Yes  No\*  
b. equipment room:  Yes  No\*  NA  NA

13. Proper safety precautions used:  Yes  No\*

14. General condition:  Good  Fair  Poor

Comments:

## UNIT PROCESS: Post Aeration

1. Number of units: 1	In operation: 1			
2. Proper flow distribution between units:	<input type="checkbox"/> Yes	<input type="checkbox"/> No*	<input checked="" type="checkbox"/> NA	
3. Evidence of following problems:				
a. dead spots	<input type="checkbox"/> Yes*	<input checked="" type="checkbox"/> No		
b. excessive foam	<input type="checkbox"/> Yes*	<input checked="" type="checkbox"/> No		
c. poor aeration	<input type="checkbox"/> Yes*	<input checked="" type="checkbox"/> No		
d. mechanical equipment failure	<input type="checkbox"/> Yes*	<input type="checkbox"/> No	<input checked="" type="checkbox"/> NA	
4. How is the aerator controlled? <input type="checkbox"/> Manual	<input type="checkbox"/> Time clock	<input type="checkbox"/> Continuous	<input type="checkbox"/> Other	<input checked="" type="checkbox"/> NA
5. What is the current operating schedule?	Continuous			
6. Step weirs level:	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No	<input type="checkbox"/> NA	
7. Effluent D.O. level:	Not analyzed			
8. General condition:	<input checked="" type="checkbox"/> Good	<input type="checkbox"/> Fair	<input type="checkbox"/> Poor	

### Comments:

- Cascade steps following the dechlorinator.

**UNIT PROCESS: Effluent/Plant Outfall**

1. Type Outfall:  Shore based  Submerged

2. Type if shore based:  Wingwall  Headwall  Rip Rap

3. Flapper valve:  Yes  No  NA

4. Erosion of bank:  Yes\*  No  NA

5. Effluent plume visible?  Yes\*  No

6. Condition of outfall and supporting structures:  Good  Fair  Poor

7. Final effluent, evidence of following problems:

a. oil sheen  Yes\*  No

b. grease  Yes\*  No

c. sludge bar  Yes\*  No

d. turbid effluent  Yes\*  No

e. visible foam  Yes\*  No

f. unusual color  Yes\*  No

## Comments:

- c) There was an accumulation of solids in the receiving stream. The bulk of the solids were retained by a fallen tree approximately 10 feet downstream of the outfall. Solids were identified as far down as 100 ft from the outfall.
- e) Foam was identified near the outfall. See camera images.

## UNIT PROCESS: AEROBIC DIGESTION

1. Number of units:	1	In operation:	1
2. Type of sludge treated		<input type="checkbox"/> Primary	<input checked="" type="checkbox"/> WAS
3. Frequency of sludge application to digesters: Every other day.			
4. Supernatant return rate: Supernatant is manually pumped from the digester every other day.			
5. pH adjustment provided: Utilized:	<input type="checkbox"/> Yes <input type="checkbox"/> Yes	<input checked="" type="checkbox"/> No <input type="checkbox"/> No	<input checked="" type="checkbox"/> NA
6. Tank contents well-mixed and relatively free of odors:	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No*	
7. If diffused aeration is used, do diffusers require frequent cleaning?	<input type="checkbox"/> Yes	<input checked="" type="checkbox"/> No	<input type="checkbox"/> NA
8. Location of supernatant return:	<input checked="" type="checkbox"/> Head	<input type="checkbox"/> Primary	<input type="checkbox"/> Other
9. Process control testing:			
a. reduction of volatile solids	<input type="checkbox"/> Yes	<input checked="" type="checkbox"/> No	%
b. pH	<input type="checkbox"/> Yes	<input checked="" type="checkbox"/> No	s.u.
c. alkalinity	<input type="checkbox"/> Yes	<input checked="" type="checkbox"/> No	mg/l
d. dissolved oxygen	<input type="checkbox"/> Yes	<input checked="" type="checkbox"/> No	mg/l
10. Foaming problem present:	<input type="checkbox"/> Yes*	<input checked="" type="checkbox"/> No	
11. Signs of short-circuiting or overloads:	<input checked="" type="checkbox"/> Yes*	<input type="checkbox"/> No	
12. General condition:	<input checked="" type="checkbox"/> Good	<input type="checkbox"/> Fair	<input type="checkbox"/> Poor

### Comments:

- 11) Solids are frequently removed from the digester due to high volume of solids in the STP.
- The digester was recoated and reinforced as part of the August 2021 improvements.

## UNIT PROCESS: Flow Measurement

Influent       Intermediate       Effluent

1. Type measuring device: Ultrasonic transponder at a 60° V-notch weir

2. Present reading: 10.93 GPM (10:43am, 11/7/22)

3. Bypass channel:  Yes  No  
Metered:  Yes  No  NA

4. Return flows discharged upstream from meter:  Yes  No  
Identify:

5. Device operating properly:  Yes  No \*

6. Date of last calibration: 01/26/2022

## 7. Evidence of following problems:


a. obstructions  Yes\*  No  
b. grease  Yes\*  No

8. General condition:  Good  Fair  Poor

### Comments:

Christendom College STP  
11/07/2022

VA0067067



Christendom College STP

Comminutor

Aeration basin




Aeration basin

Blowers and control panels

Clarifiers (2)

Christendom College STP  
11/07/2022


VA0067067



Scum collection pipe and clarifier weir

Chlorine contact tank, ultrasonic transponder, and weir.

Baffles of chlorine contact tank. Circled in red is a hole developing from rust.



Dechlor tablet feeder, sample collection point, and cascade steps.

Red arrow is pointing to Outfall 001. The photo also shows a storm drainage outlet and blockage in the stream caused by fallen trees.

Photo taken on the west side of the fallen trees, looking towards outfall 001.

Christendom College STP  
11/07/2022

VA0067067




Photo of solids accumulation

Photo looking downstream towards the west.

Photo looking downstream towards the west. The red arrow is pointing to the Shenandoah River.



Sodium Hypochlorite (12.5%) feed and composite sampler.

Endress-Hauser flow meter.

KD's field instruments.

**DEPARTMENT OF ENVIRONMENTAL QUALITY - WATER DIVISION**  
**LABORATORY INSPECTION REPORT**

11/2014

PERMIT #: VA0067067	INSPECTION DATE: 11/07/2022	PREVIOUS INSP. DATE: 04/13/2018	PREVIOUS EVALUATION: --	TIME SPENT: 3 days w/ travel & report	
<b>NAME/ADDRESS OF FACILITY:</b> Christendom College STP 134 Christendom Drive Front Royal, VA 22630		<b>FACILITY CLASS:</b> <input type="checkbox"/> MAJOR <input type="checkbox"/> MINOR <input checked="" type="checkbox"/> MINOR (Small) <input type="checkbox"/> VPA	<b>FACILITY TYPE:</b> <input checked="" type="checkbox"/> MUNICIPAL <input type="checkbox"/> INDUSTRIAL <input type="checkbox"/> FEDERAL	<b>UNANNOUNCED INSPECTION?</b> <input checked="" type="checkbox"/> YES <input type="checkbox"/> NO	
				<b>FFY-SCHEDULED INSPECTION?</b> <input checked="" type="checkbox"/> YES <input type="checkbox"/> NO	
INSPECTOR(S): Alex Wynn	REVIEWER(S): TAE, BDK	<b>PRESENT AT INSPECTION:</b> Mike Foeckler, Tom Heim, Mark Inboden (IES), Daniel Bradford (IES), Karl DeMay (IES), Celeste Horton (DEQ)			
<b>LABORATORY EVALUATION</b>				<b>DEFICIENCIES?</b>	
				<b>Yes</b>	<b>No</b>
<b>LABORATORY RECORDS</b>				<input type="checkbox"/>	<input checked="" type="checkbox"/>
<b>GENERAL SAMPLING AND ANALYSIS</b>				<input checked="" type="checkbox"/>	<input type="checkbox"/>
<b>pH PROCEDURE</b>				<input checked="" type="checkbox"/>	<input type="checkbox"/>
<b>TOTAL RESIDUAL CHLORINE PROCEDURE</b>				<input checked="" type="checkbox"/>	<input type="checkbox"/>
<b>DISSOLVED OXYGEN PROCEDURES</b>				<input checked="" type="checkbox"/>	<input type="checkbox"/>
<b>OTHER</b>					

<b>VELAP CERTIFICATION (on site Environmental Laboratory)</b>		<b>Yes</b>	<b>No</b>	<b>NA</b>
Does the laboratory have VELAP certification (interim or final)?		<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
- Document the laboratory's VELAP laboratory number:				
- Document the effective date of the VELAP certification:				
- Document the expiration date of the VELAP certification:				
- List the certified parameters:				
<b>VELAP ACCREDITATION (Commercial Environmental Laboratory)</b>		<b>Yes</b>	<b>No</b>	
IS A VELAP ACCREDITED LAB USED FOR OTHER PERMIT REQUIRED ANALYSES? VELAP#, LAB NAME, ADDRESS and LIST PARAMETERS:		<input checked="" type="checkbox"/>	<input type="checkbox"/>	
VELAP # 460024	LAB NAME and ADDRESS Inboden Environmental Services, Inc. Mount Jackson, VA 22842			PARAMETERS TSS, CBOD5, E. coli, & Ammonia-N
IF PERMIT REQUIRED SAMPLE ANALYSIS IS PERFORMED AT ANOTHER LOCATION, ARE SHIPPING PROCEDURES ADEQUATE?		<input checked="" type="checkbox"/>	<input type="checkbox"/>	
<b>COPIES:</b> <input checked="" type="checkbox"/> DEQ - RO; <input checked="" type="checkbox"/> Owner, <input checked="" type="checkbox"/> Other: Inboden Environmental Services, Inc.				

**LABORATORY RECORDS SECTION**

LABORATORY RECORDS INCLUDE THE FOLLOWING:

<input checked="" type="checkbox"/>	SAMPLING DATE	<input checked="" type="checkbox"/>	ANALYSIS DATE	NA	CONT MONITORING CHART
<input checked="" type="checkbox"/>	SAMPLING TIME	<input checked="" type="checkbox"/>	ANALYSIS TIME	<input checked="" type="checkbox"/>	INSTRUMENT CALIBRATION
<input checked="" type="checkbox"/>	SAMPLE LOCATION	<input checked="" type="checkbox"/>	TEST METHOD	<input checked="" type="checkbox"/>	INSTRUMENT MAINTENANCE

CERTIFICATE OF ANALYSIS

WRITTEN INSTRUCTIONS INCLUDE THE FOLLOWING:

<input type="checkbox"/>	SAMPLING SCHEDULES	<input type="checkbox"/>	CALCULATIONS	<input type="checkbox"/>	ANALYSIS PROCEDURES
--------------------------	--------------------	--------------------------	--------------	--------------------------	---------------------

	YES	NO	N/A
DO ALL ANALYSTS INITIAL THEIR WORK?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
DO BENCH SHEETS (or LOG BOOK) INCLUDE ALL INFORMATION NECESSARY TO DETERMINE RESULTS?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
IS THE DMR COMPLETE AND CORRECT? LIST MONTH(S) REVIEWED: Mar-Oct 2022	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
ARE ALL MONITORING VALUES REQUIRED BY THE PERMIT REPORTED?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
DOES CHAIN OF CUSTODY DOCUMENT PROPER SAMPLE PRESERVATION WAS MET?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
WHEN THE CERTIFICATE OF ANALYSIS CONTAINS FLAGGED DATA IS THE 'FLAG' REPORTED ON THE DMR?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

**GENERAL SAMPLING AND ANALYSIS SECTION**

	YES	NO	N/A
ARE SAMPLE LOCATIONS ACCORDING TO PERMIT REQUIREMENTS?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
ARE PERMIT REQUIRED SAMPLE COLLECTION PROCEDURES APPROPRIATE?	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
ARE EFFLUENT SAMPLES REPRESENTATIVE OF THE MONITORED ACTIVITY?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
ARE PERMIT REQUIRED COMPOSITE SAMPLES FLOW PROPORTIONAL? <b>NOTE:</b> Equal volume composite aliquots are acceptable <u>if the instantaneous flow is within <math>\pm 10\%</math> of the daily average flow during the monitoring period.</u> Some permits specify how the composite is to be taken (e.g., 5G/8HC).	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
IS COLLECTION SAMPLE EQUIPMENT ADEQUATE?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
IS FLOW MEASUREMENT ACCORDING TO PERMIT REQUIREMENTS?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

**DEPARTMENT OF ENVIRONMENTAL QUALITY – WATER DIVISION**  
**LABORATORY INSPECTION REPORT SUMMARY**

<b>FACILITY NAME:</b>	Christendom College STP	<b>Permit #:</b>	VA0067067	<b>INSPECTION DATE:</b>	11/07/2022
<b>LABORATORY EVALUATION</b>		<input type="checkbox"/>	No required actions at this time		
		<input checked="" type="checkbox"/>	<b>REQUIRED CORRECTIVE ACTION(s) IDENTIFIED</b>		
<b>SUMMARY of REQUEST FOR CORRECTIVE ACTION</b>					
<b>Lab Records</b>					
<b>Laboratory Records section deficiency and required action:</b>					
<ol style="list-style-type: none"> <li>1. None noted.</li> </ol>					
<b>General Sampling and Analysis</b>					
<b>General Sampling and Analysis section deficiency and required action:</b>					
<ol style="list-style-type: none"> <li>1. Begin utilizing a thermometer in the facility's final effluent sample refrigerator. Ensure temperatures are recorded each time a composite sample is collected. The thermometer must be verified annually with a NIST certified thermometer. Provide documentation of the thermometer's implementation and of its verification with a NIST traceable thermometer. [Permit Part II B. &amp; Q.]</li> </ol>					
<b>pH Analysis</b>					
<b>pH deficiency and required action:</b>					
<ol style="list-style-type: none"> <li>1. Submit Initial Demonstration of Capabilities for the facility's operators. Maintain IDC documentation on site. [Permit Part II A.]</li> </ol>					
<b>TRC Analysis</b>					
<b>TRC deficiency and required action:</b>					
<ol style="list-style-type: none"> <li>1. Submit Initial Demonstration of Capabilities for the facility's operators. Maintain IDC documentation on site. [Permit Part II A.]</li> <li>2. Ensure the buffering capability check of DPD pillows is completed annually and the results are maintained onsite. [Permit Part II A.]</li> </ol>					
<b>D.O. Analysis</b>					
<b>D.O. deficiency and required action:</b>					
<ol style="list-style-type: none"> <li>1. Submit Initial Demonstration of Capabilities for the facility's operators. Maintain IDC documentation on site. [Permit Part II A.]</li> </ol>					
<b>OTHER – Comments or Observations</b>					
<ul style="list-style-type: none"> <li>• None.</li> </ul>					

ANALYST:	Karl DeMay	VPDES NO	VA0067067
----------	------------	----------	-----------

Meter: EcoSense DO200A

Parameter: Dissolved Oxygen  
Method: Membrane Electrode  
11/2014

METHOD OF ANALYSIS:

<input type="checkbox"/>	21 <sup>st</sup> Edition of Standard Methods (SM 21) – 4500-O G-2001 (SM 21 DO)
<input checked="" type="checkbox"/>	22 <sup>nd</sup> of Standard Methods, or Online Editions of Standard Methods (SM 22) – 4500-O G-2011 (SM 22 DO)

***Dissolved Oxygen (D.O.) is a method-defined analyte so modifications are not allowed.  
[40 CFR Part 136.6]***

	<b><i>Y</i></b>	<b><i>N</i></b>
1) Is a certificate of operator competence or initial demonstration of capability available for <u>each analyst/operator</u> performing this analysis? <b>NOTE:</b> Analyze 4 samples of air-saturated water. Recovery for each of the 4 samples must be +/- 4% of the calculated oxygen saturation for the altitude/barometric pressure and temperature of the samples. {Alternatively analyze 4 samples of water of known concentration (verified by iodometric titration procedure SM 21 or SM 22 4500-O C). Instrument measurements must agree within +/-0.1 mg/L of verified concentration.} [SM 21 or SM 22 1020 B.1 and 4020 B.1]	<input type="checkbox"/>	<input checked="" type="checkbox"/>
2) Are calibration results (mg/L) within $\pm$ 4% of the barometric (or altitude) corrected oxygen saturated water value? [SM 21 B.2 or SM 22 1020 B.2.]	<input checked="" type="checkbox"/>	<input type="checkbox"/>
3) If samples are collected, is collection carried out with a minimum of turbulence and air bubble formation and is the sample bottle allowed to overflow several times its volume? [SM 21 DO or SM 22 B 3.]	<input type="checkbox"/>	NA
4) Are meter and electrode operable and providing consistent readings? [SM 21 DO G 2. or SM 22 DO G 2.]	<input checked="" type="checkbox"/>	<input type="checkbox"/>
5) Is membrane in good condition without trapped air bubbles? <b>NOTE: No air bubbles <math>\geq</math> 1/8 inch (total area of all bubbles).</b> [SM 21 DO G 3.b. or SM 22 DO G 3.b.]	<input checked="" type="checkbox"/>	<input type="checkbox"/>
6) Is correct filling solution used in electrode? [Mfr.]	<input checked="" type="checkbox"/>	<input type="checkbox"/>
7) Are water droplets shaken off the membrane prior to calibration? [Mfr.]	<input checked="" type="checkbox"/>	<input type="checkbox"/>
8) Is meter calibrated before use or at least daily? [Mfr. & SM 21 1020 B 10.a. or SM 22 1020 B 11.a]	<input checked="" type="checkbox"/>	<input type="checkbox"/>
9) Is calibration procedure performed according to manufacturer's instructions? [Mfr.]	<input checked="" type="checkbox"/>	<input type="checkbox"/>
10) Is sample stirred during analysis (or is there sufficient flow across probe's membrane surface)? [SM 21 DO or SM 22 DO G 3.b. and Mfr.]	<input checked="" type="checkbox"/>	<input type="checkbox"/>
11) Is the sample analysis procedure performed according to manufacturer's instructions? [Mfr.]	<input checked="" type="checkbox"/>	<input type="checkbox"/>
12) Is meter stabilized before reading D.O.? [Mfr.]	<input checked="" type="checkbox"/>	<input type="checkbox"/>
13) Is electrode stored according to manufacturer's instructions? [Mfr.]	<input checked="" type="checkbox"/>	<input type="checkbox"/>

Comments:

- IDCs for the current operators were not available onsite.

ANALYST:	Karl DeMay	VPDES NO	VA0067067
----------	------------	----------	-----------

Meter: Oakton pH 30

Parameter: Hydrogen Ion (pH)

Method: Electrometric

3/2015

METHOD OF ANALYSIS:

<input type="checkbox"/>	21 <sup>st</sup> Edition of Standard Methods (SM 21) – 4500-H <sup>+</sup> B-2000 (SM 21 pH)
<input checked="" type="checkbox"/>	22 <sup>nd</sup> Edition of Standard Methods (SM 22), or Online Editions of Standard Methods – 4500-H <sup>+</sup> B-2011 (SM 22 pH)

***pH is a method-defined analyte so modifications are not allowed. [40 CFR Part 136.6]***

	Y	N
1) Is a certificate of operator competence or initial demonstration of capability available for <u>each analyst/operator</u> performing this analysis? <b>NOTE:</b> Analyze 4 samples of known pH; you may use an external source of buffers or other known standards (different lot/manufacturer than buffers used to calibrate meter). Recovery for each of the 4 samples must be +/- 0.2 SU of the known concentration of the sample or within “Acceptable Range” specified by the PT provider. [SM 1020 B.1] <b>NOTE: The same pH buffer [values] used for calibration of the instrument can be used as LCS if from a different source or different lot.</b>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
2) <b>IF</b> a replicate sample is analyzed is there a written procedure for which result will be reported on DMR (Sample or Replicate) and is this procedure being followed? [DEQ – based on EPA Good Laboratory Practices Standards]	<input type="checkbox"/>	NA
3) Is a Laboratory Control Sample (LCS) tested at least annually and are results within acceptance criteria? [SM 21 B.2 or SM 22 1020 B.3.] <b>NOTE:</b> LCS should be a purchased Proficiency Test (PT) sample or a different buffer other than ones used for calibration of the meter [with a +/- 0.2 SU acceptance range or within “Acceptable Range” specified by the PT provider]. <b>NOTE: The same pH buffer [values] used for calibration of the instrument can be used as LCS if from a different source or different lot.</b>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
4) Is the electrode in good condition (no chloride precipitate, scratches, deterioration, etc.)? [SM 21 pH or SM 22 pH 2.b./c. and 5.b.]	<input checked="" type="checkbox"/>	<input type="checkbox"/>
5) Is electrode storage solution in accordance with manufacturer's instructions? [SM 21 pH or SM 22 pH 4.a. and Mfr.]	<input checked="" type="checkbox"/>	<input type="checkbox"/>
6) Is meter calibrated on at least a daily basis using three buffers all of which are at the same temperature? [SM 21 pH or SM 22 pH 4.a.] <b>NOTE:</b> Start with Buffer 7 unless manufacturer's instructions state otherwise. <b>[NOTE: If meter is not capable of 3 buffer calibration use 2 buffers bracketing the expected sample pH and then measure a 3<sup>rd</sup> buffer (the measurement value recorded must be +/- 0.1 SU), and then reread and record value of buffer 7 to ensure +/- 0.1 SU.]</b>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
7) After calibration, is a buffer analyzed as a check sample to verify that calibration is correct? Verification measurement should be within +/- 0.1 SU. [SM 21 1020 B 10.c. or SM 22 1020 B 11.c.]	<input checked="" type="checkbox"/>	<input type="checkbox"/>
8) Is calibration verification measurement repeated with every 10 samples and at the end of a series of samples? Verification measurement should be within +/- 0.1 SU. [SM 21 pH or SM 22 pH 4020 B 2.b.] <b>NOTE:</b> Not applicable if pH meter is calibrated before taking any measurement (e.g., if operator monitors daily pH at more than one facility and calibrates before each measurement).	<input type="checkbox"/>	NA
9) Do the buffer solutions appear to be free of contamination or growths? [SM 21 pH or SM 22 pH 3.a.]	<input type="checkbox"/>	*
10) Are buffer solutions within the listed shelf-life or have they been prepared within the last 4 weeks? [SM 21 pH or SM 22 pH 3.a.]	<input type="checkbox"/>	*
11) Is the cap or sleeve covering the access hole on the reference electrode removed when measuring pH? [Mfr.]	<input type="checkbox"/>	NA
12) Is sample analyzed within 15 minutes of collections? [40 CFR Part 136]	<input checked="" type="checkbox"/>	<input type="checkbox"/>

13)	Is the electrode rinsed and then blotted dry between reading solutions (Disregard if a portion of the next sample analyzed is used as the rinsing solution.)? [SM 21 pH or SM 22 pH 4.a and 4.b.]	<input checked="" type="checkbox"/>	<input type="checkbox"/>
14)	Is the sample stirred gently at a constant speed during measurement? [SM 21 pH or SM 22 pH 4.b.]	<input checked="" type="checkbox"/>	<input type="checkbox"/>
15)	Does the meter hold a steady reading after reaching equilibrium? [4.b.]	<input checked="" type="checkbox"/>	<input type="checkbox"/>

Comments:

- IDCs for the current operators were not available onsite.
- pH buffers were not inspected at this inspection. Buffers are stored at IES's office.

<b>ANALYST:</b>	Karl DeMay	<b>VPDES NO.</b>	VA0067067
-----------------	------------	------------------	-----------

Parameter: Total Residual Chlorine (TRC)  
Method: DPD Colorimetric (HACH Pocket and Pocket II Colorimeter)  
11/2014

METHOD OF ANALYSIS:      Instrument: HACH DR300

<input checked="" type="checkbox"/>	HACH Manufacturer's Instructions (Method 8167) plus an edition of <i>Standard Methods</i>
<input type="checkbox"/>	21st Edition of <i>Standard Methods</i> 4500-Cl G-2000 (SM 21 Cl)
<input checked="" type="checkbox"/>	22 <sup>nd</sup> Edition of <i>Standard Methods</i> 4500-Cl G-2011 (SM 22 Cl)

	<b>Y</b>	<b>N</b>
1) Is a certificate of operator competence or initial demonstration of capability available for <u>each analyst/operator</u> performing this analysis? <b>NOTE:</b> Analyze 4 samples of known TRC. Must use a lot number or source that is different from that used to prepare calibration standards. May not use Spec <sup>✓</sup> ™. Acceptance range is 70-130% recovery <u>and</u> 20% Relative Standard Deviation (RSD) <u>or</u> within PT specified acceptance range <u>and</u> 20% RSD. [SM 1020 B.1]	<input type="checkbox"/>	<input checked="" type="checkbox"/>
2) Is calibration curve verification checked daily using a high and a low standard? <b>NOTE:</b> May use manufacturer's installed calibration and commercially available chlorine standards, or Spec <sup>✓</sup> ™, for daily calibration verifications. [SM 21 1020]	<input checked="" type="checkbox"/>	<input type="checkbox"/>
3) <u>IF</u> a replicate sample is analyzed is there a written procedure for which result will be reported on DMR (Sample or Replicate) and is this procedure being followed? [DEQ – based on EPA Good Laboratory Practices Standards]	<input type="checkbox"/>	NA
4) Is a Laboratory Control Sample (LCS) tested at least annually and are results within acceptance criteria? [SM 21 B. 2. or SM 22 1020 B.3.] <b>NOTE:</b> LCS should be a purchased Proficiency Test (PT) sample or if a known standard different from the calibration standards is used. Use the PT acceptance criteria when given or use 70-130% recovery <u>and</u> 20% Relative Standard Deviation (RSD) as the acceptance criteria.	<input checked="" type="checkbox"/>	<input type="checkbox"/>
5) Are the DPD Powder Pillows stored in a cool, dry place? [Mfr.]	<input checked="" type="checkbox"/>	<input type="checkbox"/>
6) Are the pillows within the manufacturer's expiration date? [Mfr.]	<input checked="" type="checkbox"/>	<input type="checkbox"/>
7) Are pillows appropriate for the sample size being analyzed and for <u>Total</u> Residual Chlorine	<input checked="" type="checkbox"/>	<input type="checkbox"/>
8) Has buffering capability of DPD pillows been checked annually? (Pillows should adjust sample pH to between 6 and 7) [Mfr.]	<input type="checkbox"/>	<input checked="" type="checkbox"/>
9) When pH adjustment is required, is H <sub>2</sub> SO <sub>4</sub> or NaOH used? [Hach 11.3.1]	<input type="checkbox"/>	NA
10) Are cells clean and in good condition? [Mfr]	<input checked="" type="checkbox"/>	<input type="checkbox"/>
11) Is the Hach colorimeter program set to measure "TRC, mg/L"? [Mfr.]	<input checked="" type="checkbox"/>	<input type="checkbox"/>
12) Is the low range (0.01 mg/L resolution) used for samples containing residuals from 0.1 mg/L - 2.00 mg/L? [Mfr.]	<input checked="" type="checkbox"/>	<input type="checkbox"/>
13) Is the 10-mL cell (2.5-cm diameter) used for samples from 0-2.00 mg/L? [Mfr.]	<input checked="" type="checkbox"/>	<input type="checkbox"/>
14) Are samples analyzed within 15 minutes of collection? [40 CFR Part 136]	<input checked="" type="checkbox"/>	<input type="checkbox"/>
15) Is meter zeroed correctly using sample for the blank analysis? [Mfr. and SM 21 1020 B.4. or SM 22 1020 B.5.]	<input checked="" type="checkbox"/>	<input type="checkbox"/>
16) Is the instrument light screen placed correctly on the meter body when the meter is zeroed and when the sample is analyzed? [Mfr.]	<input checked="" type="checkbox"/>	<input type="checkbox"/>
17) Is the DPD Total Chlorine Powder Pillow mixed into the sample? [Hach 11.1]	<input checked="" type="checkbox"/>	<input type="checkbox"/>

18)	Is the analysis made at least three minutes but not more than six minutes after Powder Pillow addition? [Hach 11.2]	<input checked="" type="checkbox"/>	<input type="checkbox"/>
19)	If read-out exceeds “2.19 mg/L”, is the original sample diluted correctly, and then reanalyzed within 15 minutes of the original collection time? [Hach 1.2 & 2.0]	<input checked="" type="checkbox"/>	<input type="checkbox"/>

Comments:

- IDCs for the current operators were not available onsite.
- Results of the annual buffering capability of DPD pillows check were not available on site.

**DEPARTMENT OF ENVIRONMENTAL QUALITY - WATER DIVISION**  
**SAMPLE ANALYSIS HOLDING TIME/CONTAINER/PRESERVATION CHECK SHEET**  
Revised 02/2015 [40 CFR, Part 136.3, Table II]

<b>FACILITY NAME:</b>	Christendom College STP						VPDES NO	VA0067067		DATE:	11/07/2022				
<b>HOLDING TIMES</b> [Note: Collection period (for composites) and Sample Collection time (end of collection period) must be recorded on the COC.]								<b>SAMPLE CONTAINER</b>				<b>PRESERVATION</b> [Note: Preservation is to occur <u>within 15</u> minutes of the end of the collection period.]			
PARAMETER	APPROVED	MET?		LOGGED?		ADEQ. VOLUME		APPROP. TYPE		APPROVED	MET?		CHECKED?		
		Y	N	Y	N	Y	N	Y	N		Y	N			
pH	15 MIN.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Within 15 minutes	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>							
CHLORINE	15 MIN.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Within 15 minutes	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>							
DISSOLVED O <sub>2</sub>	15 MIN	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Within 15 minutes	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>							
BOD <sub>5</sub> & CBOD <sub>5</sub>	48 HOURS	<input type="checkbox"/>	<input type="checkbox"/>	≤6° C	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>							
TSS	7 DAYS	<input type="checkbox"/>	<input type="checkbox"/>	≤6° C	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>							
E. coli	8 HRS	<input type="checkbox"/>	<input type="checkbox"/>	<10° C+0.008% Na <sub>2</sub> S <sub>2</sub> O <sub>3</sub>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>							
AMMONIA	28 DAYS	<input type="checkbox"/>	<input type="checkbox"/>	DECHLOR ≤6° C+H <sub>2</sub> S <sub>2</sub> O <sub>4</sub> pH<2t	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>							
Comments:	<b>All chemical preservation should be noted by the Permittee on the Chain of Custody.</b>														

Holding Times and Preservation References (VELAP except for Field Tests)

**DEPARTMENT OF ENVIRONMENTAL QUALITY - WATER DIVISION**  
**EQUIPMENT TEMPERATURE LOG/THERMOMETER VERIFICATION CHECK SHEET**  
11/2014

<b>FACILITY NAME:</b>	Christendom College STP				<b>PERMIT NO:</b>	VA0067067		<b>DATE:</b>	11/07/2022				
<b>Equipment</b>	<b>Preservation Range</b>	<b>In Range?</b>		<b>Inspector Reading</b>	<b>Checked &amp; Logged Daily?</b>		<b>Correct Increment?</b>		<b>ANNUAL THERMOMETER VERIFICATION</b>				
									<b>Yes</b>	<b>No</b>	<b>Is the NIST / NIST-Traceable Reference Thermometer within the manufacturer's expiration date or recertified yearly?</b>		<b>Yes</b>
		<b>°C</b>	<b>Yes</b>		<b>No</b>	<b>Yes</b>	<b>No</b>	<b>Date Checked</b>	<b>Marked?</b>		<b>Offset Value<sup>1</sup> (Correction)</b>	<b>NIST Inspection Temp</b>	
<b>Auto Sampler</b>	1-6° C	<input type="checkbox"/>	<input type="checkbox"/>		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>			
<b>pH Meter</b>	± 1° C	<input checked="" type="checkbox"/>	<input type="checkbox"/>						08/08/2022	<input checked="" type="checkbox"/>	<input type="checkbox"/>	-0.3, -0.1, -0.2	0, 15, 30
<b>D.O. Meter</b>	± 1° C	<input checked="" type="checkbox"/>	<input type="checkbox"/>						08/08/2022	<input checked="" type="checkbox"/>	<input type="checkbox"/>	-0.1, 0.0, 0.0	0, 15, 30

**Comments:**

- There was not a NIST-traceable thermometer in the refrigerated auto sampler.

<sup>1</sup> Offset Value tolerances (reference **NIST 105-6**): Sampling Refrigerator and Auto Sampler, pH and D.O. meters must be within ±2°C (2 times tolerance value). Thermometers measuring Outfall permit compliance must be within ±1.0°C (2 times tolerance value).

# Documents

**PERMITTED FACILITY**

Christendom College STP  
 134 Christendom Dr, Front Royal VA 22630  
**Permit Number:** VA0067067  
**Permit Type:** Minor Municipal  
**No Discharge:**

**COMMONWEALTH OF VIRGINIA**  
**DEPARTMENT OF ENVIRONMENTAL QUALITY**  
 NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)  
 DISCHARGE MONITORING REPORT (DMR)

MONITORING PERIOD	
FROM	TO
8/1/2022	8/31/2022

**RETURN TO**

Department of Environmental Quality  
 Valley Regional Office  
 4411 Early Road, P.O. Box 3000, Harrisonburg VA 22801  
 (540) 574-7800

NOTE: READ PERMIT AND GENERAL INSTRUCTIONS BEFORE  
 COMPLETING THIS FORM AND RETURNING IT.

Outfall Num: 001

Reporting Frequency: Month

Run Date: Nov 15, 2022

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION			NO. EX.	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM			
001 FLOW	REPORTD	0.007	0.014		*****	*****	*****		0	1/DAY
	REQRMNT	0.025	NL	MGD	*****	*****	*****			1/DAY
002 pH	REPORTD	*****	*****		7.2	*****	8.4		0	1/DAY
	REQRMNT	*****	*****		6.5	*****	9.5	SU		1/DAY
004 TSS	REPORTD	0.11	0.23		*****	4.7	6.8		0	1/W
	REQRMNT	2.8	4.3	KG/D	*****	30	45	MG/L		1/W
005 CL2, TOTAL	REPORTD	*****	*****		*****	<QL	<QL		0	1/DAY
	REQRMNT	*****	*****		*****	0.0080	0.0098	MG/L		1/DAY
007 DO	REPORTD	*****	*****		6.4	*****	*****		0	1/DAY
	REQRMNT	*****	*****		6.0	*****	*****	MG/L		1/DAY
157 CL2, TOTAL CONTACT	REPORTD	*****	*****		0.7	*****	*****		1	1/DAY
	REQRMNT	*****	*****		1.0	*****	*****	MG/L	3	1/DAY
159 CBOD5	REPORTD	0.27	0.54		*****	10	12		0	1/W
	REQRMNT	2.3	3.4	KG/D	*****	24	36	MG/L		1/W
213 CL2, INST TECH MIN LIMIT	REPORTD	*****	*****		0.7	*****	*****		0	1/DAY
	REQRMNT	*****	*****		0.6	*****	*****	MG/L		1/DAY
353 AMMONIA, AS N JUN-DEC	REPORTD	*****	*****		*****	5.6	22.4		2	1/W
	REQRMNT	*****	*****		*****	1.6	2.4	MG/L		1/W

**Additional Permit Requirements:** Submit daily operations log with DMR.

**Outfall Comments:**

**Comments:**

# Christendom College

Wastewater Treatment Plant

Front Royal, VA

## Monthly Log Report of Final Effluent



VA0067067

Month: August Year: 2022

DATE	Flow MGD	pH S.U.	D.O. mg/l	TRC, Cont.		TRC, Final	CBOD5				Total Suspended Solids				Ammonia - N	
				Conc. mg/L	Tech Min Lim mg/L	Conc. mg/L	Conc. mg/L	Week Ave., mg/L	Loading kg/d	Week Ave., kg/d	Conc. mg/L	Week Ave., mg/L	Loading kg/d	Week Ave., kg/d	Conc. mg/L	Week Ave., mg/L
1	0.0023	8.0	8.3	2.5		<0.10										
2	0.0023	8.1	7.8	1.0		<0.10										
3	0.0017	7.7	7.4	5.8		<0.10	7	7	0.05	0.05	4.8	4.8	0.03	0.03	0.0	0.0
4	0.0019	8.2	7.3	3.2		<0.10										
5	0.0014	8.2	7.5	5.6		<0.10										
6	0.0032	7.9	7.4	3.9		<0.10										
7	0.0031	7.9	7.5	3.2		<0.10										
8	0.0039	8.4	7.3	1.0		<0.10										
9	0.0037	8.2	7.9	2.6		<0.10										
10	0.0055	8.1	7.6	1.3		<0.10	12	12	0.25	0.25	6.8	6.8	0.14	0.14	0.0	0.0
11	0.0040	8.2	8.2	7.9		<0.10										
12	0.0067	8.2	8.1	1.3		<0.10										
13	0.0034	8.2	8.7	1.0		<0.10										
14	0.0064	8.4	8.5	7.9		<0.10										
15	0.0072	8.2	7.8	0.7	0.7	<0.10										
16	0.0087	8.0	8.4	6.6		<0.10										
17	0.0071	8.1	7.8	1.3		<0.10	9	9	0.24	0.24	2.1	2.1	0.06	0.06	0.0	0.0
18	0.0084	7.9	8.6	3.0		<0.10										
19	0.0087	7.8	9.2	1.4		<0.10										
20	0.0116	7.8	8.6	1.8		<0.10										
21	0.0124	7.6	7.9	2.0		<0.10										
22	0.0110	8.0	6.8	1.4		<0.10										
23	0.0121	8.0	7.1	2.6		<0.10										
24	0.0119	8.1	7.6	2.1		<0.10	12	12	0.54	0.54	5.0	5.0	0.23	0.23	22.4	22.4
25	0.0099	8.2	7.0	3.2		<0.10										
26	0.0135	8.0	6.7	1.3		<0.10										
27	0.0127	7.3	7.6	1.3		<0.10										
28	0.0118	7.2	7.9	1.1		<0.10										
29	0.0101	7.7	6.4	4.4		<0.10										
30	0.0127	7.6	6.7	6.2		<0.10										
31	0.0104	7.6	6.7	1.2		<0.10										
Tot	0.2297															
Max	0.014	8.4		7.9		<0.10	12	12	0.54	0.54	6.8	6.8	0.23	0.23	22.4	22.4
Min	0.001	7.2	6.4	0.7	0.7		7	7	0.05	0.05	2.1	2.1	0.03	0.03	0.0	0.0
Ave	0.007			2.9		<0.10	10	10	0.27	0.27	4.7	4.7	0.11	0.12	5.6	5.6

Note: "0" = "<QL". The Ammonia value given as zero tested below the Ammonia QL of 0.2 mg/L. A zero is inserted here instead of "<QL" for calculation purposes.

"0" = "<QL". The BOD value given as zero tested below the test QL of 2 mg/L. A zero is inserted here instead of "<QL" for calculation purposes.

"0" = "<QL". The TSS value given as zero tested below the test QL of 1.0 mg/L. A zero is inserted here instead of "<QL" for calculation purposes.

Lab QC:

9/10/2022

Date

Permit Number: VA0067067

**QUALITY CONTROL & ASSURANCE**  
Onsite pH Instrument Calibration Confirmation Test  
Analysis of pH 7 Buffer

MONTH:	YEAR:	pH Meter Model: pH Meter Thermistor Calibration Date:			
DAY	DATE BUFFER REPLACED	PH 7 BUFFER CHECK	TIME	TEMPERATURE (degrees C)	INITIALS
1	✓	7.00	1206	24.7	JK
2		7.02	1118	25.3	JK
3		6.99	1403	28.6	JK
4		6.99	1254	26.6	JK
5		7.01	1316	28.4	JK
6		7.01	9:54	24.0	JK
7	✓	7.03	10300	24.2	JK
8	✓	7.01	1207	27.9	JK
9		7.02	1354	28.8	JK
10		7.01	1559	28.9	JK
11		7.00	1621	28.3	JK
12		7.02	1309	23.7	JK
13		7.04	1434	23.3	JK
14		7.03	1428	24.9	JK
15	✓	7.05	1552	21.8	JK
16		7.03	1405	22.1	JK
17		7.03	1406	23.8	JK
18		7.06	1408	23.6	JK
19	✓	7.03	1457	26.7	JK
20		7.01	10:16	22.1	JK
21		7.02	10.33/0.23	23.7/23.0	JK
22		7.03	1244	24.8	JK
23		7.02	1145	25.5	JK
24		7.04	1226	26.7	JK
25		7.03	1446	26.7	JK
26		7.01	1220	26.4	JK
27	8/27/22	7.09	12:35	29.6	JK
28		7.09	12:36	28.5	JK
29	✓	7.02	1211	26.1	JK
30		7.05	1132	27.0	JK
31		7.04	1326	25.3	JK

NOTES: Instrument calibration performed in accordance with manufacturers' instructions.  
pH Standard Method 4500 H+B - 2011



Permit Number: VA0067067

MONTH AugustYEAR 2022

## DAILY OPERATION

D A Y	Tech.'s Initials	Chlorine Contact Tank				Aeration		Digester	Comments
		TRC Sample Time	TRC Test Time	TRC Result, mg/L	RPD % (+/- 20%)	Sett. Solids %	D.O. Result mg/L		
1	<u>SC</u>	1218	1223	2.50					
2	<u>SC</u>	1155	1159	1.03		28			
3	<u>SC</u>	1408	1412	5.84					
4	<u>SC</u>	1249	1252	3.16		30			Slow wasted 5 min
5	<u>SC</u>	1510	1514	5.64					
6	<u>SC</u>	10:04	10:04	3.93					
7	<u>SC</u>	10:07	10:12	3.24					1.96 x 2
8	<u>SC</u>	1204	1207	1.00					1.62 x 2
9	<u>SC</u>	1354	1354	2.60		32			
10	<u>SC</u>	1554	1557	1.30					D.O. 8.08 pH 8.14
11	<u>SC</u>	1618	1621	7.88					
12	<u>SC</u>	1306	1309	1.34		29			
13	<u>SC</u>	1444	1449	1.03					
14	<u>SC</u>	1436	1439	7.88					
15	<u>SC</u>	1607	1610	0.70					
16	<u>SC</u>	1423	1428	6.60					
17	<u>SC</u>	1426	1430	1.25		29			
18	<u>SC</u>	1415	1419	3.04					
19	<u>SC</u>	1507	1510	1.41		30			Slow wasted 6 min
20	<u>SC</u>	10:26	10:28	1.80		30			
21	<u>SC</u>	10:38	10:42	4.99					
22	<u>SC</u>	1300	1303	1.36					
23	<u>SC</u>	1182	1185	7.58					
24	<u>SC</u>	1237	1241	2.14					
25	<u>SC</u>	1452	1455	3.22		55			wasted 10 min
26	<u>SC</u>	1232	1235	1.26		55			wasted 5 min
27	<u>RD</u>	12:39	12:37	1.32					wasted 10 min
28	<u>RD</u>	13:02	13:05	1.06					
29	<u>SC</u>	1213	1217	3.30 x 4.40		60			wasted 10 min
30	<u>SC</u>	1126	1129	4.16		52			wasted 7 min
31	<u>SC</u>	1303	1307	1.12		77			

RPD % Calculation:

Duplicate Difference

Duplicate Average

X 100

All sampling performed during forward flow.

Permit Number: VA0067067

Mt. Jackson, Va. 22842



## QUALITY CONTROL &amp; ASSURANCE

MONTH: *August*YEAR: *2022*

D A Y	COLORIMETER							DISSOLVED OXYGEN METER					pH METER										
	CALIBRATION				CALIBRATION				Membrane Replace	pH BUFFERS REPLACED?	Date Replaced	pH CALIBRATION				BUFFERS				7 check +/- 0.10	Time	INITIALS	PROBE CLEANED & REFILLED
	STANDARDS			BLANK	S1	S2	S3	Acceptable				4	7	10	Temp.	4	7	10	Temp.				
1	0.00	0.15	0.83	1.58	✓	1016	X	8.16	25.1	1205	X	N	4 7 10	✓	4.01	7.00	10.01	23.0	7.00	1014	X	N	
2	0.00	0.17	0.83	1.58	✓	0924	X	8.05	26.5	1113	X	N	4 7 10		4.01	7.00	10.01	23.1	7.00	0935	X	N	
3	0.00	0.22	0.83	1.57	✓	1027	X	7.16	29.6	1354	X	N	4 7 10		4.01	7.00	10.01	24.1	7.01	1207	X	N	
4	0.00	0.21	0.83	1.61	✓	0938	X	7.91	28.5	1253	X	N	4 7 10		4.01	7.00	10.01	24.3	7.00	0944	X	N	
5	0.00	0.21	0.83	1.61	✓	1019	X	7.76	28.9	1517	X	N	4 7 10		4.01	7.00	10.01	23.7	7.02	1018	X	N	
6	0.00	0.21	0.87	1.49	✓	0950	0	7.90	26.0	9:58	0	0	4 7 10		4.00	201	18.01	210	201	9:54	01	W	
7	0.06	0.20	0.87	1.48	✓	0955	0	7.67	24.6	1003	0	0	4 7 10		4.01	7.00	10.00	21.2	20.3	1000-01	W		
8	0.00	0.21	0.84	1.59	✓	1036	X	8.24	27.1	1204	X	N	4 7 10		4.01	7.00	10.01	25.8	7.00	1046	X	N	
9	0.00	0.20	0.84	1.57	✓	0932	X	8.45	29.2	1353	X	N	4 7 10		4.01	7.00	10.01	25.3	200	0921	X	N	
10	0.00	0.18	0.84	1.61	✓	1042	X	8.20	27.8	1557	X	N	4 7 10		4.01	7.00	10.01	24.9	7.02	1051	X	N	
11	0.00	0.14	0.86	1.64	✓	1031	X	7.18	29.4	1619	X	N	4 7 10		4.01	7.00	10.01	23.4	7.00	1052	X	N	
12	0.00	0.19	0.85	1.63	✓	0928	X	8.25	25.0	1303	X	N	4 7 10		4.01	7.00	10.01	20.8	7.00	0927	X	N	
13	0.00	0.20	0.88	1.70	✓	0931	X	8.23	25.5	1430	X	N	4 7 10		4.01	7.00	10.01	16.3	7.04	0928	X	N	
14	0.00	0.15	0.86	1.65	✓	0948	X	7.36	26.7	1427	X	N	4 7 10		4.01	7.00	10.01	19.7	7.02	0944	X	N	
15	0.00	0.22	0.88	1.67	✓	1052	X	8.31	21.7	1546	X	N	4 7 10		4.01	7.00	10.01	21.8	7.07	1650	X	N	
16	0.00	0.21	0.88	1.72	✓	0903	X	8.09	24.7	1404	X	N	4 7 10		4.01	7.00	10.01	18.8	7.03	0901	X	N	
17	0.00	0.24	0.89	1.73	✓	1045	X	8.14	26.0	1406	X	N	4 7 10		4.01	7.00	10.01	19.3	7.04	1048	X	N	
18	0.00	0.18	0.87	1.68	✓	0955	X	8.09	26.2	1408	X	N	4 7 10		4.00	7.00	10.01	18.2	7.03	0954	X	N	
19	0.00	0.18	0.88	1.65	✓	0958	X	7.48	20.6	0955	X	N	4 7 10		4.01	7.00	10.01	21.2	7.04	0955	X	N	
20	0.00	0.21	0.87	1.48	✓	1012	0	7.90	24.8	10:20	0	0	4 7 10		4.01	201	10.01	221	201	10.16	01	W	
21	0.00	0.20	0.87	1.67	✓	1028	0	7.85	23.4	10:33	0	0	4 7 10		4.01	202	10.01	23.0	202	10.22	01	W	
22	0.00	0.19	0.88	1.68	✓	1048	X	7.38	25.5	1213	X	N	4 7 10		4.01	7.00	10.01	22.7	21.01	1046	X	N	
23	0.00	0.19	0.89	1.70	✓	1015	X	7.89	27.4	1143	X	N	4 7 10		4.01	7.00	10.01	23.1	7.00	1017	X	N	
24	0.00	0.18	0.88	1.68	✓	0925	X	8.42	27.9	1225	X	N	4 7 10		4.01	7.00	10.01	19.8	7.03	0838	X	N	
25	0.00	0.17	0.87	1.68	✓	1003	X	7.73	28.4	1447	X	N	4 7 10		4.01	7.00	10.01	21.7	7.03	1002	X	N	
26	0.00	0.19	0.85	1.63	✓	1014	X	7.33	28.1	1212	X	N	4 7 10		4.01	7.00	10.01	22.3	7.02	1003	X	N	
27	0.00	0.25	0.92	1.60	✓	0914	X	7.4	29.4	1237	X	N	4 7 10		4.01	207	10.01	25.0	20.3	6.09	01	W	
28	0.00	0.28	0.93	1.61	✓	1025	X	7.97	26.9	1228	X	N	4 7 10		4.01	207	10.01	23.9	2.07	6.2	01	W	
29	0.00	0.19	0.85	1.65	✓	0924	X	7.57	27.2	1215	X	N	4 7 10		4.01	7.00	10.01	25.7	6.49	0827	X	N	
30	0.00	0.18	0.85	1.63	✓	0940	X	8.28	22.3	1130	X	N	4 7 10		4.01	7.00	10.01	22.7	7.01	0440	X	N	
31	0.00	0.19	0.85	1.65	✓	0949	X	8.10	25.3	1322	X	N	4 7 10		4.01	7.00	10.01	20.0	7.03	0942	X	N	

SPEC-CHECK Color Standards: S1 = +/-  
 Lot #: S2 = +/-  
 Exp. Date: S3 = +/-

DPD Reagent Buffering Capability (1/year): Acceptance Range pH 6.00-7.00 SU  
 Reagent Lot #: \_\_\_\_\_  
 Reagent Exp. Date: \_\_\_\_\_  
 pH Result: \_\_\_\_\_

NOTES:

Instrument calibration performed in accordance  
 with manufacturers' instructions.

Permit Number:

VA0067067

Month August

Year 2022

Final - 001

S N	Flow- Meter	Flow, Gallons	Techs Initials	Final Sample Time	pH Test Time	pH Result, Std. Unit	Temp. Result, °C	TRC Test Time	TRC Result, mg/L	D.O. Sample Time	D.O. Test Time	D.O. Result, mg/L
1	5374876	2304	X	1213	1218	8.02	24.2	1216	0.02	1207	1207	8.37
2	5377180	2339	X	1119	1123	8.07	24.7	1123	0.00	1116	1117	7.76
3	5379519	1704	X	1403	1408	7.23	25.9	1406	0.01	1357	1357	7.43
4	5381223	1933	X	1303	1309	8.18	25.8	1307	0.00	1258	1259	7.30
5	5383156	1384	X	1526	1525	8.17	25.3	1524	0.00	1516	1517	7.46
6	5384640	3184	W	10505	10511	7.90	24.9	1013	0.06	1020	1028	7.34
7	5387724	3084	W	10108	10114	7.87	25.1	1015	0.01	1023	1026	7.51
8	5390808	3864	X	1213	1218	8.41	21.1	1216	0.00	1209	1209	7.31
9	5394672	3708	X	1401	1405	8.24	26.3	1404	0.02	1357	1357	7.9
10	5398372	5531	X	1603	1608	8.11	26.1	1607	0.00	1601	1601	7.56
11	5403903	4017	X	1632	1637	8.19	25.3	1635	0.00	1624	1624	8.16
12	5407920	6678	X	1116	1326	8.19	23.8	1319	0.00	1311	1312	8.13
13	5414598	3253	X	1436	1441	8.21	22.7	1440	0.00	1432	1433	8.71
14	5417951	6443	X	1432	1437	8.35	22.0	1435	0.00	1439	1430	8.45
15	5424394	7204	X	1555	1600	8.21	21.9	1558	0.01	1549	1550	7.78
16	5431598	8662	X	1416	1421	7.95	22.2	1420	0.00	1410	1411	8.44
17	5440260	7128	X	1420	1425	8.06	22.4	1423	0.00	1416	1417	7.82
18	5447388	8936	X	1419	1428	8.15	22.7	1422	0.00	1411	1412	8.58
19	5455824	8691	X	1501	1506	7.77	23.4	1508	0.02	1458	1459	9.15
20	5464515	11611	W	1031	1034	7.79	23.0	1035	0.01	1040	1043	8.60
21	5476126	12356	W	1039	1044	7.66	23.8	1045	0.01	1058	1058	7.90
22	5488482	11002	X	1253	1259	8.00	24.6	1257	0.00	1248	1249	6.80
23	5499484	12132	X	1148	1153	7.97	24.7	1151	0.02	1144	1144	7.07
24	5511616	11880	X	1233	1239	8.11	25.0	1236	0.00	1227	1230	7.63
25	5523496	9980	X	1459	1504	8.15	25.5	1502	0.00	1453	1454	6.95
26	5533476	12456	X	1221	1226	7.98	25.7	1225	0.01	1217	1218	6.77
27	5546932	11288	W	12243	12246	7.30	27.7	12242	0.02	12338	1241	7.55
28	55593620	8246	X	12154	12157	7.19	27.2	12153	0.03	12147	12152	7.85
29	5571436	10100	X	1231	1238	7.71	26.3	1235	0.01	1220	1221	6.42
30	5581536	12694	X	1135	1142	7.56	26.2	1140	0.00	1133	1133	6.73
31	5594230	10436	X	1326	1331	7.62	26.4	1330	0.02	1323	1324	6.65
1st	15004666											

QA/QC NOTES: pH duplicate is to be +/- 0.10 SU - Initial pH result is to be reported  
Initial TRC reported if duplicate performed  
DO analysis is performed in-situ

Final discharge sampled during forward flow

Methods:

pH SM 4500 H+B - 2011  
DO SM 4500-OG - 2011  
TRC Hach 8167 (SM 4500-Cl G - 2011)

12738

12069

X



5790 Main Street  
Mt. Jackson, VA 22842  
(540) 477-3300  
TOLL-FREE: (800) 648-1010  
FAX: (540) 477-3360

September 10, 2022

Ms. Linda Ferguson-Davie  
Water Compliance Auditor  
Valley Regional Office - DEQ  
P. O. Box 3000  
Harrisonburg, VA 22801

Re: Christendom College STP, Permit Number VA0067067  
Letter of Explanation – Permit Violation, August 2022

Ms. Ferguson-Davie,

Inboden Environmental Services, Inc. (IES) is the contract operator for the Christendom College STP. This letter is part of Christendom College's August Discharge Monitoring Report and addresses the high ammonia result.

Exceedance: During this monitoring period, an effluent sample collected on 8/24 had an ammonia result of 22.4 mg/L. This ammonia result exceeded both the monthly average and weekly average permit limits.

Cause: IES suspects the high ammonia to be a result of grease build-up in the collection system and high influent temperatures. The final effluent temperatures were reported as >25 ° Celsius at the end of August, and it is believed that the aeration blowers were not able to provide enough aeration for nitrifier performance.

Remedy: The operator has removed floating grease from the treatment system and has turned the aeration blowers on high when the effluent temperatures are observed to be greater than 25° Celsius in order to maintain an adequate environment for nitrification.

If you have any questions or need additional information, please contact our office.

Sincerely,

Daniel Bradford, IES

CC: Mark Inboden, IES  
Tom Heim, Christendom College  
Mike Foeckler, Christendom College



# Inboden Environmental Services, Inc.

5790 Main Street, Mt. Jackson, VA 22842

## Analytical Report Form

**Customer:** Christendom College  
 134 Christendom Drive  
 Front Royal, VA 22630

**Contact:** Mike Foeckler

**Special Notes:**

**Report Date:** 8/12/2022  
**Batch ID:**  
**Received Date:** 8/3/2022  
**Sampler:** Cannone, Jonathan  
**Sample Priority:** Normal

**Sample Location:** Final Effluent      **Sample Type:** Composite - Wastewater  
**Sample ID Number:** 2208040841      **Sample Date & Time:** 8/3/2022 8:00 AM

Parameter	Result	IES	QL	Units	Method	Analysis Date	Analysis Time	Analyst
Ammonia as N	< 0.2	0.2	mg/L	*SM 4500-NH3 D-2011		8/9/2022	11:00	gh
CBOD5	7	2	mg/L	*SM 5210 B-2011		8/4/2022	10:30	gh
Total Suspended Solids	4.8	1	mg/L	*SM 2540 D-2011		8/4/2022	9:30	gh

**Notes:**

Analytes with an asterisk (\*) present indicate NELAP accreditation. Analytes that have no asterisk(\*) are not NELAP accredited.

Reproduction of this report is not permitted, except in full, without the expressed written consent of Inboden Environmental Services Inc.

IES Quantification Limit is the concentration of the lowest calibration standard above zero with a reliable signal.

Chain-of-Custody indicates complete composite sample collection time frame.

SM represents "Standard Methods for the Examination of Water and Wastewater", 22nd Edition, 2012.

Results shown relate only to samples.

Reviewed and approved for Inboden Environmental Services, Inc.

By:   
 Date: 8/12/2022

Mark E. Inboden, Laboratory Director





## CHAIN OF CUSTODY/REQUEST FOR ANALYSIS

Inboden Environmental Services, Inc.

5790 Main Street, Mt. Jackson, VA 22842

tel: (540)477-3300 fax: (540)477-3360 toll free: 1-800-648-1010

Email: frontdesk@ies.com

A NELAP Accredited Laboratory: VELAP Laboratory ID# 460024



Page 1 of 1

PLEASE USE PRINT TO FILL OUT THIS FORM. CORRECTION TAPE, PAINT, OR INK IS PROHIBITED. PLEASE USE BLUE OR BLACK INK.

Client Name: Christendom College		COMPLIANCE TYPE		Turn Around Time (TAT):		LAB USE ONLY	
Address: 134 Christendom Drive Front Royal, Va 22630 Contact: Mike Foeckler Phone#: 540-636-2900 Fax#: 540-636-1655 Email: Project Name: Quote/PO#:		VPDES/DMR/VPA PWSID: NON-COMPLIANCE		Normal <input checked="" type="checkbox"/>	Rush <input type="checkbox"/>	Received on Ice? <input checked="" type="checkbox"/> Y / <input type="checkbox"/> N	
				Rush TAT subject to pre-approval and surcharge Date Required: <u>  </u> / <u>  </u> / <u>  </u>		Correct bottles used? <input checked="" type="checkbox"/> Y / <input type="checkbox"/> N COC/Labels on bottles agree? <input checked="" type="checkbox"/> Y / <input type="checkbox"/> N	
		MATRIX		METHOD OF PRESERVATION KEY:		Correct Preservation on all preserved bottles? <input checked="" type="checkbox"/> Y / <input type="checkbox"/> N Cl <sub>2</sub> Check for Ammonia? <input type="checkbox"/> Y / <input checked="" type="checkbox"/> N - or <input type="checkbox"/> N/A Total number of bottles: <u>2</u>	
		Wastewater <input checked="" type="checkbox"/>	Drinking Water <input type="checkbox"/>	(1) Cool, <6° (5) HCL (9) Ascorbic Acid (2) H <sub>2</sub> SO <sub>4</sub> (6) Na <sub>2</sub> SO <sub>3</sub> (10) Filter (3) HNO <sub>3</sub> (7) Na <sub>2</sub> S <sub>2</sub> O <sub>3</sub> (4) NaOH (8) None Other: _____		Temp Instr. ID# <u>Etekcity</u>	

SAMPLE INFORMATION						ANALYSIS REQUESTED						
SAMPLE LOCATION	Composite Start		Composite End or Grab		Samplers Initials	Sample Type*	Bottle Type**	PARAMETER		Preservative (See Key Above)	Receipt Temp.	Bottle Properly Preserved?
	Date	Time	Date	Time				G -or- C	G -or- P			
Final Effluent	8/3/22 0800	8/3/22 0800	8/3/22 0800	8/3/22 0800	X	C	P	CBOD5, TSS		1	0.9	Y
Final Effluent	8/3/22 0800	8/3/22 0800	8/3/22 0800	8/3/22 0800	X	C	P	Ammonia		1,2	0.7	Y

Sampled by: <u>Jonathan Cannone</u>	Date: <u>8/3/22</u>	Time: <u>1413</u>	Received by: _____	Date: <u>8/3/22</u>	Time: <u>1753</u>	Comments: _____
Relinquished by: <u>Jonathan Cannone</u>	Date: <u>8/3/22</u>	Time: <u>1753</u>	Received by: <u>Shab</u>	Date: <u>8/3/22</u>	Time: <u>1753</u>	
Relinquished by: _____	Date: _____	Time: _____	Received by: _____	Date: _____	Time: _____	
Relinquished by: _____	Date: _____	Time: _____	Received by: _____	Date: _____	Time: _____	

\* G=Grab; C=Composite

\*\*G=Glass; P=Plastic

2208040841

QAM attachment #16  
rev. 1.0 mel 12815

Christendom College STP  
WASTEWATER TREATMENT

Permit Number:

VA0067067

Inboden Environmental Services, Inc.  
Mt. Jackson, Va. 22842

**QUALITY CONTROL & ASSURANCE**  
Onsite pH Instrument Calibration Confirmation Test  
Analysis of pH 7 Buffer

MONTH:	YEAR:	pH Meter Model: pH Meter Thermistor Calibration Date:			
DAY	DATE BUFFER REPLACED	PH 7 BUFFER CHECK	TIME	TEMPERATURE (degrees C)	INITIALS
1		7.06	13:56	17.4	
2		7.07	17:01	16.1	
3		7.04	14:36	17.3	
4		7.06	18:07	19.3	
5		7.01	16:53	27.6	KAD
6		7.02	11:18	22.5	KAD
7					
8					
9					
10					
11					
12					
13					
14					
15					
16					
17					
18					
19					
20					
21					
22					
23					
24					
25					
26					
27					
28					
29					
30					
31					

NOTES: Instrument calibration performed in accordance with manufacturers' instructions.

pH Standard Method 4500 H+B - 2011

Christendom College STP  
WASTEWATER TREATMENT  
Permit Number:

Christendom College STP  
WASTEWATER TREATMENT

Permit Number: VA0067067

Inboden Environmental Services, Inc.

Mc. Jordon, Va. 22112



D A Y	Month		Year		Final - 001							
	Flow Meter	Flow, Gallons	Techs Initials	Final Sample Time	pH Test Time	pH Result, Std. Unit	Temp. Result, °C	TRC Test Time	TRC Result, mg/L	D.O. Sample Time	D.O. Test Time	D.O. Result, mg/L
1	6244722	13133	JP	15:00	15:02	7.61	17.8	15:05	0.03	15:18	15:14	6.81
2	6257855	11132	JP	17:10	17:13	7.32	20.7	17:15	0.01	17:19	17:20	7.03
3	6269137	12135	JP	14:41	14:43	7.59	19.8	14:45	0.00	14:47	14:50	7.13
4	6281772	1575	JP	18:20	18:23	7.40	18.9	18:23	0.03	18:27	18:30	6.78
5	6293347	8105	JP	12:04	12:07	7.21	22.7	12:09	0.02	12:02	12:06	6.59
6	6301452		JP	11:46	11:49	7.37	22.6	11:44	0.02	11:43	11:46	6.52
7												
8												
9												
10												
11												
12												
13												
14												
15												
16												
17												
18												
19												
20												
21												
22												
23												
24												
25												
26												
27												
28												
29												
30												
31												
32												
33												
34												
		QA/QC NOTES: pH duplicate is to be +/- 0.10 SU - initial pH result is to be reported initial TRC reported if duplicate performed DO analysis is performed in-situ						Final discharge sampled during forward flow		Methods:	pH	SM 4500 H/B - 2011
										DO	SM 4500-O/G - 2011	
										TRC	Hach 8167 (SM 4500-C/G - 2011)	

Christendom College STP  
WASTEWATER TREATMENT

Permit Number: VA0067067

Inboden Environmental Services, Inc.

Mt. Jackson, Va. 22842



QUALITY CONTROL & ASSURANCE

MONTH:      YEAR:

D A Y	COLORIMETER				DISSOLVED OXYGEN METER				pH METER								PROBE CLEANED & REFILLED				
	CALIBRATION				CALIBRATION				pH CALIBRATION				BUFFERS				T check +/- 0.10	Time	INITIALS		
	STANDARDS				Acceptable	Time	Initials	D.O. mg/L	TEMP °C	Time	Initials	Membrans Replace	pH BUFFERS REPLACED?	Date Replaced	4	7	14	Temp.			
1	0.00	0.23	0.38	1.65	✓	16:00	SP	2.58	20.1	14:30	SP	N	4 7 10	4.03	7.02	10.04	13.7	7.04	10.02	SP	N
2	0.00	0.22	0.39	1.66	✓	12:05	SP	4.31	16.7	12.01	SP	N	4 7 10	4.03	7.02	10.04	15.9	7.05	12.03	SP	N
3	0.00	0.16	0.26	1.47	✓	6:45	SP	3.46	19.8	14:38	SP	N	4 7 10	4.03	7.02	10.04	14.4	6.49	6.59	SP	N
4	0.00	0.16	0.34	1.62	✓	9:25	SP	3.09	23.8	13:06	SP	N	4 7 10	4.03	7.02	10.04	16.8	7.00	9.40	SP	N
5	0.00	0.23	0.36	1.66	✓	6:02	KDP	8.11	24.6	16.57	KDP	N	4 7 10	4.03	7.02	10.04	19.5	7.02	16.07	KDP	N
6	0.00	0.21	0.39	1.68	✓	9:30	KDP	3.60	21.6	11:31	KDP	N	4 7 10	4.03	7.02	10.04	20.5	6.98	6.10	KDP	N
7													4 7 10								
8													4 7 10								
9													4 7 10								
10													4 7 10								
11													4 7 10								
12													4 7 10								
13													4 7 10								
14													4 7 10								
15													4 7 10								
16													4 7 10								
17													4 7 10								
18													4 7 10								
19													4 7 10								
20													4 7 10								
21													4 7 10								
22													4 7 10								
23													4 7 10								
24													4 7 10								
25													4 7 10								
26													4 7 10								
27													4 7 10								
28													4 7 10								
29													4 7 10								
30													4 7 10								
31													4 7 10								
	SPEC-CHECK Color Standards: S1 = +/- 0.09												DPD Reagent Buffering Capability (1/month): Acceptance Range pH 6.00-7.00 SU				NOTES:				
	Lot #: S2 = +/- 0.10												Reagent Lot #:				Instrument calibration performed in accordance with manufacturers' instructions.				
	Exp. Date: S3 = +/- 6.14												Reagent Exp. Date:				Date:				
	pH Result:												pH Result:				Time:				
																	Initials:				

Christendom College STP  
WASTEWATER TREATMENT

Permit Number: VA0067067

DAILY OPERATION

MONTH	YEAR	Chlorine Contact Tank				Aeration		Digester	Comments	
		D A Y	Tech's Initials	TRC Sample Time	TRC Test Time	TRC Result, mg/L	RPD % (+/- 20%)	Sett. Solids %	D.O. Result mg/L	
1	28	15:14	JP	15:18		2.10				
2	29	17:24	JP	17:38		2.05				
3	30	14:54	JP	14:58		1.87				
4	1	18:32	JP	18:35		1.95				
5	2	16:53	KPD	16:58		3.51				
6	3	11:19	KPD	11:22		4.74				
7										
8										
9										
10										
11										
12										
13										
14										
15										
16										
17										
18										
19										
20										
21										
22										
23										
24										
25										
26										
27										
28										
29										
30										
31										

RPD % Calculation:

Duplicate Difference  
Duplicate Average

X 100

All sampling performed during forward flow.

Filled O2 tank with 12Y2 Gallon.  
Cl2 150K3

11/6/22 Sunday 73°F cloudy 200/DS

- Calibrated Instrument
- Skimmed & Strapped & Hosed Clarifier
- Skimmed 5 gals from Contact tank
- Added 2 Cl<sub>2</sub> tablets to return Box
- Added SO<sub>2</sub> tablets shook down
- Added H<sub>2</sub>O mix with 1 Cyp polymer to aeration
- Added 3 bags of G bugs
- Ran Daily Tests

10/30/22 Sunday 62°F Sunny

- Calibrated Instruments
- Skinned Clarifiler a lot
- Hosed Clarifiler
- Change tube in Cl<sub>2</sub> stenner pump
- unclogged Cl<sub>2</sub> ~~line~~ pull up line with new tubing
- added 2 Cl<sub>2</sub> tablets to return box
- added 3 Bag O2 & Bugs to aeration
- Ran Daily tests
- added SO<sub>2</sub> tablets & shook down
- Left blower on Hand

10/31/22 Monday 54°F light rain

- Calibrated Instruments
- Skinned Clarifiler & Hosed down
- Skinned some in contact tank
- added SO<sub>2</sub> tablets & shook down
- added 3 bags O2 & Bugs to aeration
- added 1 Cl<sub>2</sub> tablet to return box

10/31/22 Continued

- wasted 10 mins
- First Choice pumped Contact tank & digester
- Ran Daily tests

Tuesday 11/1/22 Torsicco & Tracy  
Change Braker for Blower #1  
wine both blower to Normal 

11-22

- calibrated tools, wasted 10 min
- Skimmed clarifier
- Shook down & Added sea
- Added 3 bags of bugs
- Added 4 ClO tablets to Return
- Hosed clarifier
- Hosed Creek 
- Ran test

11-22

- calibrated instruments, Hosed Creek
- wasted 10 min, Added 3 bags of bugs
- Skimmed clarifier & contact tank, Added 1 CUP POPO
- Pumped contact tank, Bucket Boxe off Auto SAM
- Hosed clarifier, Shook down sea & Added 



5790 Main Street  
Mt. Jackson, VA 22842  
(540) 477-3300  
TOLL-FREE: (800) 648-1010  
FAX: (540) 477-3360  
WEB: www.4ies.com

## Thermometer Calibration Certificate

Client: IES Operator

Date: 08/08/2022  
Time: 11:00 AM


Make	Model No.	Serial No.	Type	Range	Divisions, °C	Immersion	Length
Oakton	pH 30	T31108110	pH Meter	0 to 50 °C	0.1 °C	N/A	N/A

NIST Thermometer Reading	Thermometer Reading	Correction
0.0 °C	0.3 °C	-0.3 °C
15.0 °C	15.1 °C	-0.1 °C
30.0 °C	30.2 °C	-0.2 °C

NOTE: If above correction is preceded by a (+) sign, it should be added to the thermometer reading; if it is preceded by a (-) sign, it should be subtracted from the thermometer reading to obtain the correct temperature.

Make	Model No.	Serial No.	Type	Range	Divisions, °C	Immersion	Length
Thermco	1011-3	1015	Glass nitrogen filled	-1 to 110 °C	0.2 °C	76 mm	457 mm

NIST thermometer checked with ice point. Pure distilled shaved ice used for ice point calibration.

  
Laboratory Technician  
Gabriella Hensley

Consulting-Laboratory-Monitoring-Contract Operations-Engineering-Utility Contractor



5790 Main Street  
Mt. Jackson, VA 22842

1000 Clark Street  
McLean, VA 22101

Phone: 477-6390

FAX: 703-256-2942

5790 Main Street  
Mt. Jackson, VA 22842  
(540) 477-3300  
TOLL-FREE (800) 648-1010  
FAX. (540) 477-3360  
WEB: www.4ies.com

## INBODEN ENVIRONMENTAL SERVICES, Inc.

5790 Main St. Mt. Jackson, VA 22842

QUALITY CONTROL

### INBODEN ENVIRONMENTAL SERVICES, Inc.

5790 Main St. Mt. Jackson, VA 22842

#### QUALITY CONTROL LOG

#### COLORIMETER INSTRUMENT CHECK

Date: 08-08-2022

Client: IES Operations		Date: 08-08-2022
Instrument Identification: Hach DR300 S/N 19090A001360		Date: DEC-2022
DPD Chlorine Standard	Lot: A0356 Exp. Date: DEC-2022	
DPD Chlorine Standard	Standard Reading	Instrument Reading
Standard 1	0.21 ± 0.09	0.18
Standard 2	0.91 ± 0.10	0.88
Standard 3	1.60 ± 0.14	1.56
Accepted (YES or NO)		YES
Primary Check Standard		
YSI Primary Standard Kit	Lot: 200729 Exp Date: 08-31-2022	
Standard Value:	Instrument Reading	
1.49 ± 0.006	1.45	
Accepted (YES or NO)	YES	

\* All values listed are in mg/L

*G. Hensley*  
Laboratory Technician  
Gabriella Hensley



5790 Main Street  
Mt. Jackson, VA 22842  
(540) 477-3300  
TOLL-FREE: (800) 648-1010  
FAX: (540) 477-3360  
WEB: www.ies.com

## Laboratory Secondary Control Standard Certificate

Date: 08/08/2022  
Time: 11:00 AM

Client: IES Operator

Make	Model No.	Serial No.	Type	Range	Divisions, S.U.
Oakton	pH 30	T31108110	pH Meter	-1.00-15.00 S.U.	0.01 S.U.

pH Buffer 4 Identification	pH Buffer 7 Identification	pH Buffer 10 Identification	Temperature °C	Acceptable (YES or NO)
Manufacturer: BlueBook Lot No.:1GH1124 Reading: 3.99	Manufacturer: BlueBook Lot No.:1GF824 Reading: 7.00	Manufacturer: BlueBook Lot No.:1GG1079 Reading: 10.00	23.1	<u>YES</u>

Laboratory Standard	Standard Value	pH Meter Reading	Acceptable (YES or NO) pH within 0.10 of standard
Manufacturer: USABlueBook Lot No.:1GC844	7.00	6.97	<u>YES</u>

pH determined using SM4500-H+ B-2011

Laboratory Technician  
Gabriella Hensley

Consulting-Laboratory-Monitoring-Contract Operations-Engineering-Utility Contractor



5790 Main Street  
Mt. Jackson, VA 22842  
(540) 477-3300  
TOLL-FREE: (800) 648-1010  
FAX: (540) 477-3360  
WEB: www.4ies.com

## Thermometer Calibration Certificate

Date: 08/08/2022  
Time: 11:00 AM

Client: IES Operations  
5790 Main St. Mount Jackson, VA 22842

Make	Model No.	Serial No.	Type	Range, °C	Divisions, °C	Immersion	Length
EcoSense	DO200A	JC06598	Thermister	-6.0 to +46.0	0.1 °C	N/A	N/A

NIST Thermometer Reading	Thermometer Reading	Correction
0.0 °C	0.1 °C	-0.1 °C
15.0 °C	15.0 °C	0.0 °C
30.0 °C	30.0 °C	0.0 °C

NOTE: If above correction is preceded by a (+) sign, it should be added to the thermometer reading; if it is preceded by a (-) sign, it should be subtracted from the thermometer reading to obtain the correct temperature.

Calibration Instrument							
Make	Model No.	Serial No.	Type	Range	Divisions, °C	Immersion	Length
Thermco	1011-3	1015	Glass nitrogen filled	-1 to 110 °C	0.2 °C	76 mm	457 mm

NIST thermometer checked with ice point. Pure distilled shaved ice used for ice point calibration.

  
Quality Control Technician  
Gabriella Hensley

Consulting-Laboratory-Monitoring-Contract Operations-Engineering-Utility Contractor

# OPERATION AND MAINTENANCE MANUAL

Christendom College  
Sewage Treatment Plant

July 1985

Prepared For:  
Christendom College  
134 Christendom Drive  
Front Royal, VA 22630

Revised By:  
Inboden Environmental Services, Inc.  
5790 Main Street  
Mount Jackson, VA 22842  
(540) 477-3300

Revised:  
November 1985  
January 1991  
March 9, 2009  
June 19, 2018

## IV. OPERATION OF TREATMENT FACILITY

The operation of the treatment facility shall be in accordance with the manufacturers recommendations, contained in Appendix "H" of this manual. A generalized check list for troubleshooting appears as Appendix "E" of this manual.

Sludge generated at the facility is disposed of in accordance with the approved Sludge Management Plan for VPDES Permit No: VA0067067 and involves pumping and hauling the wasted sludge to the Town of Front Royal STP.

The operation of sludge pump and supernatant pump station shall be on an as needed bases. The operation and maintenance of these pumps shall be in accordance with the manufacturers' recommendations, contained in Appendix "L" of this manual.

## V. MAINTENANCE

Routine maintenance shall be performed by the plant operator. Major repairs and equipment replacements shall be performed by Inboden Environmental Services, Inc. or Kappe Associates, Inc.

### Tools

Normal maintenance will be accomplished with common tools. These common tools shall be supplied by the College. Any special equipment will be supplied by the service representative.

### Spare Parts

The following spare parts will be stored at the College:

1. 1 each: Spare blower (The spare blower shall have identical features to the blower furnished with the plant. The blower shall be less motors and accessories and be packaged for storage.)
2. 6 each: snap caps
3. 6 each: diffusers
4. 4 each: froth nozzle
5. 2 each: blower belts
6. 2 each: complete set of blower bearings

These parts shall be stored at a dry inside location readily accessible for replacement.

## Maintenance Schedule

### General

Daily	1. Check motors for overheating by hand 2. Wash plant sidewalls
Weekly	1. Check effluent weir level
Monthly	1. Clean dust away from motor
Semi-Annually	1. Check valves for leaks 2. Clean spray pump screen
Yearly	1. Repaint effluent weir 2. Clean and repaint metal surfaces 3. Scrape and paint all exposed steel

### Electrical

Monthly	1. Inspect breakers, fuses, and resets
Yearly	1. Check electrical leads

### Comminutor

Monthly	1. Check oil level 2. Check cutting efficiency
Semi-Annually	1. Grease Comminutor

### Aerator Blowers

Daily	1. Check air valve settings
Weekly	1. Inspect V-belt for slippage
Monthly	1. Check pulley alignment 2. Clean air filter 3. Oil pressure relief valve 4. Inspect V-belt for wear 5. Check oil level

6. Grease bearings
7. Check motor mounting bolts

### Clarifier

Daily	<ol style="list-style-type: none"><li>1. Clean tank walls</li><li>2. Skim scum from scum baffles</li><li>3. Hose down weirs and scum</li></ol>
Semi-annually	<ol style="list-style-type: none"><li>1. Take out of service and inspect all mechanical equipment wear and corrosion.</li><li>2. Check all moving parts for wear</li><li>3. Replace moving parts, if necessary</li><li>4. Check weirs to make sure they are level</li></ol>

### Hypochlorinator

For all maintenance of the hypochlorinator see Appendix "J".

### Cascade Aerator

Daily	<ol style="list-style-type: none"><li>1. Clean any deposits or debris</li></ol>
-------	---

### Maintenance Records

The College shall institute procedures for maintaining an equipment record system. Each major component of the plant shall have an equipment record maintained on it.

The Vice President of Operations shall have ultimate responsibility for the maintenance of the equipment record system and review the records at a minimum of once per year. The Vice President of Operations may day to day keeping of the equipment records to the designated operator.

The equipment records shall be kept in a 3-ring binder catalog in the office of the Vice President of Operations.

The maintenance record for each piece of equipment shall include the following:

1. Common Name:
2. Function:
3. Date of Purchase:
4. Manufacturer model number:
5. Serial Number:
6. Notes:
7. Listings of Corrective or Emergency Maintenance work: A detailed description of the problem, its source, and curative procedures shall be attached to the maintenance record for each piece of equipment.

Sample Maintenance Record Forms are shown in Appendix “G”.

## VI. SAMPLING AND LABORATORY TESTING

All field monitoring and sampling shall be done by the contract operator. Required field monitoring and sample types are listed on the VPDES permit.

Sampling: Influent and other process control samples may be taken at any time to diagnose a biological issue or quantify various parameters within the treatment waste. All effluent samples are taken from a point following the cascade aerator. All samples are either classified as “composite” or “grab” samples. A “composite” sample is composited from many individual samples collected at regular intervals over a period of time. The volume of each sample is taken proportional to the flow a rate at the time of sampling. A “grab” sample is a single sample collected at one individual sampling event and does not reflect the current flow rate. Required sampling parameters and frequencies are specified in the VPDES Permit No: VA0067067. Sample results must be reported within the Discharge Monitoring Report (DMR) and sent to DEQ each month. A copy of the DMR is included as Appendix “B”.

The following principles are to be followed in order to collect a representative sample:

1. Samples should be taken after post-aeration.
2. Sample are to be preserved and cooled properly.
3. Sample containers shall be clean and not contaminated during sampling.

**Christendom College STP**

WASTEWATER TREATMENT

Inboden Environmental Services, Inc.

Mt. Jackson, Va. 22842

*Inboden Environmental Services, Inc.*

VA0067067

**Foam Log****MONTH**

Are floating solids or is visible foam present beyond a trace (barely noticeable) amount?

Month and Year:

Day	Sample Pt.		Stream		If so, check for cause. action to be taken (if any):
	YES	NO	YES	NO	
1					
2					
3					
4					
5					
6					
7					
8					
9					
10					
11					
12					
13					
14					
15					
16					
17					
18					
19					
20					
21					
22					
23					
24					
25					
26					
27					
28					
29					
30					
31					

Can foam be created by turbulence upstream of outfall?